

This information was generated by the HP KEYMARK database on 23 Jun 2022

[Login](#)

Summary of	Sphera EVO 2.0 Invisible 4.1, 5.1	Reg. No.	ICIM-PDC-000159
Certificate Holder			
Name	Clivet s.p.a.		
Address	Via camp lonc 25 c.ap.	Zip	I-32032
City	z.i. Villapaiera - Feltre (BL)	Country	Italy
Certification Body	ICIM S.p.A.		
Subtype title	Sphera EVO 2.0 Invisible 4.1, 5.1		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	1.65 kg		
Certification Date	15.04.2022		
Testing basis	HP KEYMARK certification scheme rules rev. n. 9		

Model: SQKN-YEE 1 IC A + MiSAN-YEE 1 S 4.1

Configure model	
Model name	SQKN-YEE 1 IC A + MiSAN-YEE 1 S 4.1
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	8.30 kW	7.50 kW
El input	1.56 kW	2.35 kW
COP	5.31	3.19

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	dB(A)	41 dB(A)
Sound power level outdoor	dB(A)	58 dB(A)

EN 14825		
----------	--	--

This information was generated by the HP KEYMARK database on 23 Jun 2022

	Low temperature	Medium temperature
η_s	210 %	146 %
Prated	8.08 kW	6.88 kW
SCOP	5.32	3.72
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.15 kW	6.09 kW
COP Tj = -7°C	3.30	2.27
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	4.65 kW	3.94 kW
COP Tj = +2°C	5.17	3.56
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	2.91 kW	2.52 kW
COP Tj = +7°C	7.08	4.70
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.85 kW	1.72 kW
COP Tj = 12°C	9.46	9.71
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	7.15 kW	6.09 kW
COP Tj = Tbiv	3.30	2.27
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.42 kW	4.97 kW

This information was generated by the HP KEYMARK database on 23 Jun 2022

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.06	1.88
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	65 °C	65 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	1.66 kW	1.91 kW
Annual energy consumption Qhe	3141 kWh	3824 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	115 %
COP	2.60
Heating up time	01:50 h:min
Standby power input	54.0 W
Reference hot water temperature	49.0 °C
Mixed water at 40°C	188 l

Model: SQKN-YEE 1 IC A + MiSAN-YEE 1 S 5.1

Configure model

Model name	SQKN-YEE 1 IC A + MiSAN-YEE 1 S 5.1
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	10.30 kW	9.60 kW
El input	2.01 kW	3.10 kW
COP	5.01	3.10

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	dB(A)	41 dB(A)
Sound power level outdoor	dB(A)	60 dB(A)

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	Low temperature	Medium temperature
η_s	208 %	146 %
Prated	9.55 kW	8.57 kW
SCOP	5.27	3.73
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.45 kW	7.58 kW
COP Tj = -7°C	3.18	2.02
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.23 kW	4.44 kW
COP Tj = +2°C	5.03	3.63
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.47 kW	2.92 kW
COP Tj = +7°C	7.33	4.95
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.96 kW	1.74 kW
COP Tj = 12°C	9.94	9.87
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	8.45 kW	7.58 kW
COP Tj = Tbiv	3.18	2.02
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.38 kW	5.46 kW

This information was generated by the HP KEYMARK database on 23 Jun 2022

COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.97	1.87
Cdh $T_j = TOL$ or Pdh $T_j = T_{designh}$ if $TOL < T_{designh}$	0.900	0.900
WTOL	65 °C	65 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	2.17 kW	3.11 kW
Annual energy consumption Qhe	3747 kWh	4749 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	115 %
COP	2.60
Heating up time	01:50 h:min
Standby power input	54.0 W
Reference hot water temperature	49.0 °C
Mixed water at 40°C	188 l