

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	RSJ-16/190	Reg. No.	ICIM-PDC-000039
Certificate Holder			
Name	GD Midea Heating & Ventilating Equipment Co., Ltd.		
Address	Penglai Industry Road	Zip	528311
City	Beijiao, Shunde, Foshan	Country	China
Certification Body	ICIM S.p.A.		
Subtype title	RSJ-16/190		
Heat Pump Type	Heat Pump for Domestic Hot Water (DHW)		
Refrigerant	R134a		
Mass of Refrigerant	1.1 kg		
Certification Date	25.06.2019		

Model: RSJ-16/190

Configure model

Model name	RSJ-16/190
Units	Indoor
Climate zone (for heating)	n/a
Heat Source	n/a
Any additional heat sources	n/a

General Data

Power supply	1x230V 50Hz
Off-peak product	No

Domestic Hot Water (DHW)

Average Climate

EN 16147

Declared load profile	L
Efficiency η_{DHW}	115 %
COP	2.76
Reference hot water temperature	53.8 °C
Mixed water at 40°C	234 l
Heating up time	7:01 h:min
Standby power input	26.3 W

EN 12102-2

Sound power level indoor	51 dB(A)
--------------------------	----------