

This information was generated by the HP KEYMARK database on 23 Jun 2022

[Login](#)

Summary of	LA 35TBS	Reg. No.	40054223
Certificate Holder			
Name	Glen Dimplex Deutschland GmbH		
Address	Am Goldenen Feld 18	Zip	D-95326
City	Kulmbach	Country	Germany
Certification Body	VDE Prüf- und Zertifizierungsinstitut GmbH		
Subtype title	LA 35TBS		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R407c		
Mass of Refrigerant	5.6 kg		
Certification Date	21.10.2021		
Testing basis	DIN EN 14511-1:2019-07; EN 14511-1:2018 , DIN EN 14511-2:2019-07; EN 14511-2:2018, DIN EN 14511-3:2019-07; EN 14511-3:2018, DIN EN 14511-4:2019-07; EN 14511-4:2018, DIN EN 14825:2019-07; EN 14825:2018, DIN EN 12102-1:2018-02; EN 12102-1:2017		

Model: LA 35TBS

Configure model

Model name	LA 35TBS
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	17.60 kW	17.40 kW
El input	4.07 kW	5.58 kW
COP	4.33	3.11

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 23 Jun 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	152 %	125 %
Prated	20.70 kW	20.70 kW
SCOP	3.87	3.21
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	21.80 kW	22.20 kW
COP Tj = -7°C	3.02	2.36
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	14.30 kW	14.10 kW
COP Tj = +2°C	3.88	3.22
Cdh Tj = +2 °C	0.990	1.000
Pdh Tj = +7°C	18.00 kW	17.60 kW
COP Tj = +7°C	4.79	3.95
Cdh Tj = +7 °C	0.990	1.000
Pdh Tj = 12°C	21.90 kW	21.30 kW

This information was generated by the HP KEYMARK database on 23 Jun 2022

COP Tj = 12°C	5.72	4.93
Cdh Tj = +12 °C	0.990	1.000
Pdh Tj = Tbiv	20.50 kW	20.60 kW
COP Tj = Tbiv	2.90	2.17
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	20.50 kW	20.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.90	2.17
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.000	1.000
WTOL	60 °C	60 °C
Poff	20 W	20 W
PTO	20 W	20 W
PSB	20 W	20 W
PCK	88 W	88 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.20 kW	0.10 kW
Annual energy consumption Qhe	11198 kWh	13342 kWh