

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	LWV 82 Inverter	Reg. No.	041-K001-23
Certificate Holder			
Name	ait-deutschland GmbH		
Address	Industriestr. 3	Zip	95359
City	Kasendorf	Country	Germany
Certification Body	BRE Energy & Communications Division		
Name of testing laboratory	WPZ		
Subtype title	LWV 82 Inverter		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410a		
Mass Of Refrigerant	3 kg		
Certification Date	27.03.2019		

## Model: LWCV 82R1/3

### General Data

Power supply	1x230V 50Hz
--------------	-------------

## Heating

### EN 14511-2

	Low temperature	Medium temperature
Heat output	2.81 kW	3.28 kW
El input	0.56 kW	0.87 kW
COP	5.02	2.85
Indoor water flow rate	0.36 m <sup>3</sup> /h	0.36 m <sup>3</sup> /h

### EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

## Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	48 dB(A)	48 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	180 %	135 %
Prated	6.70 kW	5.65 kW
SCOP	4.57	3.44
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.88 kW	5.04 kW
COP Tj = -7°C	3.26	2.31
Pdh Tj = +2°C	3.84 kW	3.48 kW
COP Tj = +2°C	4.70	3.43
Pdh Tj = +7°C	3.27 kW	3.04 kW
COP Tj = +7°C	5.97	4.86
Pdh Tj = 12°C	3.36 kW	3.39 kW
COP Tj = 12°C	7.92	6.56
Pdh Tj = Tbiv	5.88 kW	5.04 kW
COP Tj = Tbiv	3.26	2.31

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	5.11 kW	4.23 kW
COP Tj = TOL	3.18	2.12
Cdh	1.00	1.00
WTOL	60 °C	60 °C
Poff	31 W	31 W
PTO	0 W	0 W
PSB	31 W	31 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.59 kW	1.42 kW
Annual energy consumption Qhe	3029 kWh	3390 kWh

## Warmer Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	48 dB(A)	48 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	214 %	156 %
Prated	4.10 kW	5.50 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

SCOP	5.43	3.99
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	4.07 kW	5.55 kW
COP Tj = +2°C	4.15	2.69
Pdh Tj = +7°C	3.06 kW	3.86 kW
COP Tj = +7°C	5.65	3.70
Pdh Tj = 12°C	3.60 kW	3.50 kW
COP Tj = 12°C	8.43	5.60
Pdh Tj = Tbiv	4.20 kW	5.55 kW
COP Tj = Tbiv	4.28	2.69
Pdh Tj = TOL	4.20 kW	5.55 kW
COP Tj = TOL	4.28	2.69
Cdh	1.00	1.00
WTOL	60 °C	60 °C
Poff	31 W	31 W
PTO	0 W	0 W
PSB	31 W	31 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

Annual energy consumption Q <sub>he</sub>	1009 kWh	1844 kWh
---	----------	----------

## Colder Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	48 dB(A)	48 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	145 %	127 %
Prated	6.50 kW	5.00 kW
SCOP	3.69	3.26
T <sub>biv</sub>	-15 °C	-15 °C
TOL	-22 °C	-22 °C
P <sub>dh</sub> T <sub>j</sub> = -7°C	5.60 kW	6.25 kW
COP T <sub>j</sub> = -7°C	3.17	2.69
P <sub>dh</sub> T <sub>j</sub> = +2°C	4.02 kW	3.33 kW
COP T <sub>j</sub> = +2°C	5.27	4.14
P <sub>dh</sub> T <sub>j</sub> = +7°C	3.12 kW	3.48 kW
COP T <sub>j</sub> = +7°C	6.04	5.25
P <sub>dh</sub> T <sub>j</sub> = 12°C	4.21 kW	3.70 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

COP Tj = 12°C	9.50	7.52
Pdh Tj = Tbiv	3.56 kW	4.03 kW
COP Tj = Tbiv	2.43	1.98
Pdh Tj = TOL	1.73 kW	5.58 kW
COP Tj = TOL	1.56	2.24
Cdh	1.00	1.00
WTOL	60 °C	60 °C
Poff	31 W	31 W
PTO	0 W	0 W
PSB	31 W	31 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	4.77 kW	0.00 kW
Annual energy consumption Qhe	4339 kWh	3781 kWh

## Model: LWV 82R1/3

### General Data

Power supply	1x230V 50Hz
--------------	-------------

## Heating

### EN 14511-2

	Low temperature	Medium temperature
Heat output	2.81 kW	3.28 kW
El input	0.56 kW	0.87 kW
COP	5.02	2.85
Indoor water flow rate	0.36 m <sup>3</sup> /h	0.36 m <sup>3</sup> /h

### EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

## Average Climate



This information was generated by the HP KEYMARK database on 17 Dec 2020

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	48 dB(A)	48 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	180 %	135 %
Prated	6.70 kW	5.65 kW
SCOP	4.57	3.44
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.88 kW	5.04 kW
COP Tj = -7°C	3.26	2.31
Pdh Tj = +2°C	3.84 kW	3.48 kW
COP Tj = +2°C	4.70	3.43
Pdh Tj = +7°C	3.27 kW	3.04 kW
COP Tj = +7°C	5.97	4.86
Pdh Tj = 12°C	3.36 kW	3.39 kW
COP Tj = 12°C	7.92	6.56
Pdh Tj = Tbiv	5.88 kW	5.04 kW
COP Tj = Tbiv	3.26	2.31

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	5.11 kW	4.23 kW
COP Tj = TOL	3.18	2.12
Cdh	1.00	1.00
WTOL	60 °C	60 °C
Poff	31 W	31 W
PTO	0 W	0 W
PSB	31 W	31 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.59 kW	1.42 kW
Annual energy consumption Qhe	3029 kWh	3390 kWh

## Warmer Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	48 dB(A)	48 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	214 %	156 %
Prated	4.10 kW	5.50 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

SCOP	5.43	3.99
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	4.07 kW	5.55 kW
COP Tj = +2°C	4.15	2.69
Pdh Tj = +7°C	3.06 kW	3.86 kW
COP Tj = +7°C	5.65	3.70
Pdh Tj = 12°C	3.60 kW	3.50 kW
COP Tj = 12°C	8.43	5.60
Pdh Tj = Tbiv	4.20 kW	5.55 kW
COP Tj = Tbiv	4.28	2.69
Pdh Tj = TOL	4.20 kW	5.55 kW
COP Tj = TOL	4.28	2.69
Cdh	1.00	1.00
WTOL	60 °C	60 °C
Poff	31 W	31 W
PTO	0 W	0 W
PSB	31 W	31 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

Annual energy consumption Q <sub>he</sub>	1009 kWh	1844 kWh
---	----------	----------

## Colder Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	48 dB(A)	48 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	145 %	127 %
Prated	6.50 kW	5.00 kW
SCOP	3.69	3.26
T <sub>biv</sub>	-15 °C	-15 °C
TOL	-22 °C	-22 °C
P <sub>dh</sub> T <sub>j</sub> = -7°C	5.60 kW	6.25 kW
COP T <sub>j</sub> = -7°C	3.17	2.69
P <sub>dh</sub> T <sub>j</sub> = +2°C	4.02 kW	3.33 kW
COP T <sub>j</sub> = +2°C	5.27	4.14
P <sub>dh</sub> T <sub>j</sub> = +7°C	3.12 kW	3.48 kW
COP T <sub>j</sub> = +7°C	6.04	5.25
P <sub>dh</sub> T <sub>j</sub> = 12°C	4.21 kW	3.70 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

COP Tj = 12°C	9.50	7.52
Pdh Tj = Tbiv	3.56 kW	4.03 kW
COP Tj = Tbiv	2.43	1.98
Pdh Tj = TOL	1.73 kW	5.58 kW
COP Tj = TOL	1.56	2.24
Cdh	1.00	1.00
WTOL	60 °C	60 °C
Poff	31 W	31 W
PTO	0 W	0 W
PSB	31 W	31 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	4.77 kW	0.00 kW
Annual energy consumption Qhe	4339 kWh	3781 kWh

## Model: LWAV 82R1/3

### General Data

Power supply	1x230V 50Hz
--------------	-------------

## Heating

### EN 14511-2

	Low temperature	Medium temperature
Heat output	2.81 kW	3.28 kW
El input	0.56 kW	0.87 kW
COP	5.02	2.85
Indoor water flow rate	0.36 m <sup>3</sup> /h	0.36 m <sup>3</sup> /h

### EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

## Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	48 dB(A)	48 dB(A)
Sound power level outdoor	50 dB(A)	50 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	180 %	135 %
Prated	6.70 kW	5.65 kW
SCOP	4.57	3.44
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.88 kW	5.04 kW
COP Tj = -7°C	3.26	2.31
Pdh Tj = +2°C	3.84 kW	3.48 kW
COP Tj = +2°C	4.70	3.43
Pdh Tj = +7°C	3.27 kW	3.04 kW
COP Tj = +7°C	5.97	4.86
Pdh Tj = 12°C	3.36 kW	3.39 kW
COP Tj = 12°C	7.92	6.56
Pdh Tj = Tbiv	5.88 kW	5.04 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

COP Tj = Tbiv	3.26	2.31
Pdh Tj = TOL	5.11 kW	4.23 kW
COP Tj = TOL	3.18	2.12
Cdh	1.00	1.00
WTOL	60 °C	60 °C
Poff	31 W	31 W
PTO	0 W	0 W
PSB	31 W	31 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.59 kW	1.42 kW
Annual energy consumption Qhe	3029 kWh	3390 kWh

## Warmer Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	48 dB(A)	48 dB(A)
Sound power level outdoor	50 dB(A)	50 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>



This information was generated by the HP KEYMARK database on 17 Dec 2020

$\eta_s$	214 %	156 %
Prated	4.10 kW	5.50 kW
SCOP	5.43	3.99
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	4.07 kW	5.55 kW
COP Tj = +2°C	4.15	2.69
Pdh Tj = +7°C	3.06 kW	3.86 kW
COP Tj = +7°C	5.65	3.70
Pdh Tj = 12°C	3.60 kW	3.50 kW
COP Tj = 12°C	8.43	5.60
Pdh Tj = Tbiv	4.20 kW	5.55 kW
COP Tj = Tbiv	4.28	2.69
Pdh Tj = TOL	4.20 kW	5.55 kW
COP Tj = TOL	4.28	2.69
Cdh	1.00	1.00
WTOL	60 °C	60 °C
Poff	31 W	31 W
PTO	0 W	0 W
PSB	31 W	31 W
PCK	0 W	0 W

This information was generated by the HP KEYMARK database on 17 Dec 2020

Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q <sub>he</sub>	1009 kWh	1844 kWh

## Colder Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	48 dB(A)	48 dB(A)
Sound power level outdoor	50 dB(A)	50 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	145 %	127 %
Prated	6.50 kW	5.00 kW
SCOP	3.69	3.26
T <sub>biv</sub>	-15 °C	-15 °C
TOL	-22 °C	-22 °C
P <sub>dh</sub> T <sub>j</sub> = -7°C	5.60 kW	6.25 kW
COP T <sub>j</sub> = -7°C	3.17	2.69
P <sub>dh</sub> T <sub>j</sub> = +2°C	4.02 kW	3.33 kW
COP T <sub>j</sub> = +2°C	5.27	4.14

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = +7°C	3.12 kW	3.48 kW
COP Tj = +7°C	6.04	5.25
Pdh Tj = 12°C	4.21 kW	3.70 kW
COP Tj = 12°C	9.50	7.52
Pdh Tj = Tbiv	3.56 kW	4.03 kW
COP Tj = Tbiv	2.43	1.98
Pdh Tj = TOL	1.73 kW	5.58 kW
COP Tj = TOL	1.56	2.24
Cdh	1.00	1.00
WTOL	60 °C	60 °C
Poff	31 W	31 W
PTO	0 W	0 W
PSB	31 W	31 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	4.77 kW	0.00 kW
Annual energy consumption Qhe	4339 kWh	3781 kWh

## Model: LWAV+ 82R1/3

### General Data

Power supply	1x230V 50Hz
--------------	-------------

## Heating

### EN 14511-2

	Low temperature	Medium temperature
Heat output	2.81 kW	3.28 kW
El input	0.56 kW	0.87 kW
COP	5.02	2.85
Indoor water flow rate	0.36 m <sup>3</sup> /h	0.36 m <sup>3</sup> /h

### EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

## Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	48 dB(A)	48 dB(A)
Sound power level outdoor	50 dB(A)	50 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	180 %	135 %
Prated	6.70 kW	5.65 kW
SCOP	4.57	3.44
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.88 kW	5.04 kW
COP Tj = -7°C	3.26	2.31
Pdh Tj = +2°C	3.84 kW	3.48 kW
COP Tj = +2°C	4.70	3.43
Pdh Tj = +7°C	3.27 kW	3.04 kW
COP Tj = +7°C	5.97	4.86
Pdh Tj = 12°C	3.36 kW	3.39 kW
COP Tj = 12°C	7.92	6.56
Pdh Tj = Tbiv	5.88 kW	5.04 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

COP Tj = Tbiv	3.26	2.31
Pdh Tj = TOL	5.11 kW	4.23 kW
COP Tj = TOL	3.18	2.12
Cdh	1.00	1.00
WTOL	60 °C	60 °C
Poff	31 W	31 W
PTO	0 W	0 W
PSB	31 W	31 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.59 kW	1.42 kW
Annual energy consumption Qhe	3029 kWh	3390 kWh

## Warmer Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	48 dB(A)	48 dB(A)
Sound power level outdoor	50 dB(A)	50 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>

This information was generated by the HP KEYMARK database on 17 Dec 2020

$\eta_s$	214 %	156 %
Prated	4.10 kW	5.50 kW
SCOP	5.43	3.99
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	4.07 kW	5.55 kW
COP Tj = +2°C	4.15	2.69
Pdh Tj = +7°C	3.06 kW	3.86 kW
COP Tj = +7°C	5.65	3.70
Pdh Tj = 12°C	3.60 kW	3.50 kW
COP Tj = 12°C	8.43	5.60
Pdh Tj = Tbiv	4.20 kW	5.55 kW
COP Tj = Tbiv	4.28	2.69
Pdh Tj = TOL	4.20 kW	5.55 kW
COP Tj = TOL	4.28	2.69
Cdh	1.00	1.00
WTOL	60 °C	60 °C
Poff	31 W	31 W
PTO	0 W	0 W
PSB	31 W	31 W
PCK	0 W	0 W

This information was generated by the HP KEYMARK database on 17 Dec 2020

Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q <sub>he</sub>	1009 kWh	1844 kWh

## Colder Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	48 dB(A)	48 dB(A)
Sound power level outdoor	50 dB(A)	50 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	145 %	127 %
Prated	6.50 kW	5.00 kW
SCOP	3.69	3.26
T <sub>biv</sub>	-15 °C	-15 °C
TOL	-22 °C	-22 °C
P <sub>dh</sub> T <sub>j</sub> = -7°C	5.60 kW	6.25 kW
COP T <sub>j</sub> = -7°C	3.17	2.69
P <sub>dh</sub> T <sub>j</sub> = +2°C	4.02 kW	3.33 kW
COP T <sub>j</sub> = +2°C	5.27	4.14



This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = +7°C	3.12 kW	3.48 kW
COP Tj = +7°C	6.04	5.25
Pdh Tj = 12°C	4.21 kW	3.70 kW
COP Tj = 12°C	9.50	7.52
Pdh Tj = Tbiv	3.56 kW	4.03 kW
COP Tj = Tbiv	2.43	1.98
Pdh Tj = TOL	1.73 kW	5.58 kW
COP Tj = TOL	1.56	2.24
Cdh	1.00	1.00
WTOL	60 °C	60 °C
Poff	31 W	31 W
PTO	0 W	0 W
PSB	31 W	31 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	4.77 kW	0.00 kW
Annual energy consumption Qhe	4339 kWh	3781 kWh