

Page 1 of 4

This information was generated by the HP KEYMARK database on 22 Jun 2022

Login

Summary of	BoxAir Inverter BA26IS-1	Reg. No.	037-0069-21
Certificate Holder			
Name	Master Therm tepelna cerpadla s.r.o.		
Address	Vaclavske namesti 819/43	Zip	110 00
City	Praha	Country	Czech Republic
Certification Body	SZU - Strojirensky zkusebni ustav (Engineering Test Institute, Public Enterprise)		
Subtype title	BoxAir Inverter BA26IS-1		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	2.3 kg		
Certification Date	26.01.2021		
Testing basis	HP Keymark scheme rules rev. no. 7		



This information was generated by the HP KEYMARK database on 22 Jun 2022

Model: BoxAir Inverter BA26IS-1

Configure model			
Model name	BoxAir Inverter BA26IS-1		
Application	Heating (medium temp)		
Units	Indoor + Outdoor		
Climate Zone	n/a		
Reversibility	Yes		
Cooling mode application (optional)	n/a		

General Data		
Power supply	1x230V 50Hz	

Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	8.10 kW	7.28 kW	
El input	1.75 kW	2.46 kW	
СОР	4.63	2.96	

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate



 $$\operatorname{\textit{Page}}\ 3$$ of 4 This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	48 dB(A)	48 dB(A)	
Sound power level outdoor	55 dB(A)	55 dB(A)	

EN 14825		
Low temperature	Medium temperature	
168 %	126 %	
6.51 kW	6.33 kW	
4.29	3.24	
-7 °C	-7 °C	
-10 °C	-10 °C	
5.76 kW	5.60 kW	
2.59	1.94	
0.90	0.90	
3.72 kW	3.50 kW	
3.92	3.02	
0.90	0.90	
2.42 kW	2.33 kW	
6.53	4.69	
0.90	0.90	
	Low temperature 168 % 6.51 kW 4.29 -7 °C -10 °C 5.76 kW 2.59 0.90 3.72 kW 3.92 0.90 2.42 kW 6.53	

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 4 of 4 This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	2.74 kW	2.78 kW
Tull 1] = 12 C	2./7 NVV	Z./O NVV
COP Tj = 12°C	7.82	5.93
Cdh Tj = +12 °C	0.95	0.96
Pdh Tj = Tbiv	5.76 kW	5.60 kW
COP Tj = Tbiv	2.59	1.94
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.88 kW	5.66 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.52	1.82
WTOL	60 °C	60 °C
Poff	18 W	18 W
РТО	17 W	17 W
PSB	18 W	18 W
PCK	o w	o w
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.64 kW	0.67 kW
Annual energy consumption Qhe	3139 kWh	4039 kWh