

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	Jäspi Inverter Nordic 12	Reg. No.	012-SC0654-18
Certificate Holder			
Name	Kaukora		
Address	Tuotekatu 11	Zip	FI-21200
City	Raisio	Country	Finland
Certification Body	RISE CERT		
Subtype title	Jäspi Inverter Nordic 12		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	2.6 kg		

Model: Jäspi Inverter Nordic 12

Configure model	
Model name	Jäspi Inverter Nordic 12
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	3.54 kW	3.64 kW
El input	0.69 kW	1.18 kW
COP	5.12	3.08

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	53 dB(A)	53 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	190 %	148 %
Prated	8.00 kW	8.30 kW
SCOP	4.82	3.27
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.10 kW	7.30 kW
COP Tj = -7°C	3.05	2.39
Pdh Tj = +2°C	4.70 kW	4.70 kW
COP Tj = +2°C	4.57	3.85
Pdh Tj = +7°C	3.10 kW	2.90 kW
COP Tj = +7°C	5.86	4.48
Pdh Tj = 12°C	3.60 kW	3.30 kW
COP Tj = 12°C	7.22	5.30
Pdh Tj = Tbiv	7.10 kW	7.30 kW
COP Tj = Tbiv	2.95	2.28

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.30 kW	7.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.05	2.39
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.99	0.99
WTOL	65 °C	65 °C
Poff	25 W	25 W
PTO	7 W	7 W
PSB	25 W	25 W
PCK	37 W	37 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.70 kW	0.50 kW
Annual energy consumption Qhe	3409 kWh	4529 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	53 dB(A)	53 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	159 %	130 %
Prated	9.30 kW	9.80 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

SCOP	4.05	3.32
Tbiv	-12 °C	-12 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	5.70 kW	5.90 kW
COP Tj = -7°C	3.33	2.74
Pdh Tj = +2°C	3.40 kW	3.60 kW
COP Tj = +2°C	5.18	4.14
Pdh Tj = +7°C	2.90 kW	2.90 kW
COP Tj = +7°C	5.73	4.70
Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	6.44	5.41
Pdh Tj = Tbiv	6.90 kW	7.30 kW
COP Tj = Tbiv	2.99	2.47
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.20 kW	6.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.31	1.84
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.99	0.99
WTOL	65 °C	65 °C
Poff	25 W	25 W
PTO	7 W	7 W
PSB	25 W	25 W
PCK	37 W	37 W

This information was generated by the HP KEYMARK database on 18 Mar 2022

Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.10 kW	3.80 kW
Annual energy consumption Q _{he}	5666 kWh	7239 kWh