

This information was generated by the HP KEYMARK database on 7 Jul 2022

[Login](#)

Summary of	WPL 09 I(K)CS classic	Reg. No.	011-1W0223
Certificate Holder			
Name	STIEBEL ELTRON GmbH & Co KG		
Address	Dr. Stiebel Straße 33	Zip	37603
City	Holzminden	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	WPL 09 I(K)CS classic		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	2.2 kg		
Certification Date	04.09.2019		
Testing basis	HP KEYMARK certification scheme rules rev. no. 5		

Model: WPL 09 IKCS classic

Configure model	
Model name	WPL 09 IKCS classic
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	2.06 kW	2.09 kW
El input	0.44 kW	0.81 kW
COP	4.68	2.59

Warmer Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	45 dB(A)	45 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	198 %	136 %
Prated	2.62 kW	2.40 kW
SCOP	5.01	3.47
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	2.62 kW	2.37 kW
COP Tj = +2°C	3.76	2.28
Pdh Tj = +7°C	2.07 kW	1.84 kW
COP Tj = +7°C	5.19	3.35
Pdh Tj = 12°C	2.00 kW	1.94 kW
COP Tj = 12°C	7.92	5.39
Pdh Tj = Tbiv	2.62 kW	2.37 kW
COP Tj = Tbiv	3.76	2.28
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	2.62 kW	2.37 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.76	2.28

This information was generated by the HP KEYMARK database on 7 Jul 2022

$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.90	0.90
WTOL	60 °C	60 °C
Poff	56 W	56 W
PTO	21 W	21 W
PSB	56 W	56 W
PCK	26 W	26 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.03 kW
Annual energy consumption Q_{he}	698 kWh	923 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	45 dB(A)	45 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	150 %	116 %
Prated	6.80 kW	6.70 kW
SCOP	3.83	2.98
Tbiv	-7 °C	-7 °C

This information was generated by the HP KEYMARK database on 7 Jul 2022

TOL	-20 °C	-20 °C
Pdh Tj = -7°C	4.11 kW	4.05 kW
COP Tj = -7°C	3.37	2.57
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	3.01 kW	2.60 kW
COP Tj = +2°C	5.17	3.55
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	2.09 kW	2.07 kW
COP Tj = +7°C	7.26	5.31
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	2.02 kW	1.99 kW
COP Tj = 12°C	8.96	7.11
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	4.11 kW	4.05 kW
COP Tj = Tbiv	3.37	2.57
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	2.35 kW	6.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.99	1.00
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	56 W	56 W
PTO	21 W	21 W

This information was generated by the HP KEYMARK database on 7 Jul 2022

PSB	56 W	56 W
PCK	26 W	26 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.45 kW	3.50 kW
Annual energy consumption Q _{he}	4382 kWh	5547 kWh
P _{dh} T _j = -15 °C (if TOL < -20 °C)	4.11	4.05
COP T _j = -15 °C (if TOL < -20 °C)	3.37	2.57
C _{dh} T _j = -15 °C	0.90	0.90

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	45 dB(A)	45 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	175 %	128 %
Prated	4.70 kW	4.50 kW
SCOP	4.46	3.28
T _{biv}	-7 °C	-7 °C
TOL	-10 °C	-10 °C

This information was generated by the HP KEYMARK database on 7 Jul 2022

Pdh Tj = -7°C	4.17 kW	3.94 kW
COP Tj = -7°C	3.09	2.22
Pdh Tj = +2°C	2.86 kW	2.54 kW
COP Tj = +2°C	4.29	3.10
Pdh Tj = +7°C	2.08 kW	2.04 kW
COP Tj = +7°C	6.24	4.53
Pdh Tj = 12°C	2.02 kW	1.97 kW
COP Tj = 12°C	8.31	6.44
Pdh Tj = Tbiv	4.17 kW	3.94 kW
COP Tj = Tbiv	3.09	2.22
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.06 kW	2.96 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.71	1.94
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	56 W	56 W
PTO	21 W	21 W
PSB	56 W	56 W
PCK	26 W	26 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.64 kW	1.54 kW
Annual energy consumption Qhe	2187 kWh	2837 kWh

Model: WPL 09 ICS classic

Configure model	
Model name	WPL 09 ICS classic
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	2.06 kW	2.10 kW
El input	0.44 kW	0.80 kW
COP	4.68	2.64

Warmer Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	45 dB(A)	45 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	198 %	136 %
Prated	2.64 kW	2.40 kW
SCOP	5.03	3.48
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	2.64 kW	2.39 kW
COP Tj = +2°C	3.83	2.33
Pdh Tj = +7°C	2.07 kW	1.84 kW
COP Tj = +7°C	5.19	3.35
Pdh Tj = 12°C	2.00 kW	1.94 kW
COP Tj = 12°C	7.92	5.39
Pdh Tj = Tbiv	2.64 kW	2.39 kW
COP Tj = Tbiv	3.83	2.33
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	2.64 kW	2.39 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.83	2.33

This information was generated by the HP KEYMARK database on 7 Jul 2022

$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.90	0.90
WTOL	60 °C	60 °C
Poff	56 W	56 W
PTO	21 W	21 W
PSB	56 W	56 W
PCK	26 W	26 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.01 kW
Annual energy consumption Q_{he}	70 kWh	921 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	45 dB(A)	45 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	155 %	119 %
Prated	6.90 kW	6.80 kW
SCOP	3.94	3.04
Tbiv	-7 °C	-7 °C

This information was generated by the HP KEYMARK database on 7 Jul 2022

TOL	-20 °C	-20 °C
Pdh Tj = -7°C	4.16 kW	4.10 kW
COP Tj = -7°C	3.48	2.63
Pdh Tj = +2°C	3.03 kW	2.62 kW
COP Tj = +2°C	5.34	3.64
Pdh Tj = +7°C	2.09 kW	2.07 kW
COP Tj = +7°C	7.26	5.31
Pdh Tj = 12°C	2.02 kW	1.99 kW
COP Tj = 12°C	8.96	7.11
Pdh Tj = Tbiv	4.16 kW	4.10 kW
COP Tj = Tbiv	3.48	2.63
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.00 kW	3.16 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.00	2.50
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	56 W	56 W
PTO	21 W	21 W
PSB	56 W	56 W
PCK	26 W	26 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.54 kW	3.28 kW

This information was generated by the HP KEYMARK database on 7 Jul 2022

Annual energy consumption Q_{he}	4321 kWh	5515 kWh
------------------------------------	----------	----------

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	45 dB(A)	45 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	178 %	130 %
Prated	4.80 kW	4.50 kW
SCOP	4.53	3.32
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.22 kW	3.98 kW
COP Tj = -7°C	3.22	2.27
Pdh Tj = +2°C	2.88 kW	2.55 kW
COP Tj = +2°C	4.33	3.16
Pdh Tj = +7°C	2.08 kW	2.04 kW
COP Tj = +7°C	6.28	4.53
Pdh Tj = 12°C	2.02 kW	1.97 kW

This information was generated by the HP KEYMARK database on 7 Jul 2022

COP Tj = 12°C	8.35	6.44
Pdh Tj = Tbiv	4.22 kW	3.98 kW
COP Tj = Tbiv	3.22	2.27
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.11 kW	3.79 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.84	1.85
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	56 W	56 W
PTO	21 W	21 W
PSB	56 W	56 W
PCK	26 W	26 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.69 kW	0.71 kW
Annual energy consumption Qhe	2187 kWh	2804 kWh