Login

Summary of	PAC BT MB 5/7/9 kW 1ph	Reg. No.	ICIM-PDC-000008
Certificate Holder			
Name	Airwell Residential S.A.S.		
Address	10, rue du Fort de Saint Cyr	Zip	78180
City	Montigny le Bretonneux	Country	France
Certification Body	ICIM S.p.A.		
Subtype title	PAC BT MB 5/7/9 kW 1ph		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	2.4 kg		
Certification Date	30.07.2018		

Model: PAC BT MB 5KW H11

Configure model	
Model name	PAC BT MB 5KW H11
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	4.64 kW	4.80 kW
El input	0.97 kW	1.90 kW
COP	4.79	2.53

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	184 %	129 %
Prated	5.00 kW	7.00 kW
SCOP	4.67	3.30
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.10 kW	5.90 kW
COP Tj = -7°C	2.85	2.00
Pdh Tj = +2°C	2.40 kW	3.70 kW
COP Tj = +2°C	4.53	3.18
Pdh Tj = +7°C	1.70 kW	2.50 kW
COP Tj = +7°C	6.09	4.52
Pdh Tj = 12°C	1.30 kW	1.10 kW
COP Tj = 12°C	8.95	5.09
Pdh Tj = Tbiv	4.10 kW	5.90 kW
COP Tj = Tbiv	2.85	2.00

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.20 kW	6.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.63	1.80
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	49 °C	49 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	34 W	34 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2059 kWh	4202 kWh

Model: PAC BT MB 7KW H11

Configure model	
Model name	PAC BT MB 7KW H11
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	6.55 kW	6.20 kW
El input	1.45 kW	2.38 kW
COP	4.52	2.61

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	66 dB(A)	64 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	179 %	129 %
Prated	7.00 kW	7.00 kW
SCOP	4.54	3.30
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.80 kW	5.90 kW
COP Tj = -7°C	2.80	2.00
Pdh Tj = +2°C	3.60 kW	3.70 kW
COP Tj = +2°C	4.18	3.18
Pdh Tj = +7°C	2.30 kW	2.50 kW
COP Tj = +7°C	6.39	4.52
Pdh Tj = 12°C	1.40 kW	1.10 kW
COP Tj = 12°C	9.24	5.09
Pdh Tj = Tbiv	5.80 kW	5.90 kW
COP Tj = Tbiv	2.80	2.00

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.30 kW	6.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.61	1.80
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	49 °C	49 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	34 W	34 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2993 kWh	4202 kWh

Model: PAC BT MB 9KW H11

Configure model	
Model name	PAC BT MB 9KW H11
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	8.64 kW	9.40 kW
El input	2.01 kW	3.30 kW
COP	4.30	2.85

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	67 dB(A)	67 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	159 %	127 %
Prated	9.00 kW	9.00 kW
SCOP	4.05	3.26
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.83 kW	7.70 kW
COP Tj = -7°C	2.43	1.98
Pdh Tj = +2°C	4.95 kW	4.90 kW
COP Tj = +2°C	3.70	3.02
Pdh Tj = +7°C	3.18 kW	3.20 kW
COP Tj = +7°C	6.11	4.67
Pdh Tj = 12°C	1.51 kW	1.40 kW
COP Tj = 12°C	7.47	6.16
Pdh Tj = Tbiv	7.83 kW	7.70 kW
COP Tj = Tbiv	2.43	1.98

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.53 kW	7.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.38	1.78
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	49 °C	49 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	34 W	34 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.32 kW	0.00 kW
Annual energy consumption Qhe	4524 kWh	5558 kWh