

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	Buderus Logatherm WPS 8K-1	Reg. No.	011-1W0178
Certificate Holder			
Name	Bosch Thermotechnik GmbH (Buderus)		
Address	Sophienstraße 30-32	Zip	35576
City	Wetzlar	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Name of testing laboratory	IGE Institut für GebäudeEnergetik		
Subtype title	Buderus Logatherm WPS 8K-1		
Heat Pump Type	Brine/Water		
Refrigerant	R410a		
Mass Of Refrigerant	1.95 kg		

## Model: Buderus Logatherm WPS 8K-1

### General Data

Power supply	3x400V 50Hz
Off-peak product	No

## Heating

### EN 14511-2

	Low temperature	Medium temperature
Heat output	7.40 kW	6.85 kW
El input	1.66 kW	2.39 kW
COP	4.47	2.87
Indoor water flow rate	1.29 m <sup>3</sup> /h	0.75 m <sup>3</sup> /h

### EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

## Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	52 dB(A)	52 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	186 %	131 %
Prated	9.00 kW	8.00 kW
SCOP	4.85	3.48
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.50 kW	6.80 kW
COP Tj = -7°C	4.66	2.92
Pdh Tj = +2°C	7.60 kW	7.00 kW
COP Tj = +2°C	4.87	3.43
Pdh Tj = +7°C	7.70 kW	7.20 kW
COP Tj = +7°C	5.07	3.86
Pdh Tj = 12°C	7.80 kW	7.40 kW
COP Tj = 12°C	5.26	4.29
Pdh Tj = Tbiv	7.50 kW	6.80 kW
COP Tj = Tbiv	4.66	2.92

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	7.50 kW	6.70 kW
COP Tj = TOL	4.55	2.68
Cdh	1.00	1.00
WTOL	62 °C	62 °C
Poff	6 W	6 W
PTO	6 W	6 W
PSB	6 W	6 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electric	Electric
Supplementary Heater: PSUP	1.00 kW	1.00 kW
Annual energy consumption Qhe	3619 kWh	4540 kWh

## Domestic Hot Water (DHW)

### Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

<b>EN 16147</b>	
Declared load profile	L
Efficiency $\eta_{DHW}$	83 %
COP	2.09
Heating up time	01:29 h:min
Standby power input	59.8 W
Reference hot water temperature	50.3 °C
Mixed water at 40°C	235 l