

Page 1 of 11

This information was generated by the HP KEYMARK database on 18 Mar 2022

Login

Summary of	WPF 16 basic	Reg. No.	011-1W0189
Certificate Holder			
Name	STIEBEL ELTRON GmbH & Co KG		
Address	Dr. Stiebel Straße 33	Zip	37603
City	Holzminden	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	WPF 16 basic		
Heat Pump Type	Brine/Water		
Refrigerant	R410A		
Mass of Refrigerant	2.6 kg		
Certification Date	04.09.2019		



Model: WPF 16 basic, all climates


Configure model		
Model name WPF 16 basic, all climates		
Application	Heating (low temp)	
Units	Indoor	
Climate Zone	Colder Climate + Warmer Climate	
Reversibility	No	
Cooling mode application (optional)	n/a	

General Data		
Power supply	1x230V 50Hz	

Average Climate

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	65 dB(A)	65 dB(A)	

EN 14825			
	Low temperature	Medium temperature	
η_{S}	117 %	117 %	
Prated	17.00 kW	16.00 kW	
SCOP	4.80	3.18	
Tbiv	-10 °C	-10 °C	
TOL	-10 °C	-10 °C	
Pdh Tj = -7° C	16.70 kW	15.70 kW	
COP Tj = -7 °C	4.22	2.59	





Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	16.80 kW	16.10 kW
COP Tj = +2°C	4.54	3.06
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	16.90 kW	16.30 kW
COP Tj = +7°C	4.87	3.43
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	17.00 kW	16.50 kW
COP Tj = 12°C	5.26	3.88
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	16.60 kW	15.60 kW
COP Tj = Tbiv	4.16	2.48
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	16.60 kW	15.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.16	2.48
WTOL	60 °C	60 °C
Poff	0 W	0 W
РТО	78 W	78 W
PSB	3 W	3 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW



Annual energy consumption Qhe	7440 kWh	10353 kWh	


Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	16.64 kW	15.62 kW
El input	4.00 kW	6.34 kW
СОР	4.35	2.46

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	failed
Starting and operating test	passed


Warmer Climate

EN 14825			
	Low temperature	Medium temperature	
η_{s}	178 %	117 %	
Prated	17.00 kW	16.00 kW	
SCOP	4.98	3.20	





Tbiv	2 °C	2 °C
TOL	-5 °C	-5 °C
Pdh Tj = $+2$ °C	16.60 kW	15.60 kW
COP Tj = +2°C	4.16	2.48
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = $+7^{\circ}$ C	16.80 kW	15.90 kW
COP Tj = +7°C	4.47	3.84
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	16.90 kW	16.40 kW
COP Tj = 12°C	5.00	3.57
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	16.60 kW	15.60 kW
COP Tj = Tbiv	4.16	2.48
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	16.60 kW	15.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.16	2.48
WTOL	60 °C	60 °C
Poff	o w	0 W
РТО	78 W	78 W
PSB	3 W	3 W
РСК	0 W	o w
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW






|--|

EN 12102-1	
	Low temperature
Sound power level indoor	65 dB(A)

Colder Climate

EN 14825		
	Low temperature	Medium temperature
η_{s}	183 %	122 %
Prated	21.00 kW	20.00 kW
SCOP	5.08	3.30
Tbiv	-15 °C	-15 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	16.80 kW	16.10 kW
COP Tj = -7°C	4.71	3.04
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	16.90 kW	16.30 kW
COP Tj = +2°C	4.97	3.42
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	17.00 kW	16.50 kW





COP Tj = +7°C	5.20	3.79
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	17.00 kW	16.60 kW
COP Tj = 12°C	5.23	4.10
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	16.80 kW	15.90 kW
COP Tj = Tbiv	4.60	2.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	16.60 kW	15.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.16	2.48
WTOL	60 °C	60 °C
Poff	o w	o w
РТО	78 W	78 W
PSB	3 W	3 W
PCK	o w	o w
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.94 kW	3.90 kW
Annual energy consumption Qhe	10600 kWh	14861 kWh
Pdh Tj = -15°C (if TOL<-20°C)	16.80	15.90
COP Tj = -15°C (if TOL $<$ -20°C)	4.60	2.84
Cdh Tj = -15 °C	0.90	0.90





EN 12102-1	
	Low temperature
Sound power level indoor	65 dB(A)



Model: WPF 16 basic, average climates

Configure model		
Model name	WPF 16 basic, average climates	
Application	Heating (medium temp)	
Units	Indoor	
Climate Zone	n/a	
Reversibility	No	
Cooling mode application (optional)	n/a	

General Data		
Power supply	1x230V 50Hz	

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	65 dB(A)	65 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{S}	117 %	117 %
Prated	17.00 kW	16.00 kW
SCOP	4.80	3.18
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	16.70 kW	15.70 kW
COP Tj = -7°C	4.22	2.59
	·	



This information was genera	ated by the HP KEYMAI	RK database on 18 Mar 2022
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	16.80 kW	16.10 kW
COP Tj = +2°C	4.54	3.06
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = $+7^{\circ}$ C	16.90 kW	16.30 kW
$COPTj = +7^{\circ}C$	4.87	3.43
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	17.00 kW	16.50 kW
COP Tj = 12°C	5.26	3.88
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	16.60 kW	15.60 kW
COP Tj = Tbiv	4.16	2.48
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	16.60 kW	15.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.16	2.48
WTOL	60 °C	60 °C
Poff	0 W	0 W
РТО	78 W	78 W
PSB	3 W	3 W
РСК	o w	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW



Annual energy consumption Qhe	7440 kWh	10353 kWh
-------------------------------	----------	-----------

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	16.64 kW	15.62 kW
El input	4.00 kW	6.34 kW
СОР	4.35	2.46

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	failed
Starting and operating test	passed