This information was generated by the HP KEYMARK database on 7 Jul 2022

Login

Summary of	VIESSMANN Vitocal 060-A (250 L) Typ T0S 060-A	Reg. No.	011-1W0112
Certificate Holder			
Name	Viessmann Faulquemont SAS		
Address	Avenue André Gouy	Zip	F-57380
City	Faulquemont	Country	France
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	VIESSMANN Vitocal 060-A (250 L) Typ T0S 060-A		
Heat Pump Type	Heat Pump for Domestic Hot Water (DHW)		
Refrigerant	R134a		
Mass of Refrigerant	1.25 kg		

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

This information was generated by the HP KEYMARK database on 7 Jul 2022

Model: VIESSMANN Vitocal 060-A (250 L) Typ T0S 060-A

Configure model	
Model name	VIESSMANN Vitocal 060-A (250 L) Typ T0S 060-A
Units	Indoor
Climate zone (for heating)	n/a
Heat Source	n/a
Any additional heat sources	n/a

General Data	
Power supply	1x230V 50Hz
Off-peak product	Yes

Domestic Hot Water (DHW)

Average Climate

EN 12102-2	
Sound power level indoor	56 dB(A)
Sound power level outdoor	56 dB(A)

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

This information was generated by the HP KEYMARK database on 7 Jul 2022

EN 16147	
Declared load profile	L
Efficiency ηDHW	135 %
COP	3.04
Heating up time	9h05min h:min
Standby power input	24.0 W
Reference hot water temperature	53.3 °C
Mixed water at 40°C	337 l

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.