

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	LW 121	Reg. No.	041-K001-37
Certificate Holder			
Name	ait-deutschland GmbH		
Address	Industriestr. 3	Zip	95359
City	Kasendorf	Country	Germany
Certification Body	BRE Energy & Communications Division		
Name of testing laboratory	HLK Stuttgart		
Subtype title	LW 121		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R407c		
Mass Of Refrigerant	5.8 kg		
Certification Date	08.10.2019		

Model: LW 121

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

EN 14511-2

	Low temperature	Medium temperature
Heat output	12.80 kW	12.60 kW
El input	3.00 kW	4.50 kW
COP	4.20	2.80
Indoor water flow rate	2.50 m ³ /h	2.50 m ³ /h

Average Climate

EN 14825

	Low temperature	Medium temperature
η_s	153 %	122 %

This information was generated by the HP KEYMARK database on 17 Dec 2020

Prated	13.70 kW	12.51 kW
SCOP	3.90	3.13
Tbiv	-4 °C	-4 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.22 kW	8.70 kW
COP Tj = -7°C	3.05	2.08
Cdh	1.00	1.00
Pdh Tj = +2°C	11.90 kW	11.52 kW
COP Tj = +2°C	3.94	3.11
Cdh	1.00	1.00
Pdh Tj = +7°C	12.99 kW	12.56 kW
COP Tj = +7°C	4.86	4.14
Cdh	1.00	1.00
Pdh Tj = 12°C	15.09 kW	15.03 kW
COP Tj = 12°C	5.32	5.18
Cdh	1.00	1.00
Pdh Tj = Tbiv	10.13 kW	9.62 kW
COP Tj = Tbiv	3.40	2.39
Pdh Tj = TOL	8.36 kW	7.86 kW
COP Tj = TOL	2.78	1.85
WTOL	65 °C	65 °C

This information was generated by the HP KEYMARK database on 17 Dec 2020

Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	5.34 kW	4.65 kW
Annual energy consumption Q _{he}	7258 kWh	8264 kWh

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	58 dB(A)	58 dB(A)

Warmer Climate

EN 14825		
	Low temperature	Medium temperature
η_s	185 %	145 %
Prated	14.24 kW	13.15 kW
SCOP	4.70	3.71
T _{biv}	4 °C	4 °C
TOL	2 °C	2 °C
P _{dh} T _j = +2°C	11.78 kW	11.04 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

COP Tj = +2°C	3.66	2.42
Cdh	1.00	1.00
Pdh Tj = +7°C	12.83 kW	11.82 kW
COP Tj = +7°C	4.59	3.22
Cdh	1.00	1.00
Pdh Tj = 12°C	15.01 kW	14.75 kW
COP Tj = 12°C	5.21	4.69
Cdh	1.00	1.00
Pdh Tj = Tbiv	12.21 kW	11.27 kW
COP Tj = Tbiv	4.06	2.68
Pdh Tj = TOL	11.78 kW	11.04 kW
COP Tj = TOL	3.66	2.42
WTOL	65 °C	65 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	2.46 kW	2.11 kW
Annual energy consumption Qhe	4044 kWh	4736 kWh

Colder Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 14825

	Low temperature	Medium temperature
η_s	137 %	112 %
Prated	10.70 kW	10.21 kW
SCOP	3.50	2.87
Tbiv	-12 °C	-12 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.31 kW	8.93 kW
COP Tj = -7°C	3.28	2.43
Cdh	1.00	1.00
Pdh Tj = +2°C	11.96 kW	11.71 kW
COP Tj = +2°C	4.10	3.47
Cdh	1.00	1.00
Pdh Tj = +7°C	13.07 kW	12.86 kW
COP Tj = +7°C	4.99	4.59
Cdh	1.00	1.00
Pdh Tj = 12°C	15.06 kW	15.17 kW
COP Tj = 12°C	5.16	5.38
Cdh	1.00	1.00
Pdh Tj = Tbiv	7.88 kW	7.52 kW
COP Tj = Tbiv	2.86	2.02

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	5.60 kW	5.88 kW
COP Tj = TOL	2.06	1.56
WTOL	65 °C	65 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	10.70 kW	10.21 kW
Annual energy consumption Qhe	7537 kWh	8774 kWh
Pdh Tj = -15°C (if TOL<-20°C)	7.02	6.69
COP Tj = -15°C (if TOL<-20°C)	2.56	1.78
Cdh	1.00	1.00

Model: LW 121A

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

EN 14511-2

	Low temperature	Medium temperature
Heat output	12.80 kW	12.60 kW
El input	3.00 kW	4.50 kW
COP	4.20	2.80
Indoor water flow rate	2.50 m ³ /h	2.50 m ³ /h

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	50 dB(A)	50 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	153 %	122 %
Prated	13.70 kW	12.51 kW
SCOP	3.90	3.13
Tbiv	-4 °C	-4 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.22 kW	8.70 kW
COP Tj = -7°C	3.05	2.08
Cdh	1.00	1.00
Pdh Tj = +2°C	11.90 kW	11.52 kW
COP Tj = +2°C	3.94	3.11
Cdh	1.00	1.00
Pdh Tj = +7°C	12.99 kW	12.56 kW
COP Tj = +7°C	4.86	4.14
Cdh	1.00	1.00

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	15.09 kW	15.03 kW
COP Tj = 12°C	5.32	5.18
Cdh	1.00	1.00
Pdh Tj = Tbiv	10.13 kW	9.62 kW
COP Tj = Tbiv	3.40	2.39
Pdh Tj = TOL	8.36 kW	7.86 kW
COP Tj = TOL	2.78	1.85
WTOL	65 °C	65 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	5.34 kW	4.65 kW
Annual energy consumption Qhe	7258 kWh	8264 kWh

Warmer Climate

EN 14825		
	Low temperature	Medium temperature
η_s	185 %	145 %
Prated	14.24 kW	13.15 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

SCOP	4.70	3.71
Tbiv	4 °C	4 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	11.78 kW	11.04 kW
COP Tj = +2°C	3.66	2.42
Cdh	1.00	1.00
Pdh Tj = +7°C	12.83 kW	11.82 kW
COP Tj = +7°C	4.59	3.22
Cdh	1.00	1.00
Pdh Tj = 12°C	15.01 kW	14.75 kW
COP Tj = 12°C	5.21	4.69
Cdh	1.00	1.00
Pdh Tj = Tbiv	12.21 kW	11.27 kW
COP Tj = Tbiv	4.06	2.68
Pdh Tj = TOL	11.78 kW	11.04 kW
COP Tj = TOL	3.66	2.42
WTOL	65 °C	65 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W

This information was generated by the HP KEYMARK database on 17 Dec 2020

Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	2.46 kW	2.11 kW
Annual energy consumption Q _{he}	4044 kWh	4736 kWh

Colder Climate

EN 14825		
	Low temperature	Medium temperature
η_s	137 %	112 %
Prated	10.70 kW	10.21 kW
SCOP	3.50	2.87
T _{biv}	-12 °C	-12 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	9.31 kW	8.93 kW
COP T _j = -7°C	3.28	2.43
C _{dh}	1.00	1.00
P _{dh} T _j = +2°C	11.96 kW	11.71 kW
COP T _j = +2°C	4.10	3.47
C _{dh}	1.00	1.00
P _{dh} T _j = +7°C	13.07 kW	12.86 kW
COP T _j = +7°C	4.99	4.59
C _{dh}	1.00	1.00

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	15.06 kW	15.17 kW
COP Tj = 12°C	5.16	5.38
Cdh	1.00	1.00
Pdh Tj = Tbiv	7.88 kW	7.52 kW
COP Tj = Tbiv	2.86	2.02
Pdh Tj = TOL	5.60 kW	5.88 kW
COP Tj = TOL	2.06	1.56
WTOL	65 °C	65 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	10.70 kW	10.21 kW
Annual energy consumption Qhe	7537 kWh	8774 kWh
Pdh Tj = -15°C (if TOL<-20°C)	7.02	6.69
COP Tj = -15°C (if TOL<-20°C)	2.56	1.78
Cdh	1.00	1.00