

Page 1 of 4 This information was generated by the HP KEYMARK database on 17 Dec 2020

| Summary of | Buderus Logatherm WPS 54.2 HT | Reg. No. | 011-1W0164 |
|----------------------------|---|----------|------------|
| Certificate Holder | | | |
| Name | Bosch Thermotechnik GmbH (Buderus) | | |
| Address | Sophienstraße 30-32 | Zip | 35576 |
| City | Wetzlar | Country | Germany |
| Certification Body | DIN CERTCO Gesellschaft für Konformitätsbewertung mbH | | |
| Name of testing laboratory | RISE Research Institutes of Sweden AB | | |
| Subtype title | Buderus Logatherm WPS 54.2 HT | | |
| Heat Pump Type | Brine/Water | | |
| Refrigerant | R410a | | |
| Mass Of Refrigerant | 9.5 kg | | |



This information was generated by the HP KEYMARK database on 17 Dec 2020

Model: Buderus Logatherm WPS 54.2 HT

| General Data | | |
|--------------|-------------|--|
| Power supply | 3x400V 50Hz | |

Heating

| EN 14511-2 | | |
|------------------------|-----------------|--------------------|
| | Low temperature | Medium temperature |
| Heat output | 54.94 kW | 57.33 kW |
| El input | 12.10 kW | 18.38 kW |
| СОР | 4.54 | 3.12 |
| Indoor water flow rate | 9.46 m³/h | 6.17 m³/h |

| EN 14511-4 | |
|--|--------|
| Operating range outdoor exchanger/indoor exchanger lower limit/lower limit | passed |
| Operating range outdoor exchanger/indoor exchanger upper limit/upper limit | passed |
| Shutting off the heat transfer medium flow | passed |
| Complete power supply failure | passed |

Average Climate



 $$\operatorname{\textit{Page}}\xspace$ 3 of 4 This information was generated by the HP KEYMARK database on 17 Dec 2020

| EN 12102-1 | | |
|--------------------------|-----------------|--------------------|
| | Low temperature | Medium temperature |
| Sound power level indoor | 67 dB(A) | 67 dB(A) |

| EN 14825 | | |
|---------------|-----------------|--------------------|
| | Low temperature | Medium temperature |
| η_{s} | 204 % | 162 % |
| Prated | 53.00 kW | 54.00 kW |
| SCOP | 5.30 | 4.24 |
| Tbiv | -10 °C | -10 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 46.88 kW | 47.77 kW |
| COP Tj = -7°C | 4.62 | 3.46 |
| Pdh Tj = +2°C | 28.80 kW | 29.06 kW |
| COP Tj = +2°C | 5.42 | 4.31 |
| Pdh Tj = +7°C | 28.76 kW | 28.90 kW |
| COP Tj = +7°C | 5.55 | 4.60 |
| Pdh Tj = 12°C | 28.72 kW | 28.75 kW |
| COP Tj = 12°C | 5.63 | 4.84 |
| Pdh Tj = Tbiv | 54.94 kW | 57.33 kW |
| COP Tj = Tbiv | 4.54 | 3.12 |

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



 $$\operatorname{\textit{Page}}4 of 4$ This information was generated by the HP KEYMARK database on 17 Dec 2020$

| Pdh Tj = TOL | 54.94 kW | 57.33 kW |
|--|-----------|-----------|
| COP Tj = TOL | 4.54 | 3.12 |
| Cdh | 1.00 | 1.00 |
| WTOL | 68 °C | 68 °C |
| Poff | 25 W | 25 W |
| PTO | 25 W | 25 W |
| PSB | 25 W | 25 W |
| PCK | 0 W | 0 W |
| Supplementary Heater: Type of energy input | Electric | Electric |
| Supplementary Heater: PSUP | 0.00 kW | 0.00 kW |
| Annual energy consumption Qhe | 20646 kWh | 26308 kWh |