

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	Loria 6006	Reg. No.	012-014
Certificate Holder			
Name	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000
City	La Roche Sur Yon	Country	France
Certification Body	RISE CERT		
Subtype title	Loria 6006		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	1.1 kg		
Certification Date	27.07.2016		

Model: Loria 6006

Configure model	
Model name	Loria 6006
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz
Phase-out Date	12.03.2024

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	3.71 kW	5.71 kW
El input	0.71 kW	2.22 kW
COP	5.09	2.54

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	186 %	128 %
Prated	6.00 kW	5.00 kW
SCOP	4.72	3.27
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.20 kW	4.10 kW
COP Tj = -7°C	2.90	1.90
Pdh Tj = +2°C	3.50 kW	2.70 kW
COP Tj = +2°C	4.60	3.20
Pdh Tj = +7°C	1.90 kW	1.80 kW
COP Tj = +7°C	6.10	4.40
Pdh Tj = 12°C	2.40 kW	2.10 kW
COP Tj = 12°C	9.30	6.50

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = Tbiv	5.20 kW	4.10 kW
COP Tj = Tbiv	2.90	9.90
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.80 kW	3.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	1.80
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	9 W	9 W
PTO	14 W	14 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.10 kW	0.70 kW
Annual energy consumption Qhe	2588 kWh	2933 kWh

Model: Loria Duo 6006

Configure model

Model name	Loria Duo 6006
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data

Power supply	1x230V 50Hz
Phase-out Date	12.03.2024

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	3.71 kW	5.71 kW
El input	0.71 kW	2.22 kW
COP	5.09	2.54

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	186 %	128 %
Prated	6.00 kW	5.00 kW
SCOP	4.72	3.27
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.20 kW	4.10 kW
COP Tj = -7°C	2.90	1.90
Pdh Tj = +2°C	3.50 kW	2.70 kW
COP Tj = +2°C	4.60	3.20
Pdh Tj = +7°C	1.90 kW	1.80 kW
COP Tj = +7°C	6.10	4.40
Pdh Tj = 12°C	2.40 kW	2.10 kW
COP Tj = 12°C	9.30	6.50

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = Tbiv	5.20 kW	4.10 kW
COP Tj = Tbiv	2.90	9.90
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.80 kW	3.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	1.80
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	9 W	9 W
PTO	14 W	14 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.10 kW	0.70 kW
Annual energy consumption Qhe	2588 kWh	2933 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	130 %
COP	3.26
Heating up time	1:36 h:min
Reference hot water temperature	52.5 °C
Mixed water at 40°C	243 l
Standby power input	31.0 W

Model: Loria Duo 2C 6006

Configure model	
Model name	Loria Duo 2C 6006
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz
Phase-out Date	12.03.2024

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	3.71 kW	5.71 kW
El input	0.71 kW	2.22 kW
COP	5.09	2.54

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	186 %	128 %
Prated	6.00 kW	5.00 kW
SCOP	4.72	3.27
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.20 kW	4.10 kW
COP Tj = -7°C	2.90	1.90
Pdh Tj = +2°C	3.50 kW	2.70 kW
COP Tj = +2°C	4.60	3.20
Pdh Tj = +7°C	1.90 kW	1.80 kW
COP Tj = +7°C	6.10	4.40
Pdh Tj = 12°C	2.40 kW	2.10 kW
COP Tj = 12°C	9.30	6.50

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = Tbiv	5.20 kW	4.10 kW
COP Tj = Tbiv	2.90	9.90
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.80 kW	3.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	1.80
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	9 W	9 W
PTO	14 W	14 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.10 kW	0.70 kW
Annual energy consumption Qhe	2588 kWh	2933 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	130 %
COP	3.26
Heating up time	1:36 h:min
Reference hot water temperature	52.5 °C
Mixed water at 40°C	243 l
Standby power input	31.0 W

Model: Loria 6006 (LFC)

Configure model

Model name	Loria 6006 (LFC)
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data

Power supply	1x230V 50Hz
Phase-out Date	14.03.2024

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	3.71 kW	5.71 kW
El input	0.71 kW	2.22 kW
COP	5.09	2.54

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	186 %	128 %
Prated	6.00 kW	5.00 kW
SCOP	4.72	3.27
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.20 kW	4.10 kW
COP Tj = -7°C	2.90	1.90
Pdh Tj = +2°C	3.50 kW	2.70 kW
COP Tj = +2°C	4.60	3.20
Pdh Tj = +7°C	1.90 kW	1.80 kW
COP Tj = +7°C	6.10	4.40
Pdh Tj = 12°C	2.40 kW	2.10 kW
COP Tj = 12°C	9.30	6.50

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = Tbiv	5.20 kW	4.10 kW
COP Tj = Tbiv	2.90	9.90
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.80 kW	3.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	1.80
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	9 W	9 W
PTO	14 W	14 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.10 kW	0.70 kW
Annual energy consumption Qhe	2588 kWh	2933 kWh