

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	i-SHWAK V4 16	Reg. No.	ICIM-PDC-000080-00
Certificate Holder			
Name	Advantix S.p.A.		
Address	Via San Giuseppe Lavoratore, 24	Zip	37040
City	Arcole Verona	Country	Italy
Certification Body	ICIM S.p.A.		
Name of testing laboratory	ReLab - Politecnico di Milano		
Subtype title	i-SHWAK V4 16		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410a		
Mass Of Refrigerant	4.6 kg		
Certification Date	26.05.2020		
Testing basis	HP KEYMARK certification scheme rules rev. no. 7		

Model: i-SHWAK V4 16

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	15.21 kW	14.80 kW
El input	3.52 kW	5.35 kW
COP	4.32	2.76
Indoor water flow rate	2.62 m ³ /h	1.59 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	157 %	123 %
Prated	10.00 kW	9.00 kW
SCOP	4.00	3.14
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.80 kW	9.10 kW
COP Tj = -7°C	2.55	1.65
Cdh	1.00	1.00
Pdh Tj = +2°C	6.00 kW	6.40 kW
COP Tj = +2°C	4.02	3.08
Cdh	1.00	1.00
Pdh Tj = +7°C	6.90 kW	7.60 kW
COP Tj = +7°C	5.11	4.43
Cdh	1.00	1.00

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	7.80 kW	7.90 kW
COP Tj = 12°C	5.42	6.50
Cdh	1.00	1.00
Pdh Tj = Tbiv	9.80 kW	9.10 kW
COP Tj = Tbiv	2.55	1.65
Pdh Tj = TOL	8.70 kW	7.40 kW
COP Tj = TOL	2.22	1.30
WTOL	39 °C	39 °C
Poff	0 W	0 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	0	0
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	3888 kWh	4576 kWh

Cooling

EN 14825

This information was generated by the HP KEYMARK database on 17 Dec 2020

	+7°C/+12°C
P _{designc}	14.65 kW
SEER	5.06
P _{dc} T _j = 35°C	14.65 kW
EER T _j = 35°C	3.24
P _{dc} T _j = 30°C	10.79 kW
EER T _j = 30°C	4.71
C _{dc}	1.0
P _{dc} T _j = 25°C	6.93 kW
EER T _j = 25°C	5.81
C _{dc}	1.0
P _{dc} T _j = 20°C	7.03 kW
EER T _j = 20°C	6.28
C _{dc}	1.0
P _{off}	12 W
PTO	0 W
PSB	12 W
PCK	0 W
Annual energy consumption Q _{ce}	1013 kWh

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 14511-2	
	+7°C/+12°C
El input	4.52 kW
Indoor water flow rate	2.52 m³/h
Cooling capacity	14.65
EER	3.24

Model: i-SHWAK V4 16T

General Data

Power supply	3x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	15.21 kW	14.80 kW
El input	3.52 kW	5.35 kW
COP	4.32	2.76
Indoor water flow rate	2.62 m ³ /h	1.59 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	157 %	123 %
Prated	10.00 kW	9.00 kW
SCOP	4.00	3.14
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.80 kW	9.10 kW
COP Tj = -7°C	2.55	1.65
Cdh	1.00	1.00
Pdh Tj = +2°C	6.00 kW	6.40 kW
COP Tj = +2°C	4.02	3.08
Cdh	1.00	1.00
Pdh Tj = +7°C	6.90 kW	7.60 kW
COP Tj = +7°C	5.11	4.43
Cdh	1.00	1.00

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	7.80 kW	7.90 kW
COP Tj = 12°C	5.42	6.50
Cdh	1.00	1.00
Pdh Tj = Tbiv	9.80 kW	9.10 kW
COP Tj = Tbiv	2.55	1.65
Pdh Tj = TOL	8.70 kW	7.40 kW
COP Tj = TOL	2.22	1.30
WTOL	39 °C	39 °C
Poff	0 W	0 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	0	0
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	3888 kWh	4576 kWh

Cooling

EN 14825

This information was generated by the HP KEYMARK database on 17 Dec 2020

	+7°C/+12°C
P _{designc}	14.65 kW
SEER	5.06
P _{dc} T _j = 35°C	14.65 kW
EER T _j = 35°C	3.24
P _{dc} T _j = 30°C	10.79 kW
EER T _j = 30°C	4.71
C _{dc}	1.0
P _{dc} T _j = 25°C	6.93 kW
EER T _j = 25°C	5.81
C _{dc}	1.0
P _{dc} T _j = 20°C	7.03 kW
EER T _j = 20°C	6.28
C _{dc}	1.0
P _{off}	12 W
PTO	0 W
PSB	12 W
PCK	0 W
Annual energy consumption Q _{ce}	1013 kWh

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 14511-2	
	+7°C/+12°C
El input	4.52 kW
Indoor water flow rate	2.52 m³/h
Cooling capacity	14.65
EER	3.24