

Page 1 of 8

This information was generated by the HP KEYMARK database on 23 Jun 2022

<u>Login</u>

Summary of	ecoAIR 1-7 PRO	Reg. No.	011-1W0427	
Certificate Holder				
Name	Ecoforest Geotermia S.L.	Ecoforest Geotermia S.L.		
Address	Rúa das Pontes, 25	Zip	36350	
City	Nigrán (Pontevedra)	Country	Spain	
Certification Body	DIN CERTCO Gesellschaft für	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	ecoAIR 1-7 PRO	ecoAIR 1-7 PRO		
Heat Pump Type	Outdoor Air/Water	Outdoor Air/Water		
Refrigerant	R290	R290		
Mass of Refrigerant	0.75 kg	0.75 kg		
Certification Date	17.11.2020	17.11.2020		
Testing basis	HP KEYMARK certification scheme rules rev. 7			

Model: ECOAIR 1-7 PRO

Configure model			
Model name	ECOAIR 1-7 PRO		
Application	Heating (medium temp)		
Units	Outdoor		
Climate Zone	Colder Climate + Warmer Climate		
Reversibility	Yes		
Cooling mode application (optional)	n/a		

General Data		
Power supply	1x230V 50Hz	

Heating

EN 14511-2				
Low temperature Medium temperature				
Heat output	3.30 kW	2.80 kW		
El input	0.64 kW	0.85 kW		
СОР	5.20	3.30		

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	

Warmer Climate



EN 12102-1		
Low temperature Medium temperature		
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{s}	202 %	159 %
Prated	4.00 kW	3.60 kW
SCOP	5.11	4.04
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	4.02 kW	3.63 kW
COP Tj = +2°C	3.00	2.11
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	2.54 kW	2.41 kW
COP Tj = +7°C	6.15	3.79
Cdh Tj = +7 °C	0.98	0.99
Pdh Tj = 12°C	1.23 kW	1.51 kW
COP Tj = 12°C	5.26	5.26
Cdh Tj = +12 °C	0.96	0.97
Pdh Tj = Tbiv	4.02 kW	3.63 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





COP Tj = Tbiv	3.00	2.11
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.02 kW	3.63 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.00	2.11
WTOL	75 °C	75 °C
Poff	0 W	0 W
РТО	10 W	10 W
PSB	8 W	8 W
PCK	10 W	10 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1045 kWh	1191 kWh

Colder Climate


EN 12102-1			
Low temperature Medium temperature			
Sound power level outdoor	58 dB(A)	58 dB(A)	

EN 14825		
	Low temperature	Medium temperature
η_{s}	146 %	120 %
Prated	4.50 kW	4.30 kW





This information was gener	The Thirt RETHING	
SCOP	3.72	3.07
Tbiv	-12 °C	-12 °C
TOL	-15 °C	-15 °C
Pdh Tj = -7°C	2.73 kW	2.64 kW
$COP Tj = -7^{\circ}C$	3.69	2.79
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = $+2$ °C	1.64 kW	1.57 kW
COP Tj = +2°C	4.95	3.87
Cdh Tj = +2 °C	0.970	0.980
Pdh Tj = $+7^{\circ}$ C	1.10 kW	1.27 kW
$COPTj = +7^{\circ}C$	4.73	4.64
Cdh Tj = +7 °C	0.960	0.960
Pdh Tj = 12°C	1.25 kW	1.20 kW
COP Tj = 12°C	5.47	5.02
Cdh Tj = +12 °C	0.960	0.960
Pdh Tj = Tbiv	3.29 kW	3.07 kW
COP Tj = Tbiv	3.17	2.47
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.32 kW	3.09 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.09	2.40
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	75 °C	75 °C





This information was generated by the HP KEYMARK database on 23 Jun 2022 Poff 0 W 0 W PTO 10 W 10 W **PSB** 8 W 8 W **PCK** 10 W 10 W Supplementary Heater: Type of energy input Electricity Electricity Supplementary Heater: PSUP 4.50 kW 4.30 kW 2983 kWh 3458 kWh Annual energy consumption Qhe Pdh Tj = -15°C (if TOL<-20°C) 3.32 3.09 COP Tj = -15°C (if TOL<-20°C) 3.09 2.40 Cdh Tj = -15 $^{\circ}$ C 1.000 0.990

Average Climate

EN 12102-1			
Low temperature Medium temperature			
Sound power level outdoor	58 dB(A)	58 dB(A)	

	EN 14825			
Low temperature	Medium temperature			
175 %	135 %			
4.10 kW	4.00 kW			
4.45	3.45			
-	175 % 4.10 kW			





 $$\operatorname{\textit{Page}}\ 7$$ of 8 This information was generated by the HP KEYMARK database on 23 Jun 2022

		in the did tabase on 25 juin 202
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.69 kW	3.47 kW
$COP Tj = -7^{\circ}C$	2.96	2.21
Cdh Tj = -7 °C	0.99	0.99
Pdh Tj = +2°C	2.26 kW	2.18 kW
COPTj = +2°C	4.63	3.46
Cdh Tj = +2 °C	0.98	0.99
Pdh Tj = $+7$ °C	1.50 kW	1.37 kW
$COP Tj = +7^{\circ}C$	5.61	4.46
Cdh Tj = +7 °C	0.97	0.97
Pdh Tj = 12°C	1.34 kW	1.45 kW
COP Tj = 12°C	5.79	5.57
Cdh Tj = +12 °C	0.96	0.96
Pdh Tj = Tbiv	3.69 kW	3.47 kW
COP Tj = Tbiv	2.96	2.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.63 kW	3.34 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.83	2.07
WTOL	75 °C	75 °C
Poff	o w	0 W
РТО	10 W	10 W



PSB	8 W	8 W
PCK	10 W	10 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.47 kW	0.66 kW
Annual energy consumption Qhe	1902 kWh	2396 kWh