

Page 1 of 10

This information was generated by the HP KEYMARK database on 21 Jun 2022

Login

Summary of	TTF 10 basic	Reg. No.	011-1W0046
Certificate Holder			
Name	tecalor GmbH		
Address	Fürstenbergerstr. 77	Zip	37603
City	Holzminden	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für	Konformitätsbewertur	ng mbH
Subtype title	TTF 10 basic		
Heat Pump Type	Brine/Water		
Refrigerant	R410A		
Mass of Refrigerant	2.6 kg		
Certification Date	28.10.2016		

Model: TTF 10 basic, all climates

Configure model	
Model name	TTF 10 basic, all climates
Application	Heating (low temp)
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

	General Data	
Power supply	3x400V 50Hz	

Heating

EN 14511-2	
	Low temperature
Heat output	9.70 kW
El input	2.22 kW
СОР	4.37

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Average Climate



EN 12102-1	
	Low temperature
Sound power level indoor	51 dB(A)

EN 14825	
	Low temperature
η_{s}	190 %
Prated	10.00 kW
SCOP	4.94
Tbiv	-10 °C
TOL	-20 °C
Pdh Tj = -7°C	9.70 kW
COP Tj = -7°C	4.44
Cdh Tj = -7 °C	0.90
Pdh Tj = +2°C	9.80 kW
$COP Tj = +2^{\circ}C$	4.85
Cdh Tj = +2 °C	0.90
Pdh Tj = +7°C	10.00 kW
$COP Tj = +7^{\circ}C$	5.28
Cdh Tj = +7 °C	0.90
Pdh Tj = 12°C	10.10 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





COP Tj = 12°C 5.78	
Cdh Tj = +12 °C 0.90	
Pdh Tj = Tbiv	1
COP Tj = Tbiv	
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh 4.37	
WTOL 60 °C	
Poff 0 W	
PTO 78 W	
PSB 3 W	
PCK 0 W	
Supplementary Heater: Type of energy input Electrici	ty
Supplementary Heater: PSUP 0.00 kW	1
Annual energy consumption Qhe 4053 kV	Vh

Warmer Climate

EN 14825	
Low temperature	
190 %	
10.00 kW	
4.95	





This information was generated by the Hr Keri	TARK dutabase on 21 jun 2022
Tbiv	2 °C
TOL	0 °C
Pdh Tj = +2°C	9.70 kW
COPTj = +2°C	4.37
Cdh Tj = +2 °C	0.90
Pdh Tj = +7°C	9.80 kW
$COPTj = +7^{\circ}C$	4.76
Cdh Tj = +7 °C	0.90
Pdh Tj = 12°C	10.00 kW
COP Tj = 12°C	5.44
Cdh Tj = +12 °C	0.90
Pdh Tj = Tbiv	9.70 kW
COP Tj = Tbiv	4.37
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.37
WTOL	60 °C
Poff	0 W
РТО	78 W
PSB	3 W
PCK	0 W
Supplementary Heater: Type of energy input	Electricity





Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	2617 kWh

Colder Climate

EN 14825	
	Low temperature
∫s	199 %
Prated	12.00 kW
SCOP	5.17
Гbіv	-15 °C
ГОL	-22 °C
Pdh Tj = -7°C	9.90 kW
COP Tj = -7°C	5.07
Cdh Tj = -7 °C	0.90
dh Tj = +2°C	10.00 kW
COP Tj = +2°C	5.41
Cdh Tj = +2 °C	0.90
Pdh Tj = +7°C	10.10 kW
COP Tj = +7°C	5.70
Cdh Tj = +7 °C	0.90
Pdh Tj = 12°C	10.10 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





COP Tj = 12°C	5.75
Cdh Tj = +12 °C	0.90
Pdh Tj = Tbiv	9.90 kW
COP Tj = Tbiv	4.93
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.93
WTOL	60 °C
Poff	o w
РТО	78 W
PSB	3 W
PCK	o w
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	2.40 kW
Annual energy consumption Qhe	5768 kWh
Pdh Tj = -15°C (if TOL<-20°C)	9.90
COP Tj = -15 °C (if TOL< -20 °C)	4.93
Cdh Tj = -15 °C	0.90

Model: TTF 10 basic, average climates

Configure model			
Model name	TTF 10 basic, average climates		
Application	Heating (medium temp)		
Units	Indoor		
Climate Zone	n/a		
Reversibility	No		
Cooling mode application (optional)	n/a		

General Data		
Power supply	3x400V 50Hz	

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	9.70 kW	8.57 kW
El input	2.22 kW	3.67 kW
СОР	4.37	2.34

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Shutting on the heat transfer medium now	passeu	
Complete power supply failure	passed	
Starting and operating test	passed	

Average Climate



EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	51 dB(A)	51 dB(A)

	EN 14825	
	Low temperature	Medium temperature
η_{s}	190 %	114 %
Prated	10.00 kW	9.00 kW
SCOP	4.94	3.06
Tbiv	-10 °C	-10 °C
TOL	-20 °C	-10 °C
Pdh Tj = -7°C	9.70 kW	8.70 kW
COP Tj = -7°C	4.44	2.46
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	9.80 kW	9.10 kW
COP Tj = +2°C	4.85	2.99
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	10.00 kW	9.30 kW
COP Tj = +7°C	5.28	3.42
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	10.10 kW	9.50 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 10 of 10

This information was generated by the HP KEYMARK database on 21 Jun 2022

COP Tj = 12°C	5.78	3.95
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	9.70 kW	8.60 kW
COP Tj = Tbiv	4.37	2.34
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.70 kW	8.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.37	2.34
WTOL	60 °C	60 °C
Poff	o w	0 W
РТО	78 W	78 W
PSB	3 W	3 W
PCK	o w	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	4053 kWh	5788 kWh