

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	F1x45-15	Reg. No.	012-045
Certificate Holder			
Name	Nibe AB		
Address	Box 14	Zip	S-28521
City	Markaryd	Country	Sweden
Certification Body	RISE CERT		
Subtype title	F1x45-15		
Heat Pump Type	Brine/Water		
Refrigerant	R407c		
Mass of Refrigerant	2 kg		

Model: F1145-15

Configure model	
Model name	F1145-15
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	10.42 kW	14.83 kW
El input	3.63 kW	5.05 kW
COP	4.25	2.94

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	175 %	138 %
Prated	18.00 kW	18.00 kW
SCOP	4.57	3.65
Tbiv	-6 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	15.40 kW	6.00 kW
COP Tj = -7°C	4.52	3.16
Pdh Tj = +2°C	15.60 kW	14.80 kW
COP Tj = +2°C	4.70	3.72
Pdh Tj = +7°C	15.70 kW	15.10 kW
COP Tj = +7°C	4.82	4.01
Pdh Tj = 12°C	15.80 kW	15.40 kW
COP Tj = 12°C	4.73	4.27
Pdh Tj = Tbiv	15.50 kW	14.60 kW
COP Tj = Tbiv	4.55	3.27

This information was generated by the HP KEYMARK database on 18 Mar 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	15.40 kW	14.60 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	4.41	2.96
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.98	0.99
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	60 W	60 W
PSB	7 W	7 W
PCK	35 W	35 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.60 kW	3.40 kW
Annual energy consumption Q_{he}	8134 kWh	10194 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	180 %	141 %
Prated	18.00 kW	18.00 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

SCOP	4.70	3.72
Tbiv	-17 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	15.60 kW	14.70 kW
COP Tj = -7°C	4.73	3.60
Pdh Tj = +2°C	15.70 kW	15.00 kW
COP Tj = +2°C	4.85	3.95
Pdh Tj = +7°C	15.80 kW	15.30 kW
COP Tj = +7°C	4.84	4.21
Pdh Tj = 12°C	15.80 kW	15.50 kW
COP Tj = 12°C	4.49	4.35
Pdh Tj = Tbiv	15.50 kW	14.60 kW
COP Tj = Tbiv	4.58	3.29
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	15.40 kW	14.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.41	2.96
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.98	0.99
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	60 W	60 W
PSB	7 W	7 W
PCK	35 W	35 W

This information was generated by the HP KEYMARK database on 18 Mar 2022

Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.60 kW	3.40 kW
Annual energy consumption Q _{he}	9454 kWh	11893 kWh