

$$\operatorname{\textit{Page}}\ 1$$ of 7 This information was generated by the HP KEYMARK database on 23 Jun 2022

<u>Login</u>

Summary of	Intelligent Inverter Heat Pump 60	Reg. No.	041-K020-03
Certificate Holder		<u> </u>	
Name	Guangdong PHNIX Eco-Energy Solutions L	.td.	
Address	No. 3 Tianyuan Road Dagang Town	Zip	511470
City	Guangdong	Country	China
Certification Body	BRE Global Limited		
Subtype title	Intelligent Inverter Heat Pump 60		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	2 kg		
Certification Date	01.11.2021		
Testing basis	Heat Pump Keymark Scheme Rules Rev 0	9	

This information was generated by the HP KEYMARK database on 23 Jun 2022

Model: PASRW060-BP-PS-B

Configure model		
Model name	PASRW060-BP-PS-B	
Application	Heating (medium temp)	
Units	Outdoor	
Climate Zone	n/a	
Reversibility	Yes	
Cooling mode application (optional)	n/a	

General Data		
Power supply 1x230V 50Hz		

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	17.02 kW	15.18 kW
El input	3.57 kW	5.23 kW
СОР	4.77	2.90

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate



 $$\operatorname{\textit{Page}}\xspace$ 3 of 7 This information was generated by the HP KEYMARK database on 23 Jun 2022

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{s}	188 %	135 %
Prated	12.54 kW	14.61 kW
SCOP	4.78	3.45
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.09 kW	12.92 kW
COP Tj = -7°C	3.28	2.12
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	6.88 kW	7.94 kW
COP Tj = +2°C	4.49	3.35
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	8.30 kW	7.47 kW
COP Tj = +7°C	6.18	4.55
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	9.26 kW	7.94 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 4 of 7 This information was generated by the HP KEYMARK database on 23 Jun 2022

COP Tj = 12°C	8.26	6.73
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	11.09 kW	12.92 kW
COP Tj = Tbiv	3.28	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.54 kW	10.71 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.01	1.68
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	57 °C	57 °C
Poff	20 W	20 W
РТО	20 W	20 W
PSB	20 W	20 W
РСК	60 W	60 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	3.90 kW
Annual energy consumption Qhe	5419 kWh	8738 kWh



This information was generated by the HP KEYMARK database on 23 Jun 2022

Model: PASRW060S-BP-PS-B

Configure model		
Model name	PASRW060S-BP-PS-B	
Application	Heating (medium temp)	
Units	Outdoor	
Climate Zone	n/a	
Reversibility	Yes	
Cooling mode application (optional)	n/a	

General Data		
Power supply	3x400V 50Hz	

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	16.60 kW	15.14 kW
El input	3.32 kW	4.88 kW
СОР	5.00	3.10

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate



This information was generated by the HP KEYMARK database on 23 Jun 2022

EN 12102-1				
	Low temperature	Medium temperature		
Sound power level outdoor	61 dB(A)	61 dB(A)		

EN 14825			
	Low temperature	Medium temperature	
η_{s}	185 %	135 %	
Prated	12.89 kW	14.47 kW	
SCOP	4.71	3.46	
Tbiv	-7 °C	-7 °C	
TOL	-10 °C	-10 °C	
Pdh Tj = -7°C	11.40 kW	12.80 kW	
COP Tj = -7°C	3.36	2.27	
Cdh Tj = -7 °C	0.900	0.900	
Pdh Tj = +2°C	6.89 kW	7.97 kW	
COP Tj = +2°C	4.41	3.19	
Cdh Tj = +2 °C	0.900	0.900	
Pdh Tj = +7°C	8.27 kW	7.14 kW	
COP Tj = +7°C	6.14	4.64	
Cdh Tj = +7 °C	0.990	0.990	
Pdh Tj = 12°C	9.10 kW	6.27 kW	

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



$$\operatorname{\textit{Page}}\ 7$$ of 7 This information was generated by the HP KEYMARK database on 23 Jun 2022

COP Tj = 12°C	8.04	6.69
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	11.40 kW	12.80 kW
COP Tj = Tbiv	3.36	2.27
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.80 kW	14.47 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.05	1.98
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	56 °C	56 °C
Poff	23 W	23 W
РТО	23 W	23 W
PSB	23 W	23 W
PCK	58 W	58 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.09 kW	0.00 kW
Annual energy consumption Qhe	5654 kWh	8639 kWh