Login

Summary of	WPF 04, WPF 04 cool, WPC 04, WPC 04 cool	Reg. No.	011-1W0019
Certificate Holder			
Name	STIEBEL ELTRON GmbH & Co KG		
Address	Dr. Stiebel Straße 33	Zip	37603
City	Holzminden	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	WPF 04, WPF 04 cool, WPC 04, WPC 04 cool		
Heat Pump Type	Brine/Water		
Refrigerant	R410A		
Mass of Refrigerant	1.05 kg		
Certification Date	23.08.2016		

Model: WPF 04, all climates

Configure model	
Model name	WPF 04, all climates
Application	Heating (low temp)
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2	
	Low temperature
Heat output	4.77 kW
El input	1.06 kW
COP	4.50

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1	
	Low temperature
Sound power level indoor	45 dB(A)

EN 14825	
	Low temperature
η_s	189 %
Prated	5.00 kW
SCOP	4.92
Tbiv	-10 °C
TOL	-10 °C
Pdh Tj = -7°C	4.80 kW
COP Tj = -7°C	4.55
Cdh Tj = -7 °C	0.90
Pdh Tj = +2°C	4.80 kW
COP Tj = +2°C	4.87
Cdh Tj = +2 °C	0.90
Pdh Tj = +7°C	4.90 kW
COP Tj = +7°C	5.18
Cdh Tj = +7 °C	0.90
Pdh Tj = 12°C	4.90 kW

COP Tj = 12°C	5.52
Cdh Tj = +12 °C	0.90
Pdh Tj = Tbiv	4.80 kW
COP Tj = Tbiv	4.50
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.50
WTOL	65 °C
Poff	0 W
PTO	54 W
PSB	9 W
PCK	0 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	2002 kWh

Warmer Climate

EN 14825	
	Low temperature
η_s	187 %
Prated	5.00 kW
SCOP	4.87

Tbiv	2 °C
TOL	0 °C
Pdh Tj = +2°C	4.80 kW
COP Tj = +2°C	4.50
Cdh Tj = +2 °C	0.90
Pdh Tj = +7°C	4.80 kW
COP Tj = +7°C	4.80
Cdh Tj = +7 °C	0.90
Pdh Tj = 12°C	4.90 kW
COP Tj = 12°C	5.29
Cdh Tj = +12 °C	0.90
Pdh Tj = Tbiv	4.80 kW
COP Tj = Tbiv	4.50
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.50
WTOL	65 °C
Poff	0 W
PTO	54 W
PSB	9 W
PCK	0 W
Supplementary Heater: Type of energy input	Electricity

Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	1310 kWh

EN 12102-1	
	Low temperature
Sound power level indoor	45 dB(A)

Colder Climate

EN 14825	
	Low temperature
η_s	195 %
Prated	6.00 kW
SCOP	5.07
Tbiv	-15 °C
TOL	-22 °C
Pdh Tj = -7°C	4.90 kW
COP Tj = -7°C	5.03
Cdh Tj = -7 °C	0.90
Pdh Tj = +2°C	4.90 kW
COP Tj = +2°C	5.27
Cdh Tj = +2 °C	0.90

Pdh Tj = +7°C	4.90 kW
COP Tj = +7°C	5.47
Cdh Tj = +7 °C	0.90
Pdh Tj = 12°C	4.90 kW
COP Tj = 12°C	5.50
Cdh Tj = +12 °C	0.90
Pdh Tj = Tbiv	4.80 kW
COP Tj = Tbiv	4.92
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.92
WTOL	65 °C
Poff	0 W
PTO	54 W
PSB	9 W
PCK	0 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	1.17 kW
Annual energy consumption Qhe	2888 kWh
Pdh Tj = -15°C (if TOL<-20°C)	4.80
COP Tj = -15°C (if TOL<-20°C)	4.92
Cdh Tj = -15 °C	0.90

EN 12102-1	
	Low temperature
Sound power level indoor	45 dB(A)

Model: WPF 04, average climates

Configure model	
Model name	WPF 04, average climates
Application	Heating (medium temp)
Units	Indoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	4.77 kW	4.25 kW
El input	1.06 kW	1.56 kW
COP	4.50	2.72

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	45 dB(A)	45 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	189 %	128 %
Prated	5.00 kW	4.00 kW
SCOP	4.92	3.40
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.80 kW	4.30 kW
COP Tj = -7°C	4.55	2.85
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	4.80 kW	4.50 kW
COP Tj = +2°C	4.87	3.35
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.90 kW	4.60 kW
COP Tj = +7°C	5.18	3.73
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	4.90 kW	4.70 kW

COP Tj = 12°C	5.52	4.18
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	4.80 kW	4.30 kW
COP Tj = Tbiv	4.50	2.72
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.80 kW	4.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.50	2.72
WTOL	65 °C	65 °C
Poff	0 W	0 W
PTO	54 W	54 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2002 kWh	2583 kWh

Model: WPF 04 cool, all climates

Configure model	
Model name	WPF 04 cool, all climates
Application	Heating (low temp)
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2	
	Low temperature
Heat output	4.77 kW
El input	1.06 kW
COP	4.50

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1	
	Low temperature
Sound power level indoor	45 dB(A)

EN 14825	
	Low temperature
η_s	189 %
Prated	5.00 kW
SCOP	4.92
Tbiv	-10 °C
TOL	-10 °C
Pdh Tj = -7°C	4.80 kW
COP Tj = -7°C	4.55
Cdh Tj = -7 °C	0.90
Pdh Tj = +2°C	4.80 kW
COP Tj = +2°C	4.87
Cdh Tj = +2 °C	0.90
Pdh Tj = +7°C	4.90 kW
COP Tj = +7°C	5.18
Cdh Tj = +7 °C	0.90
Pdh Tj = 12°C	4.90 kW

COP Tj = 12°C	5.52
Cdh Tj = +12 °C	0.90
Pdh Tj = Tbiv	4.80 kW
COP Tj = Tbiv	4.50
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.50
WTOL	65 °C
Poff	0 W
PTO	54 W
PSB	9 W
PCK	0 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	2002 kWh

Warmer Climate

EN 14825	
	Low temperature
η_s	187 %
Prated	5.00 kW
SCOP	4.87

Tbiv	2 °C
TOL	0 °C
Pdh Tj = +2°C	4.80 kW
COP Tj = +2°C	4.50
Cdh Tj = +2 °C	0.90
Pdh Tj = +7°C	4.80 kW
COP Tj = +7°C	4.80
Cdh Tj = +7 °C	0.90
Pdh Tj = 12°C	4.90 kW
COP Tj = 12°C	5.29
Cdh Tj = +12 °C	0.90
Pdh Tj = Tbiv	4.80 kW
COP Tj = Tbiv	4.50
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.50
WTOL	65 °C
Poff	0 W
PTO	54 W
PSB	9 W
PCK	0 W
Supplementary Heater: Type of energy input	Electricity

Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	1310 kWh

EN 12102-1	
	Low temperature
Sound power level indoor	45 dB(A)

Colder Climate

EN 14825	
	Low temperature
η_s	195 %
Prated	6.00 kW
SCOP	5.07
Tbiv	-15 °C
TOL	-22 °C
Pdh Tj = -7°C	4.90 kW
COP Tj = -7°C	5.03
Cdh Tj = -7 °C	0.90
Pdh Tj = +2°C	4.90 kW
COP Tj = +2°C	5.27
Cdh Tj = +2 °C	0.90

Pdh Tj = +7°C	4.90 kW
COP Tj = +7°C	5.47
Cdh Tj = +7 °C	0.90
Pdh Tj = 12°C	4.90 kW
COP Tj = 12°C	5.50
Cdh Tj = +12 °C	0.90
Pdh Tj = Tbiv	4.80 kW
COP Tj = Tbiv	4.92
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.92
WTOL	65 °C
Poff	0 W
PTO	54 W
PSB	9 W
PCK	0 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	1.17 kW
Annual energy consumption Qhe	2888 kWh
Pdh Tj = -15°C (if TOL<-20°C)	4.80
COP Tj = -15°C (if TOL<-20°C)	4.92
Cdh Tj = -15 °C	0.90

EN 12102-1	
	Low temperature
Sound power level indoor	45 dB(A)

Model: WPF 04 cool, average climates

Configure model	
Model name	WPF 04 cool, average climates
Application	Heating (medium temp)
Units	Indoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	4.77 kW	4.25 kW
El input	1.06 kW	1.56 kW
COP	4.50	2.72

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	45 dB(A)	45 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	189 %	128 %
Prated	5.00 kW	4.00 kW
SCOP	4.92	3.40
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.80 kW	4.30 kW
COP Tj = -7°C	4.55	2.85
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	4.80 kW	4.50 kW
COP Tj = +2°C	4.87	3.35
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.90 kW	4.60 kW
COP Tj = +7°C	5.18	3.73
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	4.90 kW	4.70 kW

COP Tj = 12°C	5.52	4.18
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	4.80 kW	4.30 kW
COP Tj = Tbiv	4.50	2.72
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.80 kW	4.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.50	2.72
WTOL	65 °C	65 °C
Poff	0 W	0 W
PTO	54 W	54 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2002 kWh	2583 kWh

Model: WPC 04, all climates

Configure model	
Model name	WPC 04, all climates
Application	Heating (low temp)
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2	
	Low temperature
Heat output	4.77 kW
El input	1.06 kW
COP	4.50

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1	
	Low temperature
Sound power level indoor	45 dB(A)

EN 14825	
	Low temperature
η_s	189 %
Prated	5.00 kW
SCOP	4.92
Tbiv	-10 °C
TOL	-10 °C
Pdh Tj = -7°C	4.80 kW
COP Tj = -7°C	4.55
Cdh Tj = -7 °C	0.90
Pdh Tj = +2°C	4.80 kW
COP Tj = +2°C	4.87
Cdh Tj = +2 °C	0.90
Pdh Tj = +7°C	4.90 kW
COP Tj = +7°C	5.18
Cdh Tj = +7 °C	0.90
Pdh Tj = 12°C	4.90 kW

COP Tj = 12°C	5.52
Cdh Tj = +12 °C	0.90
Pdh Tj = Tbiv	4.80 kW
COP Tj = Tbiv	4.50
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.50
WTOL	65 °C
Poff	0 W
PTO	54 W
PSB	9 W
PCK	0 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	2002 kWh

Warmer Climate

EN 14825	
	Low temperature
η_s	187 %
Prated	5.00 kW
SCOP	4.87

Tbiv	2 °C
TOL	0 °C
Pdh Tj = +2°C	4.80 kW
COP Tj = +2°C	4.50
Cdh Tj = +2 °C	0.90
Pdh Tj = +7°C	4.80 kW
COP Tj = +7°C	4.80
Cdh Tj = +7 °C	0.90
Pdh Tj = 12°C	4.90 kW
COP Tj = 12°C	5.29
Cdh Tj = +12 °C	0.90
Pdh Tj = Tbiv	4.80 kW
COP Tj = Tbiv	4.50
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.50
WTOL	65 °C
Poff	0 W
PTO	54 W
PSB	9 W
PCK	0 W
Supplementary Heater: Type of energy input	Electricity

Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	1310 kWh

EN 12102-1	
	Low temperature
Sound power level indoor	45 dB(A)

Colder Climate

EN 14825	
	Low temperature
η_s	195 %
Prated	6.00 kW
SCOP	5.07
Tbiv	-15 °C
TOL	-22 °C
Pdh Tj = -7°C	4.90 kW
COP Tj = -7°C	5.03
Cdh Tj = -7 °C	0.90
Pdh Tj = +2°C	4.90 kW
COP Tj = +2°C	5.27
Cdh Tj = +2 °C	0.90

Pdh Tj = +7°C	4.90 kW
COP Tj = +7°C	5.47
Cdh Tj = +7 °C	0.90
Pdh Tj = 12°C	4.90 kW
COP Tj = 12°C	5.50
Cdh Tj = +12 °C	0.90
Pdh Tj = Tbiv	4.80 kW
COP Tj = Tbiv	4.92
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.92
WTOL	65 °C
Poff	0 W
PTO	54 W
PSB	9 W
PCK	0 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	1.17 kW
Annual energy consumption Qhe	2888 kWh
Pdh Tj = -15°C (if TOL<-20°C)	4.80
COP Tj = -15°C (if TOL<-20°C)	4.92
Cdh Tj = -15 °C	0.90

EN 12102-1	
	Low temperature
Sound power level indoor	45 dB(A)

Model: WPC 04, average climates

Configure model	
Model name	WPC 04, average climates
Application	Heating (medium temp)
Units	Indoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	4.77 kW	4.25 kW
El input	1.06 kW	1.56 kW
COP	4.50	2.72

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	45 dB(A)	45 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	189 %	128 %
Prated	5.00 kW	4.00 kW
SCOP	4.92	3.40
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.80 kW	4.30 kW
COP Tj = -7°C	4.55	2.85
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	4.80 kW	4.50 kW
COP Tj = +2°C	4.87	3.35
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.90 kW	4.60 kW
COP Tj = +7°C	5.18	3.73
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	4.90 kW	4.70 kW

COP Tj = 12°C	5.52	4.18
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	4.80 kW	4.30 kW
COP Tj = Tbiv	4.50	2.72
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.80 kW	4.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.50	2.72
WTOL	65 °C	65 °C
Poff	0 W	0 W
PTO	54 W	54 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2002 kWh	2583 kWh

Model: WPC 04 cool, all climates

Configure model	
Model name	WPC 04 cool, all climates
Application	Heating (low temp)
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2	
	Low temperature
Heat output	4.77 kW
El input	1.06 kW
COP	4.50

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1	
	Low temperature
Sound power level indoor	45 dB(A)

EN 14825	
	Low temperature
η_s	189 %
Prated	5.00 kW
SCOP	4.92
Tbiv	-10 °C
TOL	-10 °C
Pdh Tj = -7°C	4.80 kW
COP Tj = -7°C	4.55
Cdh Tj = -7 °C	0.90
Pdh Tj = +2°C	4.80 kW
COP Tj = +2°C	4.87
Cdh Tj = +2 °C	0.90
Pdh Tj = +7°C	4.90 kW
COP Tj = +7°C	5.18
Cdh Tj = +7 °C	0.90
Pdh Tj = 12°C	4.90 kW

COP Tj = 12°C	5.52
Cdh Tj = +12 °C	0.90
Pdh Tj = Tbiv	4.80 kW
COP Tj = Tbiv	4.50
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.50
WTOL	65 °C
Poff	0 W
PTO	54 W
PSB	9 W
PCK	0 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	2002 kWh

Warmer Climate

EN 14825	
	Low temperature
η_s	187 %
Prated	5.00 kW
SCOP	4.87

Tbiv	2 °C
TOL	0 °C
Pdh Tj = +2°C	4.80 kW
COP Tj = +2°C	4.50
Cdh Tj = +2 °C	0.90
Pdh Tj = +7°C	4.80 kW
COP Tj = +7°C	4.80
Cdh Tj = +7 °C	0.90
Pdh Tj = 12°C	4.90 kW
COP Tj = 12°C	5.29
Cdh Tj = +12 °C	0.90
Pdh Tj = Tbiv	4.80 kW
COP Tj = Tbiv	4.50
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.50
WTOL	65 °C
Poff	0 W
PTO	54 W
PSB	9 W
PCK	0 W
Supplementary Heater: Type of energy input	Electricity

Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	1310 kWh

EN 12102-1	
	Low temperature
Sound power level indoor	45 dB(A)

Colder Climate

EN 14825	
	Low temperature
η_s	195 %
Prated	6.00 kW
SCOP	5.07
Tbiv	-15 °C
TOL	-22 °C
Pdh Tj = -7°C	4.90 kW
COP Tj = -7°C	5.03
Cdh Tj = -7 °C	0.90
Pdh Tj = +2°C	4.90 kW
COP Tj = +2°C	5.27
Cdh Tj = +2 °C	0.90

Pdh Tj = +7°C	4.90 kW
COP Tj = +7°C	5.47
Cdh Tj = +7 °C	0.90
Pdh Tj = 12°C	4.90 kW
COP Tj = 12°C	5.50
Cdh Tj = +12 °C	0.90
Pdh Tj = Tbiv	4.80 kW
COP Tj = Tbiv	4.92
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.92
WTOL	65 °C
Poff	0 W
PTO	54 W
PSB	9 W
PCK	0 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	1.17 kW
Annual energy consumption Qhe	2888 kWh
Pdh Tj = -15°C (if TOL<-20°C)	4.80
COP Tj = -15°C (if TOL<-20°C)	4.92
Cdh Tj = -15 °C	0.90

EN 12102-1	
	Low temperature
Sound power level indoor	45 dB(A)

Model: WPC 04 cool, average climates

Configure model	
Model name	WPC 04 cool, average climates
Application	Heating (medium temp)
Units	Indoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	4.77 kW	4.25 kW
El input	1.06 kW	1.56 kW
COP	4.50	2.72

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	45 dB(A)	45 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	189 %	128 %
Prated	5.00 kW	4.00 kW
SCOP	4.92	3.40
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.80 kW	4.30 kW
COP Tj = -7°C	4.55	2.85
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	4.80 kW	4.50 kW
COP Tj = +2°C	4.87	3.35
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.90 kW	4.60 kW
COP Tj = +7°C	5.18	3.73
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	4.90 kW	4.70 kW

COP Tj = 12°C	5.52	4.18
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	4.80 kW	4.30 kW
COP Tj = Tbiv	4.50	2.72
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.80 kW	4.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.50	2.72
WTOL	65 °C	65 °C
Poff	0 W	0 W
PTO	54 W	54 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2002 kWh	2583 kWh