

Page 1 of 7

This information was generated by the HP KEYMARK database on 21 Jun 2022

Login

| Summary of | LWC 100 | Reg. No. | 041-K001-29 | |
|---------------------|---------------------|----------------------|-------------|--|
| Certificate Holder | <u>'</u> | <u> </u> | <u> </u> | |
| Name | ait-deutschland Gmb | ait-deutschland GmbH | | |
| Address | Industriestr. 3 | Zip | 95359 | |
| City | Kasendorf | Country | Germany | |
| Certification Body | BRE Global Limited | BRE Global Limited | | |
| Subtype title | LWC 100 | LWC 100 | | |
| Heat Pump Type | Outdoor Air/Water | | | |
| Refrigerant | R404A | R404A | | |
| Mass of Refrigerant | 4.1 kg | 4.1 kg | | |
| Certification Date | 06.09.2019 | 06.09.2019 | | |



Model: LWC 100

| Configure model | | |
|-------------------------------------|---------------------------------|--|
| Model name LWC 100 | | |
| Application | Heating (medium temp) | |
| Units | Indoor | |
| Climate Zone | Colder Climate + Warmer Climate | |
| Reversibility | No | |
| Cooling mode application (optional) | n/a | |

| General Data | | |
|--------------|-------------|--|
| Power supply | 3x400V 50Hz | |

Heating

| EN 14511-2 | | |
|------------------------------------|----------|--------------------|
| Low temperature Medium temperature | | Medium temperature |
| Heat output | 12.20 kW | 11.20 kW |
| El input | 2.98 kW | 5.01 kW |
| СОР | 4.10 | 2.20 |

| EN 14511-4 | | |
|--|--------|--|
| Shutting off the heat transfer medium flow | passed | |
| Shutting on the heat transfer medium now | passeu | |
| Complete power supply failure | passed | |
| Starting and operating test | passed | |

Average Climate



 $$\operatorname{\textit{Page}}\xspace$ 3 of 7 This information was generated by the HP KEYMARK database on 21 Jun 2022

| EN 12102-1 | | |
|--------------------------|-----------------|--------------------|
| | Low temperature | Medium temperature |
| Sound power level indoor | 55 dB(A) | 55 dB(A) |

| EN 14825 | | |
|----------------|-----------------|--------------------|
| | Low temperature | Medium temperature |
| η_{s} | 146 % | 116 % |
| Prated | 11.89 kW | 11.19 kW |
| SCOP | 3.73 | 2.97 |
| Tbiv | -4 °C | -4 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 8.43 kW | 7.83 kW |
| COP Tj = -7°C | 2.86 | 2.01 |
| Cdh Tj = -7 °C | 1.00 | 1.00 |
| Pdh Tj = +2°C | 10.51 kW | 10.17 kW |
| COP Tj = +2°C | 3.77 | 2.93 |
| Cdh Tj = +2 °C | 1.00 | 1.00 |
| Pdh Tj = +7°C | 12.41 kW | 12.15 kW |
| COP Tj = +7°C | 4.63 | 3.93 |
| Cdh Tj = +7 °C | 1.00 | 1.00 |
| Pdh Tj = 12°C | 14.06 kW | 14.00 kW |

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





| This information was gener | ated by the HP KEYMA | RK database on 21 Jun 202 |
|---|----------------------|---------------------------|
| COP Tj = 12°C | 5.03 | 4.88 |
| Cdh Tj = +12 °C | 1.00 | 1.00 |
| Pdh Tj = Tbiv | 9.14 kW | 8.61 kW |
| COP Tj = Tbiv | 3.19 | 2.27 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL $<$ Tdesignh | 7.69 kW | 7.17 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.59 | 1.79 |
| WTOL | 58 °C | 58 °C |
| Poff | 10 W | 10 W |
| РТО | 10 W | 10 W |
| PSB | 10 W | 10 W |
| РСК | o w | 0 W |
| Supplementary Heater: Type of energy input | Electricity | Electricity |
| Supplementary Heater: PSUP | 4.20 kW | 4.02 kW |
| | | |

Warmer Climate

Annual energy consumption Qhe

| EN 14825 | | |
|------------|-----------------|--------------------|
| | Low temperature | Medium temperature |
| η_{S} | 175 % | 137 % |
| Prated | 13.05 kW | 12.23 kW |
| SCOP | 4.45 | 3.51 |
| | , | |

6587 kWh

7791 kWh



Page 5 of 7 This information was generated by the HP KEYMARK database on 21 Jun 2022

| This information was genera | | |
|---|-------------|-------------|
| Tbiv | 4 °C | 4 °C |
| TOL | 2 °C | 2 °C |
| Pdh Tj = $+2$ °C | 10.40 kW | 9.73 kW |
| COP Tj = +2°C | 3.47 | 2.25 |
| Cdh Tj = +2 °C | 1.00 | 1.00 |
| Pdh Tj = $+7^{\circ}$ C | 12.31 kW | 11.69 kW |
| $COPTj = +7^{\circ}C$ | 4.35 | 3.07 |
| Cdh Tj = +7 °C | 1.00 | 1.00 |
| Pdh Tj = 12°C | 13.99 kW | 13.76 kW |
| COP Tj = 12°C | 4.92 | 4.43 |
| Cdh Tj = +12 °C | 1.00 | 1.00 |
| Pdh Tj = Tbiv | 11.18 kW | 10.49 kW |
| COP Tj = Tbiv | 3.87 | 2.53 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 10.40 kW | 9.73 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 3.47 | 2.25 |
| WTOL | 58 °C | 58 °C |
| Poff | 10 W | 10 W |
| РТО | 10 W | 10 W |
| PSB | 10 W | 10 W |
| PCK | 0 W | 0 W |
| Supplementary Heater: Type of energy input | Electricity | Electricity |
| | | |

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





This information was generated by the HP KEYMARK database on 21 Jun 2022

| Supplementary Heater: PSUP | 2.65 kW | 2.50 kW |
|-------------------------------|----------|----------|
| Annual energy consumption Qhe | 3920 kWh | 4652 kWh |

Colder Climate

| EN 14825 | | |
|------------------------|-----------------|--------------------|
| | Low temperature | Medium temperature |
| η_{s} | 131 % | 107 % |
| Prated | 9.21 kW | 8.82 kW |
| SCOP | 3.34 | 2.74 |
| Tbiv | -13 °C | -13 °C |
| TOL | -20 °C | -20 °C |
| Pdh Tj = -7°C | 8.53 kW | 8.10 kW |
| COP Tj = -7°C | 3.04 | 2.32 |
| Cdh Tj = -7 °C | 1.00 | 1.00 |
| Pdh Tj = +2°C | 10.57 kW | 10.33 kW |
| COP Tj = +2°C | 3.94 | 3.28 |
| Cdh Tj = +2 °C | 1.00 | 1.00 |
| Pdh Tj = +7°C | 12.47 kW | 12.34 kW |
| $COP Tj = +7^{\circ}C$ | 4.75 | 4.36 |
| Cdh Tj = +7 °C | 1.00 | 1.00 |
| Pdh Tj = 12°C | 14.04 kW | 14.12 kW |



Page 7 of 7 This information was generated by the HP KEYMARK database on 21 Jun 2022

| | | - |
|--|-------------|-------------|
| COP Tj = 12°C | 4.86 | 5.04 |
| Cdh Tj = +12 °C | 1.00 | 1.00 |
| Pdh Tj = Tbiv | 7.03 kW | 6.73 kW |
| COP Tj = Tbiv | 2.54 | 1.87 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 5.31 kW | 5.30 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 1.89 | 1.42 |
| WTOL | 58 °C | 58 °C |
| Poff | 10 W | 10 W |
| PTO | 10 W | 10 W |
| PSB | 10 W | 10 W |
| PCK | 0 W | 0 W |
| Supplementary Heater: Type of energy input | Electricity | Electricity |
| Supplementary Heater: PSUP | 9.21 kW | 8.82 kW |
| Annual energy consumption Qhe | 6791 kWh | 7942 kWh |
| Pdh Tj = -15°C (if TOL<-20°C) | 6.53 | 6.30 |
| COP Tj = -15°C (if TOL $<$ -20°C) | 2.35 | 1.73 |
| Cdh Tj = -15 °C | 1.00 | 1.00 |
| I control of the cont | 1 | |