

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	CTC GSi 16	Reg. No.	012-SC0819-18
Certificate Holder			
Name	Enertech CTC AB		
Address	Box 309, Näsvägen	Zip	SE-381 26
City	Ljungby	Country	Sweden
Certification Body	RISE CERT		
Subtype title	CTC GSi 16		
Heat Pump Type	Brine/Water		
Refrigerant	R407c		
Mass of Refrigerant	2.2 kg		
Certification Date	28.11.2018		

Model: CTC GSi 16 3x400V

Configure model	
Model name	CTC GSi 16 3x400V
Application	Heating + DHW + low temp
Units	Indoor
Climate Zone	Colder Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz
Off-peak product	No
Phase-out Date	25.10.2023

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.55 kW	9.85 kW
El input	2.62 kW	3.63 kW
COP	4.40	2.72

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 14825		
	Low temperature	Medium temperature
η_s	201 %	154 %
Prated	16.00 kW	16.00 kW
SCOP	5.23	4.04
Tbiv	-9 °C	-8 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	14.04 kW	14.19 kW
COP Tj = -7°C	4.17	2.79
Pdh Tj = +2°C	8.49 kW	8.83 kW
COP Tj = +2°C	5.36	4.13
Pdh Tj = +7°C	5.61 kW	5.50 kW
COP Tj = +7°C	5.87	4.89
Pdh Tj = 12°C	4.55 kW	4.39 kW
COP Tj = 12°C	6.03	5.14
Pdh Tj = Tbiv	15.27 kW	14.58 kW
COP Tj = Tbiv	3.88	2.70
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	15.60 kW	14.34 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.77	2.57
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.99	0.99
WTOL	65 °C	65 °C

This information was generated by the HP KEYMARK database on 18 Mar 2022

Poff	20 W	20 W
PTO	20 W	20 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.40 kW	1.66 kW
Annual energy consumption Qhe	6321 kWh	8176 kWh

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)

Colder Climate

EN 14825		
	Low temperature	Medium temperature
η_s	210 %	161 %
Prated	16.00 kW	16.00 kW
SCOP	5.45	4.22
Tbiv	-21 °C	-18 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	9.89 kW	9.98 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = -7°C	5.22	3.79
Pdh Tj = +2°C	5.88 kW	5.92 kW
COP Tj = +2°C	5.93	4.78
Pdh Tj = +7°C	4.45 kW	4.46 kW
COP Tj = +7°C	6.07	5.31
Pdh Tj = 12°C	4.39 kW	4.46 kW
COP Tj = 12°C	5.76	5.31
Pdh Tj = Tbiv	15.51 kW	14.27 kW
COP Tj = Tbiv	3.77	2.76
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	15.60 kW	14.34 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.77	2.57
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.99	0.99
WTOL	65 °C	65 °C
Poff	20 W	20 W
PTO	20 W	20 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.40 kW	1.66 kW
Annual energy consumption Qhe	7239 kWh	9352 kWh

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	99 %
COP	2.38
Heating up time	01:04 h:min
Reference hot water temperature	50.0 °C
Mixed water at 40°C	234 l
Standby power input	57.0 W

Colder Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	99 %
COP	2.38
Heating up time	01:04 h:min
Reference hot water temperature	50.0 °C
Mixed water at 40°C	234 l
Standby power input	57.0 W

Model: CTC EcoPart 616M 3x400V

Configure model	
Model name	CTC EcoPart 616M 3x400V
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz
Phase-out Date	25.10.2023

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.55 kW	9.85 kW
El input	2.62 kW	3.63 kW
COP	4.40	2.72

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 14825		
	Low temperature	Medium temperature
η_s	201 %	154 %
Prated	16.00 kW	16.00 kW
SCOP	5.23	4.04
Tbiv	-9 °C	-8 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	14.04 kW	14.19 kW
COP Tj = -7°C	4.17	2.79
Pdh Tj = +2°C	8.49 kW	8.83 kW
COP Tj = +2°C	5.36	4.13
Pdh Tj = +7°C	5.61 kW	5.50 kW
COP Tj = +7°C	5.87	4.89
Pdh Tj = 12°C	4.55 kW	4.39 kW
COP Tj = 12°C	6.03	5.14
Pdh Tj = Tbiv	15.27 kW	14.58 kW
COP Tj = Tbiv	3.88	2.70
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	15.60 kW	14.34 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.77	2.57
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.99	0.99
WTOL	65 °C	65 °C

This information was generated by the HP KEYMARK database on 18 Mar 2022

Poff	20 W	20 W
PTO	20 W	20 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.40 kW	1.66 kW
Annual energy consumption Qhe	6321 kWh	8176 kWh

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)

Colder Climate

EN 14825		
	Low temperature	Medium temperature
η_s	210 %	161 %
Prated	16.00 kW	16.00 kW
SCOP	5.45	4.22
Tbiv	-21 °C	-18 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	9.89 kW	9.98 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = -7°C	5.22	3.79
Pdh Tj = +2°C	5.88 kW	5.92 kW
COP Tj = +2°C	5.93	4.78
Pdh Tj = +7°C	4.45 kW	4.46 kW
COP Tj = +7°C	6.07	5.31
Pdh Tj = 12°C	4.39 kW	4.46 kW
COP Tj = 12°C	5.76	5.31
Pdh Tj = Tbiv	15.51 kW	14.27 kW
COP Tj = Tbiv	3.77	2.76
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	15.60 kW	14.34 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.77	2.57
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.99	0.99
WTOL	65 °C	65 °C
Poff	20 W	20 W
PTO	20 W	20 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.40 kW	1.66 kW
Annual energy consumption Qhe	7239 kWh	9352 kWh

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)