

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	Alféa Excellia Tri 14	Reg. No.	012-004
Certificate Holder			
Name	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000
City	La Roche Sur Yon	Country	France
Certification Body	RISE CERT		
Subtype title	Alféa Excellia Tri 14		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	2.5 kg		
Certification Date	15.07.2016		
Testing basis	EN 14511:2013; EN 16147:2011; EN 14825:2013; EN 12102:2013		

Model: Alféa Excellia Tri 14

Configure model	
Model name	Alféa Excellia Tri 14
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	13.00 kW	10.60 kW
El input	3.11 kW	4.40 kW
COP	4.18	2.41

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	69 dB(A)	69 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	150 %	117 %
Prated	13.00 kW	11.00 kW
SCOP	3.82	3.00
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	10.00 kW
COP Tj = -7°C	2.50	2.00
Pdh Tj = +2°C	6.70 kW	6.10 kW
COP Tj = +2°C	3.70	2.90
Pdh Tj = +7°C	6.20 kW	5.90 kW
COP Tj = +7°C	5.40	4.10
Pdh Tj = 12°C	7.30 kW	7.10 kW
COP Tj = 12°C	7.00	5.40
Pdh Tj = Tbiv	11.10 kW	10.00 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP $T_j = T_{biv}$	2.50	2.00
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	10.80 kW	9.30 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.40	1.60
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	14 W	14 W
PTO	66 W	43 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.70 kW	2.00 kW
Annual energy consumption Q _{he}	6738 kWh	7803 kWh

Model: Alféa Excellia A.I. Tri 14

Configure model	
Model name	Alféa Excellia A.I. Tri 14
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	13.00 kW	10.60 kW
El input	3.11 kW	4.40 kW
COP	4.18	2.41

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	69 dB(A)	69 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	150 %	117 %
Prated	13.00 kW	11.00 kW
SCOP	3.82	3.00
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	10.00 kW
COP Tj = -7°C	2.50	2.00
Pdh Tj = +2°C	6.70 kW	6.10 kW
COP Tj = +2°C	3.70	2.90
Pdh Tj = +7°C	6.20 kW	5.90 kW
COP Tj = +7°C	5.40	4.10
Pdh Tj = 12°C	7.30 kW	7.10 kW
COP Tj = 12°C	7.00	5.40
Pdh Tj = Tbiv	11.10 kW	10.00 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP $T_j = T_{biv}$	2.50	2.00
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	10.80 kW	9.30 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.40	1.60
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	14 W	14 W
PTO	66 W	43 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.70 kW	2.00 kW
Annual energy consumption Q_{he}	6738 kWh	7803 kWh

Model: Alféa Excellia Duo Tri 14

Configure model	
Model name	Alféa Excellia Duo Tri 14
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	13.00 kW	10.60 kW
El input	3.11 kW	4.40 kW
COP	4.18	2.41

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	69 dB(A)	69 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	150 %	117 %
Prated	13.00 kW	11.00 kW
SCOP	3.82	3.00
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	10.00 kW
COP Tj = -7°C	2.50	2.00
Pdh Tj = +2°C	6.70 kW	6.10 kW
COP Tj = +2°C	3.70	2.90
Pdh Tj = +7°C	6.20 kW	5.90 kW
COP Tj = +7°C	5.40	4.10
Pdh Tj = 12°C	7.30 kW	7.10 kW
COP Tj = 12°C	7.00	5.40
Pdh Tj = Tbiv	11.10 kW	10.00 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP $T_j = T_{biv}$	2.50	2.00
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	10.80 kW	9.30 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.40	1.60
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	14 W	14 W
PTO	66 W	43 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.70 kW	2.00 kW
Annual energy consumption Q_{he}	6738 kWh	7803 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	88 %
COP	2.30
Heating up time	0:46 h:min
Standby power input	40.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	250 l

Model: Alféa Excellia Duo A.I. Tri 14

Configure model	
Model name	Alféa Excellia Duo A.I. Tri 14
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	13.00 kW	10.60 kW
El input	3.11 kW	4.40 kW
COP	4.18	2.41

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	150 %	117 %
Prated	13.00 kW	11.00 kW
SCOP	3.82	3.00
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	10.00 kW
COP Tj = -7°C	2.50	2.00
Pdh Tj = +2°C	6.70 kW	6.10 kW
COP Tj = +2°C	3.70	2.90
Pdh Tj = +7°C	6.20 kW	5.90 kW
COP Tj = +7°C	5.40	4.10
Pdh Tj = 12°C	7.30 kW	7.10 kW
COP Tj = 12°C	7.00	5.40
Pdh Tj = Tbiv	11.10 kW	10.00 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP $T_j = T_{biv}$	2.50	2.00
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	10.80 kW	9.30 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.40	1.60
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	14 W	14 W
PTO	66 W	43 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.70 kW	2.00 kW
Annual energy consumption Q_{he}	6738 kWh	7803 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	88 %
COP	2.30
Heating up time	0:46 h:min
Standby power input	40.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	250 l

Model: Hydrapac 14B25

Configure model	
Model name	Hydrapac 14B25
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	13.00 kW	10.60 kW
El input	3.11 kW	4.40 kW
COP	4.18	2.41

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	69 dB(A)	69 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	150 %	117 %
Prated	13.00 kW	11.00 kW
SCOP	3.82	3.00
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	10.00 kW
COP Tj = -7°C	2.50	2.00
Pdh Tj = +2°C	6.70 kW	6.10 kW
COP Tj = +2°C	3.70	2.90
Pdh Tj = +7°C	6.20 kW	5.90 kW
COP Tj = +7°C	5.40	4.10
Pdh Tj = 12°C	7.30 kW	7.10 kW
COP Tj = 12°C	7.00	5.40
Pdh Tj = Tbiv	11.10 kW	10.00 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP $T_j = T_{biv}$	2.50	2.00
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	10.80 kW	9.30 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.40	1.60
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	14 W	14 W
PTO	66 W	43 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.70 kW	2.00 kW
Annual energy consumption Q _{he}	6738 kWh	7803 kWh

Model: Hydramax Gaz 14B25

Configure model	
Model name	Hydramax Gaz 14B25
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	13.00 kW	10.60 kW
El input	3.11 kW	4.40 kW
COP	4.18	2.41

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	69 dB(A)	69 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	150 %	117 %
Prated	13.00 kW	11.00 kW
SCOP	3.82	3.00
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	10.00 kW
COP Tj = -7°C	2.50	2.00
Pdh Tj = +2°C	6.70 kW	6.10 kW
COP Tj = +2°C	3.70	2.90
Pdh Tj = +7°C	6.20 kW	5.90 kW
COP Tj = +7°C	5.40	4.10
Pdh Tj = 12°C	7.30 kW	7.10 kW
COP Tj = 12°C	7.00	5.40
Pdh Tj = Tbiv	11.10 kW	10.00 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP $T_j = T_{biv}$	2.50	2.00
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	10.80 kW	9.30 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.40	1.60
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	14 W	14 W
PTO	66 W	43 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.70 kW	2.00 kW
Annual energy consumption Q _{he}	6738 kWh	7803 kWh

Model: Alféa Excellia Tri 14 BS

Configure model	
Model name	Alféa Excellia Tri 14 BS
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	13.00 kW	10.60 kW
El input	3.11 kW	4.40 kW
COP	4.18	2.41

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	69 dB(A)	69 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	150 %	117 %
Prated	13.00 kW	11.00 kW
SCOP	3.82	3.00
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	10.00 kW
COP Tj = -7°C	2.50	2.00
Pdh Tj = +2°C	6.70 kW	6.10 kW
COP Tj = +2°C	3.70	2.90
Pdh Tj = +7°C	6.20 kW	5.90 kW
COP Tj = +7°C	5.40	4.10
Pdh Tj = 12°C	7.30 kW	7.10 kW
COP Tj = 12°C	7.00	5.40
Pdh Tj = Tbiv	11.10 kW	10.00 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP $T_j = T_{biv}$	2.50	2.00
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	10.80 kW	9.30 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.40	1.60
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	14 W	14 W
PTO	66 W	43 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.70 kW	2.00 kW
Annual energy consumption Q _{he}	6738 kWh	7803 kWh

Model: Alféa Excellia A.I. Tri 14 (LFC)

Configure model	
Model name	Alféa Excellia A.I. Tri 14 (LFC)
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	13.00 kW	10.60 kW
El input	3.11 kW	4.40 kW
COP	4.18	2.41

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	69 dB(A)	69 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	150 %	117 %
Prated	13.00 kW	11.00 kW
SCOP	3.82	3.00
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	10.00 kW
COP Tj = -7°C	2.50	2.00
Pdh Tj = +2°C	6.70 kW	6.10 kW
COP Tj = +2°C	3.70	2.90
Pdh Tj = +7°C	6.20 kW	5.90 kW
COP Tj = +7°C	5.40	4.10
Pdh Tj = 12°C	7.30 kW	7.10 kW
COP Tj = 12°C	7.00	5.40
Pdh Tj = Tbiv	11.10 kW	10.00 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP $T_j = T_{biv}$	2.50	2.00
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	10.80 kW	9.30 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.40	1.60
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.90	0.90
WTOL	60 °C	60 °C
P _{off}	14 W	14 W
PTO	66 W	43 W
PSB	17 W	17 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.70 kW	2.00 kW
Annual energy consumption Q _{he}	6738 kWh	7803 kWh