

This information was generated by the HP KEYMARK database on 22 Jun 2022

[Login](#)

Summary of	CTC GS 606	Reg. No.	012-C700089
Certificate Holder			
Name	Enertech CTC AB		
Address	Box 309, Näsvägen	Zip	SE-381 26
City	Ljungby	Country	Sweden
Certification Body	RISE CERT		
Subtype title	CTC GS 606		
Heat Pump Type	Brine/Water		
Refrigerant	R407c		
Mass of Refrigerant	1.9 kg		
Certification Date	30.11.2020		
Testing basis	HP Keymark Scheme 2017		

Model: CTC GS 606

Configure model	
Model name	CTC GS 606
Application	Heating + DHW
Units	Indoor
Climate Zone	Colder Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz
Off-peak product	No

Heating

EN 14511-2	
	Medium temperature
Heat output	5.18 kW
El input	1.78 kW
COP	2.91

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Colder Climate

This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 12102-1

	Medium temperature
Sound power level indoor	41 dB(A)

EN 14825

	Medium temperature
η_s	143 %
Prated	6.03 kW
SCOP	3.78
Tbiv	-18 °C
TOL	-22 °C
Pdh Tj = -7°C	5.50 kW
COP Tj = -7°C	3.65
Pdh Tj = +2°C	5.70 kW
COP Tj = +2°C	4.12
Pdh Tj = +7°C	5.80 kW
COP Tj = +7°C	4.47
Pdh Tj = 12°C	5.90 kW
COP Tj = 12°C	4.75
Pdh Tj = Tbiv	5.30 kW
COP Tj = Tbiv	3.18

This information was generated by the HP KEYMARK database on 22 Jun 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	5.18 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	2.91
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.99
WTOL	65 °C
Poff	18 W
PTO	3 W
PSB	18 W
PCK	0 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.90 kW
Annual energy consumption Q_{he}	1685 kWh

Average Climate

EN 12102-1	
	Medium temperature
Sound power level indoor	41 dB(A)

EN 14825	
	Medium temperature
η_s	140 %
Prated	6.41 kW

This information was generated by the HP KEYMARK database on 22 Jun 2022

SCOP	3.69
Tbiv	-6 °C
TOL	-10 °C
Pdh Tj = -7°C	5.30 kW
COP Tj = -7°C	3.18
Pdh Tj = +2°C	5.60 kW
COP Tj = +2°C	3.80
Pdh Tj = +7°C	5.70 kW
COP Tj = +7°C	4.19
Pdh Tj = 12°C	5.80 kW
COP Tj = 12°C	4.62
Pdh Tj = Tbiv	5.37 kW
COP Tj = Tbiv	3.30
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.18 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.91
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.99
WTOL	65 °C
Poff	18 W
PTO	106 W
PSB	18 W
PCK	0 W

This information was generated by the HP KEYMARK database on 22 Jun 2022

Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	1.10 kW
Annual energy consumption Q_{he}	1685 kWh

Domestic Hot Water (DHW)

Colder Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	100 %
COP	2.50
Heating up time	2:14 h:min
Standby power input	57.0 W
Reference hot water temperature	49.7 °C
Mixed water at 40°C	239 l

Average Climate

This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	100 %
COP	2.50
Heating up time	2:14 h:min
Standby power input	57.0 W
Reference hot water temperature	49.7 °C
Mixed water at 40°C	239 l

Model: CTC GS 606 1x230V

Configure model	
Model name	CTC GS 606 1x230V
Application	Heating + DHW
Units	Indoor
Climate Zone	Colder Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz
Off-peak product	No

Heating

EN 14511-2	
	Medium temperature
Heat output	5.18 kW
El input	1.78 kW
COP	2.91

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Colder Climate

This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 12102-1

	Medium temperature
Sound power level indoor	41 dB(A)

EN 14825

	Medium temperature
η_s	143 %
Prated	6.03 kW
SCOP	3.78
Tbiv	-18 °C
TOL	-22 °C
Pdh Tj = -7°C	5.50 kW
COP Tj = -7°C	3.65
Pdh Tj = +2°C	5.70 kW
COP Tj = +2°C	4.12
Pdh Tj = +7°C	5.80 kW
COP Tj = +7°C	4.47
Pdh Tj = 12°C	5.90 kW
COP Tj = 12°C	4.75
Pdh Tj = Tbiv	5.30 kW
COP Tj = Tbiv	3.18

This information was generated by the HP KEYMARK database on 22 Jun 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	5.18 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	2.91
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.99
WTOL	65 °C
Poff	18 W
PTO	3 W
PSB	18 W
PCK	0 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.90 kW
Annual energy consumption Q_{he}	1685 kWh

Average Climate

EN 12102-1	
	Medium temperature
Sound power level indoor	41 dB(A)

EN 14825	
	Medium temperature
η_s	140 %
Prated	6.41 kW

This information was generated by the HP KEYMARK database on 22 Jun 2022

SCOP	3.69
Tbiv	-6 °C
TOL	-10 °C
Pdh Tj = -7°C	5.30 kW
COP Tj = -7°C	3.18
Pdh Tj = +2°C	5.60 kW
COP Tj = +2°C	3.80
Pdh Tj = +7°C	5.70 kW
COP Tj = +7°C	4.19
Pdh Tj = 12°C	5.80 kW
COP Tj = 12°C	4.62
Pdh Tj = Tbiv	5.37 kW
COP Tj = Tbiv	3.30
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.18 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.91
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.99
WTOL	65 °C
Poff	18 W
PTO	106 W
PSB	18 W
PCK	0 W

Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	1.10 kW
Annual energy consumption Q _{he}	1685 kWh

Domestic Hot Water (DHW)

Colder Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	100 %
COP	2.50
Heating up time	2:14 h:min
Standby power input	57.0 W
Reference hot water temperature	49.7 °C
Mixed water at 40°C	239 l

Average Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	100 %
COP	2.50
Heating up time	2:14 h:min
Standby power input	57.0 W
Reference hot water temperature	49.7 °C
Mixed water at 40°C	239 l