

$$\operatorname{\textit{Page}}\ 1$$ of 11 This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	CTC EcoAir 406	Reg. No.	012-056
Certificate Holder	-		
Name	Enertech CTC AB		
Address	Box 309, Näsvägen	Zip	SE-381 26
City	Ljungby	Country	Sweden
Certification Body	RISE CERT	RISE CERT	
Name of testing laboratory	RISE	RISE	
Subtype title	CTC EcoAir 406	CTC EcoAir 406	
Heat Pump Type	Outdoor Air/Water	Outdoor Air/Water	
Refrigerant	R407c	R407c	
Mass Of Refrigerant	2.2 kg	2.2 kg	



Model: CTC EcoAir 406 1x230V

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.22 kW	5.56 kW
El input	1.28 kW	1.83 kW
СОР	4.78	3.03
Indoor water flow rate	1.09 m³/h	0.62 m³/h

EN 14511-4		
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed	
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	

Average Climate



EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	56 dB(A)	56 dB(A)

	EN 14825	
	Low temperature	Medium temperature
η_{s}	151 %	131 %
Prated	5.08 kW	4.95 kW
SCOP	3.90	3.00
Tbiv	-5 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.90 kW	3.50 kW
COP Tj = -7°C	3.16	2.13
Pdh Tj = +2°C	4.80 kW	4.40 kW
COP Tj = +2°C	3.92	2.93
Pdh Tj = +7°C	6.40 kW	6.00 kW
COP Tj = +7°C	5.25	3.99
Pdh Tj = 12°C	7.90 kW	7.60 kW
COP Tj = 12°C	6.66	5.21
Pdh Tj = Tbiv	4.10 kW	3.80 kW
COP Tj = Tbiv	3.35	2.44

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





Pdh Tj = TOL	3.50 kW	3.10 kW
COP Tj = TOL	2.85	1.82
Cdh	0.97	0.98
WTOL	65 °C	65 °C
Poff	18 W	18 W
РТО	19 W	6 W
PSB	18 W	18 W
PCK	o w	o w
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.60 kW	1.90 kW
Annual energy consumption Qhe	2722 kWh	3045 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	56 dB(A)	56 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{S}	131 %	103 %
Prated	4.14 kW	5.14 kW



Page 5 of 11 This information was generated by the HP KEYMARK database on 17 Dec 2020

	Tierated by the HF KLTM	ARK database on 17 Dec 2020
SCOP	3.40	2.70
Tbiv	-13 °C	-9 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	4.00 kW	3.60 kW
COP Tj = -7°C	3.34	2.49
Pdh Tj = +2°C	4.90 kW	4.50 kW
COP Tj = +2°C	4.07	3.22
Pdh Tj = +7°C	6.40 kW	6.10 kW
$COP Tj = +7^{\circ}C$	5.40	4.34
Pdh Tj = 12°C	7.90 kW	7.60 kW
COP Tj = 12°C	6.62	5.44
Pdh Tj = Tbiv	3.20 kW	3.40 kW
COP Tj = Tbiv	2.92	2.37
Pdh Tj = TOL	1.90 kW	1.70 kW
COP Tj = TOL	1.83	1.67
Cdh	0.97	0.98
WTOL	65 °C	65 °C
Poff	18 W	18 W
РТО	19 W	6 W
PSB	18 W	18 W
PCK	o w	o w

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 6 of 11

This information was generated by the HP KEYMARK database on 17 Dec 2020

Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	2.20 kW	3.50 kW
Annual energy consumption Qhe	3045 kWh	4785 kWh



Model: CTC EcoAir 406 3x400V

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	6.22 kW	5.56 kW	
El input	1.28 kW	1.83 kW	
СОР	4.78	3.03	
Indoor water flow rate	1.09 m³/h	0.62 m³/h	

EN 14511-4			
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed		
	pusseu		
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed		
Shutting off the heat transfer medium flow	passed		
Complete power supply failure	passed		
Defrost test	passed		

Average Climate



EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	56 dB(A)	56 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{s}	151 %	131 %
Prated	5.08 kW	4.95 kW
SCOP	3.90	3.00
Tbiv	-5 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.90 kW	3.50 kW
COP Tj = -7°C	3.16	2.13
Pdh Tj = +2°C	4.80 kW	4.40 kW
COP Tj = +2°C	3.92	2.93
Pdh Tj = +7°C	6.40 kW	6.00 kW
COP Tj = +7°C	5.25	3.99
Pdh Tj = 12°C	7.90 kW	7.60 kW
COP Tj = 12°C	6.66	5.21
Pdh Tj = Tbiv	4.10 kW	3.80 kW
COP Tj = Tbiv	3.35	2.44

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





Pdh Tj = TOL	3.50 kW	3.10 kW
COP Tj = TOL	2.85	1.82
Cdh	0.97	0.98
WTOL	65 °C	65 °C
Poff	18 W	18 W
РТО	19 W	6 W
PSB	18 W	18 W
PCK	o w	o w
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.60 kW	1.90 kW
Annual energy consumption Qhe	2722 kWh	3045 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	56 dB(A)	56 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{S}	131 %	103 %
Prated	4.14 kW	5.14 kW



Page 10 of 11

This information was generated by the HP KEYMARK database on 17 Dec 2020

	action was generated by the first	112111711111111111111111111111111111111
SCOP	3.40	2.70
Tbiv	-13 °C	-9 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	4.00 kW	3.60 kW
COP Tj = -7°C	3.34	2.49
Pdh Tj = +2°C	4.90 kW	4.50 kW
COP Tj = +2°C	4.07	3.22
Pdh Tj = +7°C	6.40 kW	6.10 kW
$COP Tj = +7^{\circ}C$	5.40	4.34
Pdh Tj = 12°C	7.90 kW	7.60 kW
COP Tj = 12°C	6.62	5.44
Pdh Tj = Tbiv	3.20 kW	3.40 kW
COP Tj = Tbiv	2.92	2.37
Pdh Tj = TOL	1.90 kW	1.70 kW
COP Tj = TOL	1.83	1.67
Cdh	0.97	0.98
WTOL	65 °C	65 °C
Poff	18 W	18 W
РТО	19 W	6 W
PSB	18 W	18 W
PCK	o w	o w



$$\operatorname{\textit{Page}}\ 11$$ of 11 This information was generated by the HP KEYMARK database on 17 Dec 2020

Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	2.20 kW	3.50 kW
Annual energy consumption Qhe	3045 kWh	4785 kWh