

This information was generated by the HP KEYMARK database on 23 Dec 2020

Summary of	CTC GS 608	Reg. No.	012-C700090
Certificate Holder			
Name	Enertech CTC AB		
Address	Box 309, Näsvägen	Zip	SE-381 26
City	Ljungby	Country	Sweden
Certification Body	RISE CERT		
Subtype title	CTC GS 608		
Heat Pump Type	Brine/Water		
Refrigerant	R407c		
Mass Of Refrigerant	1.9 kg		
Certification Date	30.11.2020		
Testing basis	HP Keymark Scheme 2017		

Model: CTC GS 608

General Data

Power supply	3x400V 50Hz
Off-peak product	No

Heating

EN 14511-2

	Medium temperature
Heat output	7.48 kW
El input	2.38 kW
COP	3.14
Indoor water flow rate	0.83 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 23 Dec 2020

EN 12102-1

	Medium temperature
Sound power level indoor	39 dB(A)

EN 14825

	Medium temperature
η_s	147 %
Prated	8.63 kW
SCOP	3.88
Tbiv	-6 °C
TOL	-10 °C
Pdh Tj = -7°C	7.60 kW
COP Tj = -7°C	3.35
Pdh Tj = +2°C	7.80 kW
COP Tj = +2°C	3.94
Pdh Tj = +7°C	8.00 kW
COP Tj = +7°C	4.33
Pdh Tj = 12°C	8.20 kW
COP Tj = 12°C	4.78
Pdh Tj = Tbiv	7.60 kW
COP Tj = Tbiv	3.47

This information was generated by the HP KEYMARK database on 23 Dec 2020

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	7.48 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	3.14
C_{dh}	0.99
WTOL	65 °C
P _{off}	18 W
PTO	4 W
PSB	18 W
PCK	0 W
Supplementary Heater: Type of energy input	electricity
Supplementary Heater: PSUP	1.20 kW
Annual energy consumption Q _{he}	4594 kWh

Colder Climate

EN 12102-1	
	Medium temperature
Sound power level indoor	39 dB(A)

EN 14825	
	Medium temperature
η_s	151 %
Prated	8.48 kW

This information was generated by the HP KEYMARK database on 23 Dec 2020

SCOP	3.96
Tbiv	-18 °C
TOL	-22 °C
Pdh Tj = -7°C	7.70 kW
COP Tj = -7°C	3.78
Pdh Tj = +2°C	8.00 kW
COP Tj = +2°C	4.28
Pdh Tj = +7°C	8.10 kW
COP Tj = +7°C	4.64
Pdh Tj = 12°C	8.20 kW
COP Tj = 12°C	4.94
Pdh Tj = Tbiv	7.60 kW
COP Tj = Tbiv	3.35
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.48 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.14
Cdh	0.99
WTOL	65 °C
Poff	18 W
PTO	4 W
PSB	18 W
PCK	0 W

This information was generated by the HP KEYMARK database on 23 Dec 2020

Supplementary Heater: Type of energy input	electricity
Supplementary Heater: PSUP	1.00 kW
Annual energy consumption Q _{he}	5275 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	111 %
Heating up time	3:17 h:min
Standby power input	46.0 W
Reference hot water temperature	49.4 °C
Mixed water at 40°C	241 l
COP	2.78

Colder Climate

This information was generated by the HP KEYMARK database on 23 Dec 2020

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	111 %
Heating up time	3:17 h:min
Standby power input	46.0 W
Reference hot water temperature	49.4 °C
Mixed water at 40°C	241 l
COP	2.78

Model: CTC GS 608 1x230V

General Data

Power supply	1x230V 50Hz
Off-peak product	No

Heating

EN 14511-2

	Medium temperature
Heat output	7.48 kW
El input	2.38 kW
COP	3.14
Indoor water flow rate	0.83 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 23 Dec 2020

EN 12102-1

	Medium temperature
Sound power level indoor	39 dB(A)

EN 14825

	Medium temperature
η_s	147 %
Prated	8.63 kW
SCOP	3.88
Tbiv	-6 °C
TOL	-10 °C
Pdh Tj = -7°C	7.60 kW
COP Tj = -7°C	3.35
Pdh Tj = +2°C	7.80 kW
COP Tj = +2°C	3.94
Pdh Tj = +7°C	8.00 kW
COP Tj = +7°C	4.33
Pdh Tj = 12°C	8.20 kW
COP Tj = 12°C	4.78
Pdh Tj = Tbiv	7.60 kW
COP Tj = Tbiv	3.47

This information was generated by the HP KEYMARK database on 23 Dec 2020

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.48 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.14
Cdh	0.99
WTOL	65 °C
Poff	18 W
PTO	4 W
PSB	18 W
PCK	0 W
Supplementary Heater: Type of energy input	electricity
Supplementary Heater: PSUP	1.20 kW
Annual energy consumption Qhe	4594 kWh

Colder Climate

EN 12102-1	
	Medium temperature
Sound power level indoor	39 dB(A)

EN 14825	
	Medium temperature
η_s	151 %
Prated	8.48 kW

This information was generated by the HP KEYMARK database on 23 Dec 2020

SCOP	3.96
Tbiv	-18 °C
TOL	-22 °C
Pdh Tj = -7°C	7.70 kW
COP Tj = -7°C	3.78
Pdh Tj = +2°C	8.00 kW
COP Tj = +2°C	4.28
Pdh Tj = +7°C	8.10 kW
COP Tj = +7°C	4.64
Pdh Tj = 12°C	8.20 kW
COP Tj = 12°C	4.94
Pdh Tj = Tbiv	7.60 kW
COP Tj = Tbiv	3.35
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.48 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.14
Cdh	0.99
WTOL	65 °C
Poff	18 W
PTO	4 W
PSB	18 W
PCK	0 W

This information was generated by the HP KEYMARK database on 23 Dec 2020

Supplementary Heater: Type of energy input	electricity
Supplementary Heater: PSUP	1.00 kW
Annual energy consumption Q _{he}	5275 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	111 %
Heating up time	3:17 h:min
Standby power input	46.0 W
Reference hot water temperature	49.4 °C
Mixed water at 40°C	241 l
COP	2.78

Colder Climate

This information was generated by the HP KEYMARK database on 23 Dec 2020

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	111 %
Heating up time	3:17 h:min
Standby power input	46.0 W
Reference hot water temperature	49.4 °C
Mixed water at 40°C	241 l
COP	2.78