

Page 1 of 5

#### This information was generated by the HP KEYMARK database on 18 Mar 2022

#### <u>Login</u>

Summary of	DAIKIN ALTHERMA GEO	Reg. No.	011-1W0067	
Certificate Holder				
Name	DAIKIN Europe N.V.	DAIKIN Europe N.V.		
Address	Zandvoordestraat 300	Zip	B-8400	
City	Oostende	Country	Belgium	
Certification Body	DIN CERTCO Gesellschaft für Ko	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	DAIKIN ALTHERMA GEO			
Heat Pump Type	Brine/Water			
Refrigerant	R410A			
Mass of Refrigerant	1.8 kg			
Certification Date	17.02.2017			
Testing basis	HP KEYMARK certification scheme rules V8			

This information was generated by the HP KEYMARK database on 18 Mar 2022

## **Model: EGSQH10S18A9W**

Configure model			
Model name	EGSQH10S18A9W		
Application	Heating + DHW + low temp		
Units	Indoor		
Climate Zone	n/a		
Reversibility	No		
Cooling mode application (optional)	n/a		

General Data		
Power supply	3x400V 50Hz	
Off-peak product	No	

### Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	10.30 kW	8.92 kW	
El input	2.38 kW	3.35 kW	
СОР	4.33	2.66	

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	

#### Average Climate




 $$\operatorname{\textit{Page}}\ 3$$  of 5 This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	194 %	139 %
Prated	10.40 kW	8.72 kW
SCOP	5.06	3.68
Tbiv	-9 °C	-9 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.12 kW	7.76 kW
COP Tj = -7°C	4.40	2.91
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	5.77 kW	4.73 kW
COP Tj = +2°C	5.22	3.73
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.82 kW	3.04 kW
COP Tj = +7°C	5.55	4.18
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	2.71 kW	2.61 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





COP Tj = 12°C	5.55	4.73
Cdh Tj = +12 °C	0.93	0.94
Pdh Tj = Tbiv	10.20 kW	8.46 kW
COP Tj = Tbiv	4.17	2.87
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.10 kW	8.41 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.16	2.80
WTOL	35 °C	55 °C
Poff	20 W	20 W
РТО	37 W	37 W
PSB	20 W	20 W
PCK	o w	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.30 kW	0.31 kW
Annual energy consumption Qhe	4260 kWh	4900 kWh

## Domestic Hot Water (DHW)

#### Average Climate





# $$\operatorname{\textit{Page}}\xspace\:5\:\text{of}\:5\:$ This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 16147		
Declared load profile	L	
Standby power input	42.0 W	
Reference hot water temperature	52.0 °C	
Mixed water at 40°C	199 l	
СОР	2.28	
Efficiency ηDHW	93 %	
Heating up time	1:25 h:min	