Login

Summary of	03. Yutaki S Combi 260L 2.0HP R32	Reg. No.	041-K002-31
Certificate Holder			
Name	Johnson Controls-Hitachi AirConditioning Spain		
Address	Ronda Shimizu, 1. Pol. Ind. Can Torrella	Zip	08233
City	Vacarisses, Barcelona	Country	Spain
Certification Body	BRE Global Limited		
Subtype title	03. Yutaki S Combi 260L 2.0HP R32		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	1.2 kg		
Certification Date	08.08.2019		

Model: 01. RAS-2WHVRP RWD-2.0NRWE-260S - Heating Only

Configure model	
Model name	01. RAS-2WHVRP RWD-2.0NRWE-260S - Heating Only
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	4.30 kW	4.30 kW
El input	0.82 kW	1.43 kW
COP	5.25	3.00

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	37 dB(A)	37 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	181 %	133 %
Prated	4.00 kW	4.00 kW
SCOP	4.60	3.40
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.54 kW	3.50 kW
COP Tj = -7°C	3.20	2.13
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	2.35 kW	2.10 kW
COP Tj = +2°C	4.80	3.35
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.00 kW	2.43 kW
COP Tj = +7°C	6.20	5.15
Cdh Tj = +7 °C	0.90	0.90

Pdh Tj = 12°C	3.05 kW	2.80 kW
COP Tj = 12°C	8.30	6.80
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	3.54 kW	3.50 kW
COP Tj = Tbiv	3.20	2.13
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.00 kW	3.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.75	1.90
WTOL	55 °C	55 °C
Poff	12 W	12 W
PTO	0 W	0 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Qhe	1798 kWh	2401 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147

Declared load profile	XL
Efficiency ηDHW	136 %
COP	3.40
Heating up time	2:20 h:min
Standby power input	37.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	350 l

Model: 02. RAS-2WHVRP RWD-2.0NRWE-260S - with cooling kit

Configure model	
Model name	02. RAS-2WHVRP RWD-2.0NRWE-260S - with cooling kit
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C and +18°C/+23°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	4.30 kW	4.30 kW
El input	0.82 kW	1.43 kW
COP	5.25	3.00

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C	+18°C/+23°C
El input	1 kW	1.02 kW
Cooling capacity	4	5.5
EER	4	5.4

EN 14825

	+7°C/+12°C	**+18°C/+23°C**
Pdesignc	4 kW	5.5 kW
SEER	5.57	8.04
Pdc Tj = 35°C	4 kW	5.5 kW
EER Tj = 35°C	4	5.4
Pdc Tj = 30°C	2.95 kW	4.05 kW
EER Tj = 30°C	5	7.2
Cdc	1	1
Pdc Tj = 25°C	2.05 kW	2.61 kW
EER Tj = 25°C	6.45	9.6
Cdc	0.9	0.9
Pdc Tj = 20°C	2.88 kW	2.51 kW
EER Tj = 20°C	8	10.3
Cdc	0.9	0.9
Poff	12 W	12 W
PTO	0 W	0 W
PSB	12 W	12 W
PCK	0 W	0 W
Annual energy consumption Qce	431 kWh	410 kWh

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	37 dB(A)	37 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	186 %	136 %
Prated	4.00 kW	4.00 kW
SCOP	4.73	3.48
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.54 kW	3.50 kW
COP Tj = -7°C	3.20	2.13
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	2.35 kW	2.10 kW
COP Tj = +2°C	4.80	3.35
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.00 kW	2.43 kW
COP Tj = +7°C	6.20	5.15
Cdh Tj = +7 °C	0.90	0.90

Pdh Tj = 12°C	3.05 kW	2.80 kW
COP Tj = 12°C	8.30	6.80
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	3.54 kW	3.50 kW
COP Tj = Tbiv	3.20	2.13
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.00 kW	3.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.75	1.90
WTOL	55 °C	55 °C
Poff	12 W	12 W
PTO	0 W	0 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Qhe	1754 kWh	2357 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147

Declared load profile	XL
Efficiency ηDHW	136 %
COP	3.40
Heating up time	2:20 h:min
Standby power input	37.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	350 l

Model: 03. RAS-2WHVRP RWD-2.0NRWE-260S-K - UK Version - Heating Only

Configure model	
Model name	03. RAS-2WHVRP RWD-2.0NRWE-260S-K - UK Version - Heating Only
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	4.30 kW	4.30 kW
El input	0.82 kW	1.43 kW
COP	5.25	3.00

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	37 dB(A)	37 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	181 %	133 %
Prated	4.00 kW	4.00 kW
SCOP	4.60	3.40
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.54 kW	3.50 kW
COP Tj = -7°C	3.20	2.13
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	2.35 kW	2.10 kW
COP Tj = +2°C	4.80	3.35
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.00 kW	2.43 kW
COP Tj = +7°C	6.20	5.15
Cdh Tj = +7 °C	0.90	0.90

Pdh Tj = 12°C	3.05 kW	2.80 kW
COP Tj = 12°C	8.30	6.80
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	3.54 kW	3.50 kW
COP Tj = Tbiv	3.20	2.13
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.00 kW	3.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.75	1.90
WTOL	55 °C	55 °C
Poff	12 W	12 W
PTO	0 W	0 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Qhe	1798 kWh	2401 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency ηDHW	136 %
COP	3.40
Heating up time	2:20 h:min
Standby power input	37.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	350 l

Model: 04. RAS-2WHVRP RWD-2.0NRWE-260S-K - UK Version - with cooling kit

Configure model	
Model name	04. RAS-2WHVRP RWD-2.0NRWE-260S-K - UK Version - with cooling kit
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C and +18°C/+23°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	4.30 kW	4.30 kW
El input	0.82 kW	1.43 kW
COP	5.25	3.00

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C	+18°C/+23°C
El input	1 kW	1.02 kW
Cooling capacity	4	5.5
EER	4	5.4

EN 14825

	+7°C/+12°C	**+18°C/+23°C**
Pdesignc	4 kW	5.5 kW
SEER	5.57	8.04
Pdc Tj = 35°C	4 kW	5.5 kW
EER Tj = 35°C	4	5.4
Pdc Tj = 30°C	2.95 kW	4.05 kW
EER Tj = 30°C	5	7.2
Cdc	1	1
Pdc Tj = 25°C	2.05 kW	2.61 kW
EER Tj = 25°C	6.45	9.6
Cdc	0.9	0.9
Pdc Tj = 20°C	2.88 kW	2.51 kW
EER Tj = 20°C	8	10.3
Cdc	0.9	0.9
Poff	12 W	12 W
PTO	0 W	0 W
PSB	12 W	12 W
PCK	0 W	0 W
Annual energy consumption Qce	431 kWh	410 kWh

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	37 dB(A)	37 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	186 %	136 %
Prated	4.00 kW	4.00 kW
SCOP	4.73	3.48
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.54 kW	3.50 kW
COP Tj = -7°C	3.20	2.13
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	2.35 kW	2.10 kW
COP Tj = +2°C	4.80	3.35
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.00 kW	2.43 kW
COP Tj = +7°C	6.20	5.15
Cdh Tj = +7 °C	0.90	0.90

Pdh Tj = 12°C	3.05 kW	2.80 kW
COP Tj = 12°C	8.30	6.80
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	3.54 kW	3.50 kW
COP Tj = Tbiv	3.20	2.13
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.00 kW	3.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.75	1.90
WTOL	55 °C	55 °C
Poff	12 W	12 W
PTO	0 W	0 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Qhe	1754 kWh	2357 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency ηDHW	136 %
COP	3.40
Heating up time	2:20 h:min
Standby power input	37.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	350 l

Model: 05. RAS-2WHVRP RWD-2.0NRWSE-260S - Solar Version - Heating Only

Configure model	
Model name	05. RAS-2WHVRP RWD-2.0NRWSE-260S - Solar Version - Heating Only
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	4.30 kW	4.30 kW
El input	0.82 kW	1.43 kW
COP	5.25	3.00

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	37 dB(A)	37 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	181 %	133 %
Prated	4.00 kW	4.00 kW
SCOP	4.60	3.40
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.54 kW	3.50 kW
COP Tj = -7°C	3.20	2.13
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	2.35 kW	2.10 kW
COP Tj = +2°C	4.80	3.35
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.00 kW	2.43 kW
COP Tj = +7°C	6.20	5.15
Cdh Tj = +7 °C	0.90	0.90

Pdh Tj = 12°C	3.05 kW	2.80 kW
COP Tj = 12°C	8.30	6.80
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	3.54 kW	3.50 kW
COP Tj = Tbiv	3.20	2.13
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.00 kW	3.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.75	1.90
WTOL	55 °C	55 °C
Poff	12 W	12 W
PTO	0 W	0 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Qhe	1798 kWh	2401 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147

Declared load profile	XL
Efficiency ηDHW	136 %
COP	3.40
Heating up time	2:20 h:min
Standby power input	37.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	350 l

Model: 06. RAS-2WHVRP RWD-2.0NRWSE-260S - Solar Version - with cooling kit

Configure model	
Model name	06. RAS-2WHVRP RWD-2.0NRWSE-260S - Solar Version - with cooling kit
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C and +18°C/+23°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	4.30 kW	4.30 kW
El input	0.82 kW	1.43 kW
COP	5.25	3.00

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C	+18°C/+23°C
El input	1 kW	1.02 kW
Cooling capacity	4	5.5
EER	4	5.4

EN 14825

	+7°C/+12°C	**+18°C/+23°C**
Pdesignc	4 kW	5.5 kW
SEER	5.57	8.04
Pdc Tj = 35°C	4 kW	5.5 kW
EER Tj = 35°C	4	5.4
Pdc Tj = 30°C	2.95 kW	4.05 kW
EER Tj = 30°C	5	7.2
Cdc	1	1
Pdc Tj = 25°C	2.05 kW	2.61 kW
EER Tj = 25°C	6.45	9.6
Cdc	0.9	0.9
Pdc Tj = 20°C	2.88 kW	2.51 kW
EER Tj = 20°C	8	10.3
Cdc	0.9	0.9
Poff	12 W	12 W
PTO	0 W	0 W
PSB	12 W	12 W
PCK	0 W	0 W
Annual energy consumption Qce	431 kWh	410 kWh

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	37 dB(A)	37 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	186 %	136 %
Prated	4.00 kW	4.00 kW
SCOP	4.73	3.48
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.54 kW	3.50 kW
COP Tj = -7°C	3.20	2.13
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	2.35 kW	2.10 kW
COP Tj = +2°C	4.80	3.35
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.00 kW	2.43 kW
COP Tj = +7°C	6.20	5.15
Cdh Tj = +7 °C	0.90	0.90

Pdh Tj = 12°C	3.05 kW	2.80 kW
COP Tj = 12°C	8.30	6.80
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	3.54 kW	3.50 kW
COP Tj = Tbiv	3.20	2.13
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.00 kW	3.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.75	1.90
WTOL	55 °C	55 °C
Poff	12 W	12 W
PTO	0 W	0 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Qhe	1754 kWh	2357 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147

Declared load profile	XL
Efficiency ηDHW	136 %
COP	3.40
Heating up time	2:20 h:min
Standby power input	37.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	350 l