Summary of	DAIKIN ALTHERMA 3 H HT 16KW (180L)	Reg. No.	011-1W0357
Certificate Holder			
Name	DAIKIN Europe N.V.		
Address	Zandvoordestraat 300	Zip	B-8400
City	Oostende	Country	Belgium
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Name of testing laboratory	Danish Technological Institute (DTI)		
Subtype title	DAIKIN ALTHERMA 3 H HT 16KW (180L)		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass Of Refrigerant	4.2 kg		
Certification Date	07.02.2020		

Model: EPRA16DV / ETBH16D6V

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	9.00 kW	7.24 kW
El input	1.80 kW	2.41 kW
COP	5.00	3.01
Indoor water flow rate	1.55 m³/h	0.89 m³/h

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	54 dB(A)	54 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	177 %	140 %
Prated	13.00 kW	13.00 kW
SCOP	4.51	3.58
Tbiv	-7 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	11.20 kW
COP Tj = -7°C	3.12	2.47
Cdh	1.00	1.00
Pdh Tj = +2°C	6.70 kW	6.90 kW
COP Tj = +2°C	4.44	3.56
Cdh	1.00	1.00
Pdh Tj = +7°C	5.70 kW	6.90 kW
COP Tj = +7°C	5.84	4.44
Cdh	1.00	1.00

Pdh Tj = 12°C	6.00 kW	6.20 kW
COP Tj = 12°C	7.40	5.72
Cdh	1.00	1.00
Pdh Tj = Tbiv	11.10 kW	12.20 kW
COP Tj = Tbiv	3.12	2.19
Pdh Tj = TOL	11.10 kW	12.20 kW
COP Tj = TOL	2.76	2.19
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electrical	electrical
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Qhe	5726 kWh	7211 kWh

Model: EPRA16DV / ETBH16D9W

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	9.00 kW	7.24 kW
El input	1.80 kW	2.41 kW
COP	5.00	3.01
Indoor water flow rate	1.55 m³/h	0.89 m³/h

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	54 dB(A)	54 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	177 %	140 %
Prated	13.00 kW	13.00 kW
SCOP	4.51	3.58
Tbiv	-7 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	11.20 kW
COP Tj = -7°C	3.12	2.47
Cdh	1.00	1.00
Pdh Tj = +2°C	6.70 kW	6.90 kW
COP Tj = +2°C	4.44	3.56
Cdh	1.00	1.00
Pdh Tj = +7°C	5.70 kW	6.90 kW
COP Tj = +7°C	5.84	4.44
Cdh	1.00	1.00

Pdh Tj = 12°C	6.00 kW	6.20 kW
COP Tj = 12°C	7.40	5.72
Cdh	1.00	1.00
Pdh Tj = Tbiv	11.10 kW	12.20 kW
COP Tj = Tbiv	3.12	2.19
Pdh Tj = TOL	11.10 kW	12.20 kW
COP Tj = TOL	2.76	2.19
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electrical	electrical
Supplementary Heater: PSUP	9.00 kW	9.00 kW
Annual energy consumption Qhe	5726 kWh	7211 kWh

Model: EPRA16DW / ETBH16D6V

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	9.00 kW	7.24 kW
El input	1.23 kW	2.47 kW
COP	5.00	2.93
Indoor water flow rate	1.55 m³/h	0.89 m³/h

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	54 dB(A)	54 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	176 %	140 %
Prated	13.00 kW	13.00 kW
SCOP	4.48	3.57
Tbiv	-7 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.72 kW	11.10 kW
COP Tj = -7°C	2.97	2.43
Cdh	1.00	1.00
Pdh Tj = +2°C	6.87 kW	6.70 kW
COP Tj = +2°C	4.94	3.52
Cdh	1.00	1.00
Pdh Tj = +7°C	6.10 kW	6.50 kW
COP Tj = +7°C	5.75	4.54
Cdh	1.00	1.00

Pdh Tj = 12°C	5.50 kW	5.20 kW
COP Tj = 12°C	6.97	5.97
Cdh	1.00	1.00
Pdh Tj = Tbiv	10.72 kW	12.50 kW
COP Tj = Tbiv	2.97	2.12
Pdh Tj = TOL	11.80 kW	12.50 kW
COP Tj = TOL	2.84	2.12
WTOL	35 °C	55 °C
Poff	31 W	31 W
PTO	33 W	33 W
PSB	42 W	42 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electrical	electrical
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Qhe	5765 kWh	7236 kWh

Model: EPRA16DW / ETBH16D9W

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	9.00 kW	7.24 kW
El input	1.23 kW	2.47 kW
COP	5.00	2.93
Indoor water flow rate	1.55 m³/h	0.89 m³/h

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	54 dB(A)	54 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	176 %	140 %
Prated	13.00 kW	13.00 kW
SCOP	4.48	3.57
Tbiv	-7 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.72 kW	11.10 kW
COP Tj = -7°C	2.97	2.43
Cdh	1.00	1.00
Pdh Tj = +2°C	6.87 kW	6.70 kW
COP Tj = +2°C	4.94	3.52
Cdh	1.00	1.00
Pdh Tj = +7°C	6.10 kW	6.50 kW
COP Tj = +7°C	5.75	4.54
Cdh	1.00	1.00

Pdh Tj = 12°C	5.50 kW	5.20 kW
COP Tj = 12°C	6.97	5.97
Cdh	1.00	1.00
Pdh Tj = Tbiv	10.72 kW	12.50 kW
COP Tj = Tbiv	2.97	2.12
Pdh Tj = TOL	11.80 kW	12.50 kW
COP Tj = TOL	2.84	2.12
WTOL	35 °C	55 °C
Poff	31 W	31 W
PTO	33 W	33 W
PSB	42 W	42 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electrical	electrical
Supplementary Heater: PSUP	9.00 kW	9.00 kW
Annual energy consumption Qhe	5765 kWh	7236 kWh

Model: EPRA16DV / ETBX16D6V

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	9.00 kW	7.24 kW
El input	1.80 kW	2.41 kW
COP	5.00	3.01
Indoor water flow rate	1.55 m³/h	0.89 m³/h

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	54 dB(A)	54 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	180 %	142 %
Prated	13.00 kW	13.00 kW
SCOP	4.57	3.62
Tbiv	-7 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	11.20 kW
COP Tj = -7°C	3.12	2.47
Cdh	1.00	1.00
Pdh Tj = +2°C	6.70 kW	6.90 kW
COP Tj = +2°C	4.44	3.56
Cdh	1.00	1.00
Pdh Tj = +7°C	5.70 kW	6.90 kW
COP Tj = +7°C	5.84	4.44
Cdh	1.00	1.00

Pdh Tj = 12°C	6.00 kW	6.20 kW
COP Tj = 12°C	7.40	5.72
Cdh	1.00	1.00
Pdh Tj = Tbiv	11.10 kW	12.20 kW
COP Tj = Tbiv	3.12	2.19
Pdh Tj = TOL	11.10 kW	12.20 kW
COP Tj = TOL	2.76	2.19
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electrical	electrical
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Qhe	5649 kWh	7134 kWh

Cooling

EN 14511-2

	+7°C/+12°C
El input	2.54 kW
Indoor water flow rate	1.34 m³/h
Cooling capacity	7.88
EER	2.69

EN 14825

	+7°C/+12°C
Pdesignc	7.88 kW
SEER	4.08
Pdc Tj = 35°C	7.88 kW
EER Tj = 35°C	2.69
Pdc Tj = 30°C	5.92 kW
EER Tj = 30°C	3.69
Cdc	1.0
Pdc Tj = 25°C	5.09 kW
EER Tj = 25°C	4.63
Cdc	1.0
Pdc Tj = 20°C	5.13 kW
EER Tj = 20°C	5.61
Cdc	1.0
Poff	21 W
PTO	41 W
PSB	21 W
PCK	0 W
Annual energy consumption Qce	1158 kWh

Model: EPRA16DV / ETBX16D9W

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	9.00 kW	7.24 kW
El input	1.80 kW	2.41 kW
COP	5.00	3.01
Indoor water flow rate	1.55 m³/h	0.89 m³/h

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	54 dB(A)	54 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	180 %	142 %
Prated	13.00 kW	13.00 kW
SCOP	4.57	3.62
Tbiv	-7 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	11.20 kW
COP Tj = -7°C	3.12	2.47
Cdh	1.00	1.00
Pdh Tj = +2°C	6.70 kW	6.90 kW
COP Tj = +2°C	4.44	3.56
Cdh	1.00	1.00
Pdh Tj = +7°C	5.70 kW	6.90 kW
COP Tj = +7°C	5.84	4.44
Cdh	1.00	1.00

Pdh Tj = 12°C	6.00 kW	6.20 kW
COP Tj = 12°C	7.40	5.72
Cdh	1.00	1.00
Pdh Tj = Tbiv	11.10 kW	12.20 kW
COP Tj = Tbiv	3.12	2.19
Pdh Tj = TOL	11.10 kW	12.20 kW
COP Tj = TOL	2.76	2.19
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electrical	electrical
Supplementary Heater: PSUP	9.00 kW	9.00 kW
Annual energy consumption Qhe	5649 kWh	7134 kWh

Cooling

EN 14511-2

	+7°C/+12°C
El input	2.54 kW
Indoor water flow rate	1.34 m³/h
Cooling capacity	7.88
EER	2.69

EN 14825

	+7°C/+12°C
Pdesignc	7.88 kW
SEER	4.08
Pdc Tj = 35°C	7.88 kW
EER Tj = 35°C	2.69
Pdc Tj = 30°C	5.92 kW
EER Tj = 30°C	3.69
Cdc	1.0
Pdc Tj = 25°C	5.09 kW
EER Tj = 25°C	4.63
Cdc	1.0
Pdc Tj = 20°C	5.13 kW
EER Tj = 20°C	5.61
Cdc	1.0
Poff	21 W
PTO	41 W
PSB	21 W
PCK	0 W
Annual energy consumption Qce	1158 kWh

Model: EPRA16DW / ETBX16D6V

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	9.00 kW	7.24 kW
El input	1.23 kW	2.47 kW
COP	5.00	2.93
Indoor water flow rate	1.55 m³/h	0.89 m³/h

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	54 dB(A)	54 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	180 %	142 %
Prated	13.00 kW	13.00 kW
SCOP	4.57	3.63
Tbiv	-7 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.72 kW	11.10 kW
COP Tj = -7°C	2.97	2.43
Cdh	1.00	1.00
Pdh Tj = +2°C	6.87 kW	6.70 kW
COP Tj = +2°C	4.94	3.52
Cdh	1.00	1.00
Pdh Tj = +7°C	6.10 kW	6.50 kW
COP Tj = +7°C	5.75	4.54
Cdh	1.00	1.00

Pdh Tj = 12°C	5.50 kW	5.20 kW
COP Tj = 12°C	6.97	5.97
Cdh	1.00	1.00
Pdh Tj = Tbiv	10.72 kW	12.50 kW
COP Tj = Tbiv	2.97	2.12
Pdh Tj = TOL	11.80 kW	12.50 kW
COP Tj = TOL	2.84	2.12
WTOL	35 °C	55 °C
Poff	31 W	31 W
PTO	33 W	33 W
PSB	42 W	42 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electrical	electrical
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Qhe	5651 kWh	7122 kWh

Cooling

EN 14511-2

	+7°C/+12°C
El input	3.32 kW
Indoor water flow rate	1.34 m³/h
Cooling capacity	7.88
EER	2.69

EN 14825

	+7°C/+12°C
Pdesignc	7.88 kW
SEER	3.98
Pdc Tj = 35°C	7.88 kW
EER Tj = 35°C	2.69
Pdc Tj = 30°C	5.92 kW
EER Tj = 30°C	3.69
Cdc	1.0
Pdc Tj = 25°C	5.09 kW
EER Tj = 25°C	4.63
Cdc	1.0
Pdc Tj = 20°C	5.13 kW
EER Tj = 20°C	5.61
Cdc	1.0
Poff	31 W
PTO	33 W
PSB	42 W
PCK	0 W
Annual energy consumption Qce	1188 kWh

Model: EPRA16DW / ETBX16D9W

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	9.00 kW	7.24 kW
El input	1.23 kW	2.47 kW
COP	5.00	2.93
Indoor water flow rate	1.55 m³/h	0.89 m³/h

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	54 dB(A)	54 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	180 %	142 %
Prated	13.00 kW	13.00 kW
SCOP	4.57	3.63
Tbiv	-7 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.72 kW	11.10 kW
COP Tj = -7°C	2.97	2.43
Cdh	1.00	1.00
Pdh Tj = +2°C	6.87 kW	6.70 kW
COP Tj = +2°C	4.94	3.52
Cdh	1.00	1.00
Pdh Tj = +7°C	6.10 kW	6.50 kW
COP Tj = +7°C	5.75	4.54
Cdh	1.00	1.00

Pdh Tj = 12°C	5.50 kW	5.20 kW
COP Tj = 12°C	6.97	5.97
Cdh	1.00	1.00
Pdh Tj = Tbiv	10.72 kW	12.50 kW
COP Tj = Tbiv	2.97	2.12
Pdh Tj = TOL	11.80 kW	12.50 kW
COP Tj = TOL	2.84	2.12
WTOL	35 °C	55 °C
Poff	31 W	31 W
PTO	33 W	33 W
PSB	42 W	42 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electrical	electrical
Supplementary Heater: PSUP	9.00 kW	9.00 kW
Annual energy consumption Qhe	5651 kWh	7122 kWh

Cooling

EN 14511-2

	+7°C/+12°C
El input	3.32 kW
Indoor water flow rate	1.34 m³/h
Cooling capacity	7.88
EER	2.69

EN 14825

	+7°C/+12°C
Pdesignc	7.88 kW
SEER	3.98
Pdc Tj = 35°C	7.88 kW
EER Tj = 35°C	2.69
Pdc Tj = 30°C	5.92 kW
EER Tj = 30°C	3.69
Cdc	1.0
Pdc Tj = 25°C	5.09 kW
EER Tj = 25°C	4.63
Cdc	1.0
Pdc Tj = 20°C	5.13 kW
EER Tj = 20°C	5.61
Cdc	1.0
Poff	31 W
PTO	33 W
PSB	42 W
PCK	0 W
Annual energy consumption Qce	1188 kWh

Model: EPRA16DV / ETVH16S18D6V(G)

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	9.00 kW	7.24 kW
El input	1.80 kW	2.41 kW
COP	5.00	3.01
Indoor water flow rate	1.55 m³/h	0.89 m³/h

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	54 dB(A)	54 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	177 %	140 %
Prated	13.00 kW	13.00 kW
SCOP	4.51	3.58
Tbiv	-7 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	11.20 kW
COP Tj = -7°C	3.12	2.47
Cdh	1.00	1.00
Pdh Tj = +2°C	6.70 kW	6.90 kW
COP Tj = +2°C	4.44	3.56
Cdh	1.00	1.00
Pdh Tj = +7°C	5.70 kW	6.90 kW
COP Tj = +7°C	5.84	4.44
Cdh	1.00	1.00

Pdh Tj = 12°C	6.00 kW	6.20 kW
COP Tj = 12°C	7.40	5.72
Cdh	1.00	1.00
Pdh Tj = Tbiv	11.10 kW	12.20 kW
COP Tj = Tbiv	3.12	2.19
Pdh Tj = TOL	11.10 kW	12.20 kW
COP Tj = TOL	2.76	2.19
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electrical	electrical
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Qhe	5726 kWh	7211 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147

Declared load profile	L
Efficiency ηDHW	110 %
COP	2.62
Heating up time	1:07 h:min
Standby power input	34.2 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPRA16DV / ETVH16S18D9W(G)

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	9.00 kW	7.24 kW
El input	1.80 kW	2.41 kW
COP	5.00	3.01
Indoor water flow rate	1.55 m³/h	0.89 m³/h

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	54 dB(A)	54 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	177 %	140 %
Prated	13.00 kW	13.00 kW
SCOP	4.51	3.58
Tbiv	-7 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	11.20 kW
COP Tj = -7°C	3.12	2.47
Cdh	1.00	1.00
Pdh Tj = +2°C	6.70 kW	6.90 kW
COP Tj = +2°C	4.44	3.56
Cdh	1.00	1.00
Pdh Tj = +7°C	5.70 kW	6.90 kW
COP Tj = +7°C	5.84	4.44
Cdh	1.00	1.00

Pdh Tj = 12°C	6.00 kW	6.20 kW
COP Tj = 12°C	7.40	5.72
Cdh	1.00	1.00
Pdh Tj = Tbiv	11.10 kW	12.20 kW
COP Tj = Tbiv	3.12	2.19
Pdh Tj = TOL	11.10 kW	12.20 kW
COP Tj = TOL	2.76	2.19
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electrical	electrical
Supplementary Heater: PSUP	9.00 kW	9.00 kW
Annual energy consumption Qhe	5726 kWh	7211 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency ηDHW	110 %
COP	2.62
Heating up time	1:07 h:min
Standby power input	34.2 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPRA16DW / ETVH16S18D6V(G)

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	9.00 kW	7.24 kW
El input	1.23 kW	2.47 kW
COP	5.00	2.93
Indoor water flow rate	1.55 m³/h	0.89 m³/h

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	54 dB(A)	54 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	176 %	140 %
Prated	13.00 kW	13.00 kW
SCOP	4.48	3.57
Tbiv	-7 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.72 kW	11.10 kW
COP Tj = -7°C	2.97	2.43
Cdh	1.00	1.00
Pdh Tj = +2°C	6.87 kW	6.70 kW
COP Tj = +2°C	4.94	3.52
Cdh	1.00	1.00
Pdh Tj = +7°C	6.10 kW	6.50 kW
COP Tj = +7°C	5.75	4.54
Cdh	1.00	1.00

Pdh Tj = 12°C	5.50 kW	5.20 kW
COP Tj = 12°C	6.97	5.97
Cdh	1.00	1.00
Pdh Tj = Tbiv	10.72 kW	12.50 kW
COP Tj = Tbiv	2.97	2.12
Pdh Tj = TOL	11.80 kW	12.50 kW
COP Tj = TOL	2.84	2.12
WTOL	35 °C	55 °C
Poff	31 W	31 W
PTO	33 W	33 W
PSB	42 W	42 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electrical	electrical
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Qhe	5765 kWh	7236 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency ηDHW	106 %
COP	2.51
Heating up time	1:07 h:min
Standby power input	42.9 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPRA16DW / ETVH16S18D9W(G)

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	9.00 kW	7.24 kW
El input	1.23 kW	2.47 kW
COP	5.00	2.93
Indoor water flow rate	1.55 m³/h	0.89 m³/h

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	54 dB(A)	54 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	176 %	140 %
Prated	13.00 kW	13.00 kW
SCOP	4.48	3.57
Tbiv	-7 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.72 kW	11.10 kW
COP Tj = -7°C	2.97	2.43
Cdh	1.00	1.00
Pdh Tj = +2°C	6.87 kW	6.70 kW
COP Tj = +2°C	4.94	3.52
Cdh	1.00	1.00
Pdh Tj = +7°C	6.10 kW	6.50 kW
COP Tj = +7°C	5.75	4.54
Cdh	1.00	1.00

Pdh Tj = 12°C	5.50 kW	5.20 kW
COP Tj = 12°C	6.97	5.97
Cdh	1.00	1.00
Pdh Tj = Tbiv	10.72 kW	12.50 kW
COP Tj = Tbiv	2.97	2.12
Pdh Tj = TOL	11.80 kW	12.50 kW
COP Tj = TOL	2.84	2.12
WTOL	35 °C	55 °C
Poff	31 W	31 W
PTO	33 W	33 W
PSB	42 W	42 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electrical	electrical
Supplementary Heater: PSUP	9.00 kW	9.00 kW
Annual energy consumption Qhe	5765 kWh	7236 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency ηDHW	106 %
COP	2.51
Heating up time	1:07 h:min
Standby power input	42.9 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPRA16DV / ETVX16S18D6V(G)

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	9.00 kW	7.24 kW
El input	1.80 kW	2.41 kW
COP	5.00	3.01
Indoor water flow rate	1.55 m³/h	0.89 m³/h

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	54 dB(A)	54 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	180 %	142 %
Prated	13.00 kW	13.00 kW
SCOP	4.57	3.62
Tbiv	-7 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	11.20 kW
COP Tj = -7°C	3.12	2.47
Cdh	1.00	1.00
Pdh Tj = +2°C	6.70 kW	6.90 kW
COP Tj = +2°C	4.44	3.56
Cdh	1.00	1.00
Pdh Tj = +7°C	5.70 kW	6.90 kW
COP Tj = +7°C	5.84	4.44
Cdh	1.00	1.00

Pdh Tj = 12°C	6.00 kW	6.20 kW
COP Tj = 12°C	7.40	5.72
Cdh	1.00	1.00
Pdh Tj = Tbiv	11.10 kW	12.20 kW
COP Tj = Tbiv	3.12	2.19
Pdh Tj = TOL	11.10 kW	12.20 kW
COP Tj = TOL	2.76	2.19
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electrical	electrical
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Qhe	5649 kWh	7134 kWh

Cooling

EN 14511-2

	+7°C/+12°C
El input	2.54 kW
Indoor water flow rate	1.34 m³/h
Cooling capacity	7.88
EER	2.69

EN 14825

	+7°C/+12°C
Pdesignc	7.88 kW
SEER	4.08
Pdc Tj = 35°C	7.88 kW
EER Tj = 35°C	2.69
Pdc Tj = 30°C	5.92 kW
EER Tj = 30°C	3.69
Cdc	1.0
Pdc Tj = 25°C	5.09 kW
EER Tj = 25°C	4.63
Cdc	1.0
Pdc Tj = 20°C	5.13 kW
EER Tj = 20°C	5.61
Cdc	1.0
Poff	21 W
PTO	41 W
PSB	21 W
PCK	0 W
Annual energy consumption Qce	1158 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency ηDHW	110 %
COP	2.62
Heating up time	1:07 h:min
Standby power input	34.2 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPRA16DV / ETVX16S18D9W(G)

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	9.00 kW	7.24 kW
El input	1.80 kW	2.41 kW
COP	5.00	3.01
Indoor water flow rate	1.55 m³/h	0.89 m³/h

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	54 dB(A)	54 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	180 %	142 %
Prated	13.00 kW	13.00 kW
SCOP	4.57	3.62
Tbiv	-7 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	11.20 kW
COP Tj = -7°C	3.12	2.47
Cdh	1.00	1.00
Pdh Tj = +2°C	6.70 kW	6.90 kW
COP Tj = +2°C	4.44	3.56
Cdh	1.00	1.00
Pdh Tj = +7°C	5.70 kW	6.90 kW
COP Tj = +7°C	5.84	4.44
Cdh	1.00	1.00

Pdh Tj = 12°C	6.00 kW	6.20 kW
COP Tj = 12°C	7.40	5.72
Cdh	1.00	1.00
Pdh Tj = Tbiv	11.10 kW	12.20 kW
COP Tj = Tbiv	3.12	2.19
Pdh Tj = TOL	11.10 kW	12.20 kW
COP Tj = TOL	2.76	2.19
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electrical	electrical
Supplementary Heater: PSUP	9.00 kW	9.00 kW
Annual energy consumption Qhe	5649 kWh	7134 kWh

Cooling

EN 14511-2

	+7°C/+12°C
El input	2.54 kW
Indoor water flow rate	1.34 m³/h
Cooling capacity	7.88
EER	2.69

EN 14825

	+7°C/+12°C
Pdesignc	7.88 kW
SEER	4.08
Pdc Tj = 35°C	7.88 kW
EER Tj = 35°C	2.69
Pdc Tj = 30°C	5.92 kW
EER Tj = 30°C	3.69
Cdc	1.0
Pdc Tj = 25°C	5.09 kW
EER Tj = 25°C	4.63
Cdc	1.0
Pdc Tj = 20°C	5.13 kW
EER Tj = 20°C	5.61
Cdc	1.0
Poff	21 W
PTO	41 W
PSB	21 W
PCK	0 W
Annual energy consumption Qce	1158 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147

Declared load profile	L
Efficiency ηDHW	110 %
COP	2.62
Heating up time	1:07 h:min
Standby power input	34.2 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPRA16DW / ETVX16S18D6V(G)

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	9.00 kW	7.24 kW
El input	1.23 kW	2.47 kW
COP	5.00	2.93
Indoor water flow rate	1.55 m³/h	0.89 m³/h

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	54 dB(A)	54 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	180 %	142 %
Prated	13.00 kW	13.00 kW
SCOP	4.57	3.63
Tbiv	-7 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.72 kW	11.10 kW
COP Tj = -7°C	2.97	2.43
Cdh	1.00	1.00
Pdh Tj = +2°C	6.87 kW	6.70 kW
COP Tj = +2°C	4.94	3.52
Cdh	1.00	1.00
Pdh Tj = +7°C	6.10 kW	6.50 kW
COP Tj = +7°C	5.75	4.54
Cdh	1.00	1.00

Pdh Tj = 12°C	5.50 kW	5.20 kW
COP Tj = 12°C	6.97	5.97
Cdh	1.00	1.00
Pdh Tj = Tbiv	10.72 kW	12.50 kW
COP Tj = Tbiv	2.97	2.12
Pdh Tj = TOL	11.80 kW	12.50 kW
COP Tj = TOL	2.84	2.12
WTOL	35 °C	55 °C
Poff	31 W	31 W
PTO	33 W	33 W
PSB	42 W	42 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electrical	electrical
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Qhe	5651 kWh	7122 kWh

Cooling

EN 14511-2

	+7°C/+12°C
El input	3.32 kW
Indoor water flow rate	1.34 m³/h
Cooling capacity	7.88
EER	2.69

EN 14825

	+7°C/+12°C
Pdesignc	7.88 kW
SEER	3.98
Pdc Tj = 35°C	7.88 kW
EER Tj = 35°C	2.69
Pdc Tj = 30°C	5.92 kW
EER Tj = 30°C	3.69
Cdc	1.0
Pdc Tj = 25°C	5.09 kW
EER Tj = 25°C	4.63
Cdc	1.0
Pdc Tj = 20°C	5.13 kW
EER Tj = 20°C	5.61
Cdc	1.0
Poff	31 W
PTO	33 W
PSB	42 W
PCK	0 W
Annual energy consumption Qce	1188 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147

Declared load profile	L
Efficiency ηDHW	110 %
COP	2.62
Heating up time	1:07 h:min
Standby power input	34.2 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPRA16DW / ETVX16S18D9W(G)

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	9.00 kW	7.24 kW
El input	1.23 kW	2.47 kW
COP	5.00	2.93
Indoor water flow rate	1.55 m³/h	0.89 m³/h

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	54 dB(A)	54 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	180 %	142 %
Prated	13.00 kW	13.00 kW
SCOP	4.57	3.63
Tbiv	-7 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.72 kW	11.10 kW
COP Tj = -7°C	2.97	2.43
Cdh	1.00	1.00
Pdh Tj = +2°C	6.87 kW	6.70 kW
COP Tj = +2°C	4.94	3.52
Cdh	1.00	1.00
Pdh Tj = +7°C	6.10 kW	6.50 kW
COP Tj = +7°C	5.75	4.54
Cdh	1.00	1.00

Pdh Tj = 12°C	5.50 kW	5.20 kW
COP Tj = 12°C	6.97	5.97
Cdh	1.00	1.00
Pdh Tj = Tbiv	10.72 kW	12.50 kW
COP Tj = Tbiv	2.97	2.12
Pdh Tj = TOL	11.80 kW	12.50 kW
COP Tj = TOL	2.84	2.12
WTOL	35 °C	55 °C
Poff	31 W	31 W
PTO	33 W	33 W
PSB	42 W	42 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electrical	electrical
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Qhe	5651 kWh	7122 kWh

Cooling

EN 14511-2

	+7°C/+12°C
El input	3.32 kW
Indoor water flow rate	1.34 m³/h
Cooling capacity	7.88
EER	2.69

EN 14825

	+7°C/+12°C
Pdesignc	7.88 kW
SEER	3.98
Pdc Tj = 35°C	7.88 kW
EER Tj = 35°C	2.69
Pdc Tj = 30°C	5.92 kW
EER Tj = 30°C	3.69
Cdc	1.0
Pdc Tj = 25°C	5.09 kW
EER Tj = 25°C	4.63
Cdc	1.0
Pdc Tj = 20°C	5.13 kW
EER Tj = 20°C	5.61
Cdc	1.0
Poff	31 W
PTO	33 W
PSB	42 W
PCK	0 W
Annual energy consumption Qce	1188 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency ηDHW	110 %
COP	2.62
Heating up time	1:07 h:min
Standby power input	34.2 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPRA16DV / ETVZ16S18D6V(G)

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	9.00 kW	7.24 kW
El input	1.80 kW	2.41 kW
COP	5.00	3.01
Indoor water flow rate	1.55 m³/h	0.89 m³/h

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	54 dB(A)	54 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	177 %	140 %
Prated	13.00 kW	13.00 kW
SCOP	4.51	3.58
Tbiv	-7 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	11.20 kW
COP Tj = -7°C	3.12	2.47
Cdh	1.00	1.00
Pdh Tj = +2°C	6.70 kW	6.90 kW
COP Tj = +2°C	4.44	3.56
Cdh	1.00	1.00
Pdh Tj = +7°C	5.70 kW	6.90 kW
COP Tj = +7°C	5.84	4.44
Cdh	1.00	1.00

Pdh Tj = 12°C	6.00 kW	6.20 kW
COP Tj = 12°C	7.40	5.72
Cdh	1.00	1.00
Pdh Tj = Tbiv	11.10 kW	12.20 kW
COP Tj = Tbiv	3.12	2.19
Pdh Tj = TOL	11.10 kW	12.20 kW
COP Tj = TOL	2.76	2.19
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electrical	electrical
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Qhe	5726 kWh	7211 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency ηDHW	110 %
COP	2.62
Heating up time	1:07 h:min
Standby power input	34.2 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPRA16DV / ETVZ16S18D9W(G)

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	9.00 kW	7.24 kW
El input	1.80 kW	2.41 kW
COP	5.00	3.01
Indoor water flow rate	1.55 m³/h	0.89 m³/h

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	54 dB(A)	54 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	177 %	140 %
Prated	13.00 kW	13.00 kW
SCOP	4.51	3.58
Tbiv	-7 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	11.20 kW
COP Tj = -7°C	3.12	2.47
Cdh	1.00	1.00
Pdh Tj = +2°C	6.70 kW	6.90 kW
COP Tj = +2°C	4.44	3.56
Cdh	1.00	1.00
Pdh Tj = +7°C	5.70 kW	6.90 kW
COP Tj = +7°C	5.84	4.44
Cdh	1.00	1.00

Pdh Tj = 12°C	6.00 kW	6.20 kW
COP Tj = 12°C	7.40	5.72
Cdh	1.00	1.00
Pdh Tj = Tbiv	11.10 kW	12.20 kW
COP Tj = Tbiv	3.12	2.19
Pdh Tj = TOL	11.10 kW	12.20 kW
COP Tj = TOL	2.76	2.19
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electrical	electrical
Supplementary Heater: PSUP	9.00 kW	9.00 kW
Annual energy consumption Qhe	5726 kWh	7211 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency ηDHW	110 %
COP	2.62
Heating up time	1:07 h:min
Standby power input	34.2 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPRA16DW / ETVZ16S18D6V(G)

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	9.00 kW	7.24 kW
El input	1.23 kW	2.47 kW
COP	5.00	2.93
Indoor water flow rate	1.55 m³/h	0.89 m³/h

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	54 dB(A)	54 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	176 %	140 %
Prated	13.00 kW	13.00 kW
SCOP	4.48	3.57
Tbiv	-7 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.72 kW	11.10 kW
COP Tj = -7°C	2.97	2.43
Cdh	1.00	1.00
Pdh Tj = +2°C	6.87 kW	6.70 kW
COP Tj = +2°C	4.94	3.52
Cdh	1.00	1.00
Pdh Tj = +7°C	6.10 kW	6.50 kW
COP Tj = +7°C	5.75	4.54
Cdh	1.00	1.00

Pdh Tj = 12°C	5.50 kW	5.20 kW
COP Tj = 12°C	6.97	5.97
Cdh	1.00	1.00
Pdh Tj = Tbiv	10.72 kW	12.50 kW
COP Tj = Tbiv	2.97	2.12
Pdh Tj = TOL	11.80 kW	12.50 kW
COP Tj = TOL	2.84	2.12
WTOL	35 °C	55 °C
Poff	31 W	31 W
PTO	33 W	33 W
PSB	42 W	42 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electrical	electrical
Supplementary Heater: PSUP	6.00 kW	6.00 kW
Annual energy consumption Qhe	5765 kWh	7236 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency ηDHW	106 %
COP	2.51
Heating up time	1:07 h:min
Standby power input	42.9 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPRA16DW / ETVZ16S18D9W(G)

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	9.00 kW	7.24 kW
El input	1.23 kW	2.47 kW
COP	5.00	2.93
Indoor water flow rate	1.55 m³/h	0.89 m³/h

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	54 dB(A)	54 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	176 %	140 %
Prated	13.00 kW	13.00 kW
SCOP	4.48	3.57
Tbiv	-7 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.72 kW	11.10 kW
COP Tj = -7°C	2.97	2.43
Cdh	1.00	1.00
Pdh Tj = +2°C	6.87 kW	6.70 kW
COP Tj = +2°C	4.94	3.52
Cdh	1.00	1.00
Pdh Tj = +7°C	6.10 kW	6.50 kW
COP Tj = +7°C	5.75	4.54
Cdh	1.00	1.00

Pdh Tj = 12°C	5.50 kW	5.20 kW
COP Tj = 12°C	6.97	5.97
Cdh	1.00	1.00
Pdh Tj = Tbiv	10.72 kW	12.50 kW
COP Tj = Tbiv	2.97	2.12
Pdh Tj = TOL	11.80 kW	12.50 kW
COP Tj = TOL	2.84	2.12
WTOL	35 °C	55 °C
Poff	31 W	31 W
PTO	33 W	33 W
PSB	42 W	42 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electrical	electrical
Supplementary Heater: PSUP	9.00 kW	9.00 kW
Annual energy consumption Qhe	5765 kWh	7236 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency ηDHW	106 %
COP	2.51
Heating up time	1:07 h:min
Standby power input	42.9 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l