

This information was generated by the HP KEYMARK database on 7 Jul 2022

[Login](#)

Summary of	F1x55-12	Reg. No.	012-048
Certificate Holder			
Name	Nibe AB		
Address	Box 14	Zip	S-28521
City	Markaryd	Country	Sweden
Certification Body	RISE CERT		
Subtype title	F1x55-12		
Heat Pump Type	Brine/Water and Water/Water		
Refrigerant	R407c		
Mass of Refrigerant	2 kg		
Certification Date	15.06.2017		

Model: F1155-12 1x230

Configure model	
Model name	F1155-12 1x230
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Brine/Water Heat Pump

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	5.06 kW	4.46 kW
El input	1.04 kW	1.47 kW
COP	4.87	3.02

Colder Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	208 %	162 %
Prated	11.60 kW	12.40 kW
SCOP	5.40	4.25
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	7.10 kW	7.60 kW
COP Tj = -7°C	5.26	3.94
Pdh Tj = +2°C	4.30 kW	4.70 kW
COP Tj = +2°C	5.62	4.58
Pdh Tj = +7°C	2.80 kW	3.00 kW
COP Tj = +7°C	6.01	5.11
Pdh Tj = 12°C	2.70 kW	2.60 kW
COP Tj = 12°C	5.44	4.98
Pdh Tj = Tbiv	11.50 kW	12.30 kW
COP Tj = Tbiv	4.26	2.91

This information was generated by the HP KEYMARK database on 7 Jul 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	11.50 kW	12.30 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	4.26	2.91
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.97	0.98
WTOL	65 °C	65 °C
Poff	5 W	5 W
PTO	20 W	15 W
PSB	7 W	7 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q_{he}	5292 kWh	7173 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	201 %	157 %
Prated	11.00 kW	12.40 kW

This information was generated by the HP KEYMARK database on 7 Jul 2022

SCOP	5.23	4.13
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.30 kW	11.10 kW
COP Tj = -7°C	4.52	3.18
Cdh Tj = -7 °C	0.98	0.99
Pdh Tj = +2°C	6.30 kW	6.77 kW
COP Tj = +2°C	5.22	4.12
Cdh Tj = +2 °C	0.98	0.99
Pdh Tj = +7°C	4.10 kW	4.40 kW
COP Tj = +7°C	5.60	4.67
Cdh Tj = +7 °C	0.98	0.99
Pdh Tj = 12°C	2.70 kW	2.60 kW
COP Tj = 12°C	5.78	5.06
Cdh Tj = +12 °C	0.98	0.99
Pdh Tj = Tbiv	11.50 kW	12.30 kW
COP Tj = Tbiv	4.26	2.91
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.50 kW	12.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.26	2.91
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.98	0.99
WTOL	65 °C	65 °C

This information was generated by the HP KEYMARK database on 7 Jul 2022

Poff	5 W	5 W
PTO	20 W	15 W
PSB	7 W	7 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	4582 kWh	6213 kWh

Water/Water Heat Pump

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.33 kW	5.79 kW
El input	1.03 kW	1.54 kW
COP	6.12	3.75

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	263 %	204 %
Prated	14.00 kW	14.00 kW
SCOP	6.77	5.30
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	8.60 kW	8.60 kW
COP Tj = -7°C	6.50	4.85
Pdh Tj = +2°C	5.20 kW	2.20 kW
COP Tj = +2°C	7.13	5.76
Pdh Tj = +7°C	3.40 kW	3.40 kW
COP Tj = +7°C	7.84	6.65
Pdh Tj = 12°C	3.30 kW	3.20 kW
COP Tj = 12°C	7.39	6.58
Pdh Tj = Tbiv	14.00 kW	14.00 kW

This information was generated by the HP KEYMARK database on 7 Jul 2022

COP Tj = Tbiv	5.08	3.48
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	14.00 kW	14.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.08	3.48
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.96	0.97
WTOL	65 °C	65 °C
Poff	5 W	5 W
PTO	30 W	25 W
PSB	10 W	7 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5091 kWh	6497 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	253 %	197 %

This information was generated by the HP KEYMARK database on 7 Jul 2022

Prated	14.00 kW	14.00 kW
SCOP	6.52	5.12
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.50 kW	12.40 kW
COP Tj = -7°C	5.46	3.84
Pdh Tj = +2°C	7.60 kW	7.60 kW
COP Tj = +2°C	6.56	5.12
Pdh Tj = +7°C	4.90 kW	4.90 kW
COP Tj = +7°C	7.14	5.90
Pdh Tj = 12°C	3.30 kW	3.20 kW
COP Tj = 12°C	7.65	6.52
Pdh Tj = Tbiv	14.00 kW	14.00 kW
COP Tj = Tbiv	5.08	3.48
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	14.00 kW	14.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.08	3.48
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.97	0.98
WTOL	65 °C	65 °C
Poff	5 W	5 W
PTO	30 W	25 W
PSB	10 W	7 W

This information was generated by the HP KEYMARK database on 7 Jul 2022

PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	4433 kWh	5657 kWh

Model: F1155-12 3x400

Configure model	
Model name	F1155-12 3x400
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Brine/Water Heat Pump

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	5.06 kW	4.46 kW
El input	1.04 kW	1.47 kW
COP	4.87	3.02

Colder Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	208 %	162 %
Prated	11.60 kW	12.40 kW
SCOP	5.40	4.25
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	7.10 kW	7.60 kW
COP Tj = -7°C	5.26	3.94
Pdh Tj = +2°C	4.30 kW	4.70 kW
COP Tj = +2°C	5.62	4.58
Pdh Tj = +7°C	2.80 kW	3.00 kW
COP Tj = +7°C	6.01	5.11
Pdh Tj = 12°C	2.70 kW	2.60 kW
COP Tj = 12°C	5.44	4.98
Pdh Tj = Tbiv	11.50 kW	12.30 kW
COP Tj = Tbiv	4.26	2.91

This information was generated by the HP KEYMARK database on 7 Jul 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	11.50 kW	12.30 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	4.26	2.91
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.97	0.98
WTOL	65 °C	65 °C
Poff	5 W	5 W
PTO	20 W	15 W
PSB	7 W	7 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q_{he}	5292 kWh	7173 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	201 %	157 %
Prated	11.00 kW	12.40 kW

This information was generated by the HP KEYMARK database on 7 Jul 2022

SCOP	5.23	4.13
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.30 kW	11.10 kW
COP Tj = -7°C	4.52	3.18
Cdh Tj = -7 °C	0.98	0.99
Pdh Tj = +2°C	6.30 kW	6.77 kW
COP Tj = +2°C	5.22	4.12
Cdh Tj = +2 °C	0.98	0.99
Pdh Tj = +7°C	4.10 kW	4.40 kW
COP Tj = +7°C	5.60	4.67
Cdh Tj = +7 °C	0.98	0.99
Pdh Tj = 12°C	2.70 kW	2.60 kW
COP Tj = 12°C	5.78	5.06
Cdh Tj = +12 °C	0.98	0.99
Pdh Tj = Tbiv	11.50 kW	12.30 kW
COP Tj = Tbiv	4.26	2.91
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.50 kW	12.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.26	2.91
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.98	0.99
WTOL	65 °C	65 °C

This information was generated by the HP KEYMARK database on 7 Jul 2022

Poff	5 W	5 W
PTO	20 W	15 W
PSB	7 W	7 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	4582 kWh	6213 kWh

Water/Water Heat Pump

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.33 kW	5.79 kW
El input	1.03 kW	1.54 kW
COP	6.12	3.75

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	263 %	204 %
Prated	14.00 kW	14.00 kW
SCOP	6.77	5.30
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	8.60 kW	8.60 kW
COP Tj = -7°C	6.50	4.85
Pdh Tj = +2°C	5.20 kW	2.20 kW
COP Tj = +2°C	7.13	5.76
Pdh Tj = +7°C	3.40 kW	3.40 kW
COP Tj = +7°C	7.84	6.65
Pdh Tj = 12°C	3.30 kW	3.20 kW
COP Tj = 12°C	7.39	6.58
Pdh Tj = Tbiv	14.00 kW	14.00 kW

This information was generated by the HP KEYMARK database on 7 Jul 2022

COP Tj = Tbiv	5.08	3.48
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	14.00 kW	14.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.08	3.48
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.96	0.97
WTOL	65 °C	65 °C
Poff	5 W	5 W
PTO	30 W	25 W
PSB	10 W	7 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5091 kWh	6497 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	253 %	197 %

This information was generated by the HP KEYMARK database on 7 Jul 2022

Prated	14.00 kW	14.00 kW
SCOP	6.52	5.12
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.50 kW	12.40 kW
COP Tj = -7°C	5.46	3.84
Pdh Tj = +2°C	7.60 kW	7.60 kW
COP Tj = +2°C	6.56	5.12
Pdh Tj = +7°C	4.90 kW	4.90 kW
COP Tj = +7°C	7.14	5.90
Pdh Tj = 12°C	3.30 kW	3.20 kW
COP Tj = 12°C	7.65	6.52
Pdh Tj = Tbiv	14.00 kW	14.00 kW
COP Tj = Tbiv	5.08	3.48
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	14.00 kW	14.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.08	3.48
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.97	0.98
WTOL	65 °C	65 °C
Poff	5 W	5 W
PTO	30 W	25 W
PSB	10 W	7 W

This information was generated by the HP KEYMARK database on 7 Jul 2022

PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	4433 kWh	5657 kWh

Model: F1255-12 1x230

Configure model	
Model name	F1255-12 1x230
Application	Heating + DHW + low temp
Units	Indoor
Climate Zone	Colder Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz
Off-peak product	No

Brine/Water Heat Pump

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	5.06 kW	4.46 kW
El input	1.04 kW	1.47 kW
COP	4.87	3.02

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	208 %	162 %
Prated	11.60 kW	12.40 kW
SCOP	5.40	4.25
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	7.10 kW	7.60 kW
COP Tj = -7°C	5.26	3.94
Pdh Tj = +2°C	4.30 kW	4.70 kW
COP Tj = +2°C	5.62	4.58
Pdh Tj = +7°C	2.80 kW	3.00 kW
COP Tj = +7°C	6.01	5.11
Pdh Tj = 12°C	2.70 kW	2.60 kW
COP Tj = 12°C	5.44	4.98
Pdh Tj = Tbiv	11.50 kW	12.30 kW

This information was generated by the HP KEYMARK database on 7 Jul 2022

COP Tj = Tbiv	4.26	2.91
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.50 kW	12.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.26	2.91
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.97	0.98
WTOL	65 °C	65 °C
Poff	5 W	5 W
PTO	20 W	15 W
PSB	7 W	7 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5292 kWh	7173 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	201 %	157 %

This information was generated by the HP KEYMARK database on 7 Jul 2022

Prated	11.00 kW	12.40 kW
SCOP	5.23	4.13
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.30 kW	11.10 kW
COP Tj = -7°C	4.52	3.18
Cdh Tj = -7 °C	0.98	0.99
Pdh Tj = +2°C	6.30 kW	6.77 kW
COP Tj = +2°C	5.22	4.12
Cdh Tj = +2 °C	0.98	0.99
Pdh Tj = +7°C	4.10 kW	4.40 kW
COP Tj = +7°C	5.60	4.67
Cdh Tj = +7 °C	0.98	0.99
Pdh Tj = 12°C	2.70 kW	2.60 kW
COP Tj = 12°C	5.78	5.06
Cdh Tj = +12 °C	0.98	0.99
Pdh Tj = Tbiv	11.50 kW	12.30 kW
COP Tj = Tbiv	4.26	2.91
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.50 kW	12.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.26	2.91
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.98	0.99

This information was generated by the HP KEYMARK database on 7 Jul 2022

WTOL	65 °C	65 °C
Poff	5 W	5 W
PTO	20 W	15 W
PSB	7 W	7 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	4582 kWh	6213 kWh

Domestic Hot Water (DHW)

Colder Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	98 %
COP	2.45
Heating up time	01:42 h:min
Standby power input	50.0 W
Reference hot water temperature	50.0 °C
Mixed water at 40°C	240 l

Average Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	98 %
COP	2.45
Heating up time	01:42 h:min
Standby power input	50.0 W
Reference hot water temperature	50.0 °C
Mixed water at 40°C	240 l

Water/Water Heat Pump

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.33 kW	5.79 kW
El input	1.03 kW	1.54 kW
COP	6.12	3.75

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	263 %	204 %
Prated	14.00 kW	14.00 kW
SCOP	6.77	5.30
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	8.60 kW	8.60 kW
COP Tj = -7°C	6.50	4.85
Pdh Tj = +2°C	5.20 kW	2.20 kW

This information was generated by the HP KEYMARK database on 7 Jul 2022

COP Tj = +2°C	7.13	5.76
Pdh Tj = +7°C	3.40 kW	3.40 kW
COP Tj = +7°C	7.84	6.65
Pdh Tj = 12°C	3.30 kW	3.20 kW
COP Tj = 12°C	7.39	6.58
Pdh Tj = Tbiv	14.00 kW	14.00 kW
COP Tj = Tbiv	5.08	3.48
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	14.00 kW	14.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.08	3.48
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.96	0.97
WTOL	65 °C	65 °C
Poff	5 W	5 W
PTO	30 W	25 W
PSB	10 W	7 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5091 kWh	6497 kWh

Average Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	253 %	197 %
Prated	14.00 kW	14.00 kW
SCOP	6.52	5.12
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.50 kW	12.40 kW
COP Tj = -7°C	5.46	3.84
Pdh Tj = +2°C	7.60 kW	7.60 kW
COP Tj = +2°C	6.56	5.12
Pdh Tj = +7°C	4.90 kW	4.90 kW
COP Tj = +7°C	7.14	5.90
Pdh Tj = 12°C	3.30 kW	3.20 kW
COP Tj = 12°C	7.65	6.52
Pdh Tj = Tbiv	14.00 kW	14.00 kW
COP Tj = Tbiv	5.08	3.48

This information was generated by the HP KEYMARK database on 7 Jul 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	14.00 kW	14.00 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	5.08	3.48
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.97	0.98
WTOL	65 °C	65 °C
Poff	5 W	5 W
PTO	30 W	25 W
PSB	10 W	7 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q_{he}	4433 kWh	5657 kWh

Domestic Hot Water (DHW)

Colder Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	113 %
COP	2.82
Heating up time	01:32 h:min
Standby power input	45.0 W
Reference hot water temperature	49.0 °C
Mixed water at 40°C	235 l

Average Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	113 %
COP	2.82
Heating up time	01:32 h:min
Standby power input	45.0 W
Reference hot water temperature	49.0 °C
Mixed water at 40°C	235 l

Model: F1255-12 3x400

Configure model	
Model name	F1255-12 3x400
Application	Heating + DHW + low temp
Units	Indoor
Climate Zone	Colder Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz
Off-peak product	No

Brine/Water Heat Pump

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	5.06 kW	4.46 kW
El input	1.04 kW	1.47 kW
COP	4.87	3.02

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	208 %	162 %
Prated	11.60 kW	12.40 kW
SCOP	5.40	4.25
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	7.10 kW	7.60 kW
COP Tj = -7°C	5.26	3.94
Pdh Tj = +2°C	4.30 kW	4.70 kW
COP Tj = +2°C	5.62	4.58
Pdh Tj = +7°C	2.80 kW	3.00 kW
COP Tj = +7°C	6.01	5.11
Pdh Tj = 12°C	2.70 kW	2.60 kW
COP Tj = 12°C	5.44	4.98
Pdh Tj = Tbiv	11.50 kW	12.30 kW

This information was generated by the HP KEYMARK database on 7 Jul 2022

COP Tj = Tbiv	4.26	2.91
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.50 kW	12.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.26	2.91
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.97	0.98
WTOL	65 °C	65 °C
Poff	5 W	5 W
PTO	20 W	15 W
PSB	7 W	7 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5292 kWh	7173 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	201 %	157 %

This information was generated by the HP KEYMARK database on 7 Jul 2022

Prated	11.00 kW	12.40 kW
SCOP	5.23	4.13
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.30 kW	11.10 kW
COP Tj = -7°C	4.52	3.18
Cdh Tj = -7 °C	0.98	0.99
Pdh Tj = +2°C	6.30 kW	6.77 kW
COP Tj = +2°C	5.22	4.12
Cdh Tj = +2 °C	0.98	0.99
Pdh Tj = +7°C	4.10 kW	4.40 kW
COP Tj = +7°C	5.60	4.67
Cdh Tj = +7 °C	0.98	0.99
Pdh Tj = 12°C	2.70 kW	2.60 kW
COP Tj = 12°C	5.78	5.06
Cdh Tj = +12 °C	0.98	0.99
Pdh Tj = Tbiv	11.50 kW	12.30 kW
COP Tj = Tbiv	4.26	2.91
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.50 kW	12.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.26	2.91
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.98	0.99

This information was generated by the HP KEYMARK database on 7 Jul 2022

WTOL	65 °C	65 °C
Poff	5 W	5 W
PTO	20 W	15 W
PSB	7 W	7 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	4582 kWh	6213 kWh

Domestic Hot Water (DHW)

Colder Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	98 %
COP	2.45
Heating up time	01:42 h:min
Standby power input	50.0 W
Reference hot water temperature	50.0 °C
Mixed water at 40°C	240 l

Average Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	98 %
COP	2.45
Heating up time	01:42 h:min
Standby power input	50.0 W
Reference hot water temperature	50.0 °C
Mixed water at 40°C	240 l

Water/Water Heat Pump

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

EN 14511-2

	Low temperature	Medium temperature
Heat output	6.33 kW	5.79 kW
El input	1.03 kW	1.54 kW
COP	6.12	3.75

Colder Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	263 %	204 %
Prated	14.00 kW	14.00 kW
SCOP	6.77	5.30
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	8.60 kW	8.60 kW
COP Tj = -7°C	6.50	4.85
Pdh Tj = +2°C	5.20 kW	2.20 kW

This information was generated by the HP KEYMARK database on 7 Jul 2022

COP Tj = +2°C	7.13	5.76
Pdh Tj = +7°C	3.40 kW	3.40 kW
COP Tj = +7°C	7.84	6.65
Pdh Tj = 12°C	3.30 kW	3.20 kW
COP Tj = 12°C	7.39	6.58
Pdh Tj = Tbiv	14.00 kW	14.00 kW
COP Tj = Tbiv	5.08	3.48
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	14.00 kW	14.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.08	3.48
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.96	0.97
WTOL	65 °C	65 °C
Poff	5 W	5 W
PTO	30 W	25 W
PSB	10 W	7 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5091 kWh	6497 kWh

Average Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	253 %	197 %
Prated	14.00 kW	14.00 kW
SCOP	6.52	5.12
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.50 kW	12.40 kW
COP Tj = -7°C	5.46	3.84
Pdh Tj = +2°C	7.60 kW	7.60 kW
COP Tj = +2°C	6.56	5.12
Pdh Tj = +7°C	4.90 kW	4.90 kW
COP Tj = +7°C	7.14	5.90
Pdh Tj = 12°C	3.30 kW	3.20 kW
COP Tj = 12°C	7.65	6.52
Pdh Tj = Tbiv	14.00 kW	14.00 kW
COP Tj = Tbiv	5.08	3.48

This information was generated by the HP KEYMARK database on 7 Jul 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	14.00 kW	14.00 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	5.08	3.48
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.97	0.98
WTOL	65 °C	65 °C
Poff	5 W	5 W
PTO	30 W	25 W
PSB	10 W	7 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q_{he}	4433 kWh	5657 kWh

Domestic Hot Water (DHW)

Colder Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	113 %
COP	2.82
Heating up time	01:32 h:min
Standby power input	45.0 W
Reference hot water temperature	49.0 °C
Mixed water at 40°C	235 l

Average Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	113 %
COP	2.82
Heating up time	01:32 h:min
Standby power input	45.0 W
Reference hot water temperature	49.0 °C
Mixed water at 40°C	235 l