

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	Alféa Hybrid Duo Gaz R6	Reg. No.	012-020
Certificate Holder			
Name	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000
City	La Roche Sur Yon	Country	France
Certification Body	RISE CERT		
Subtype title	Alféa Hybrid Duo Gaz R6		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	1.1 kg		

Model: Alféa Hybrid Duo Gaz R6

Configure model

Model name	Alféa Hybrid Duo Gaz R6
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	5.90 kW	4.50 kW
El input	1.35 kW	1.79 kW
COP	4.37	2.51

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	63 dB(A)	63 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	169 %	115 %
Prated	5.00 kW	5.00 kW
SCOP	4.30	2.95
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.60 kW	4.00 kW
COP Tj = -7°C	2.70	1.80
Pdh Tj = +2°C	2.80 kW	2.50 kW
COP Tj = +2°C	4.20	2.90
Pdh Tj = +7°C	2.30 kW	1.70 kW
COP Tj = +7°C	6.00	4.00
Pdh Tj = 12°C	2.30 kW	2.10 kW
COP Tj = 12°C	8.30	5.80
Pdh Tj = Tbiv	4.60 kW	4.00 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP $T_j = T_{biv}$	2.70	1.80
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	4.50 kW	3.50 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.60	1.60
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.90	0.90
WTOL	80 °C	80 °C
P _{off}	6 W	6 W
PTO	23 W	16 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Gas	Gas
Supplementary Heater: PSUP	0.70 kW	1.00 kW
Annual energy consumption Q _{he}	2505 kWh	3180 kWh