

Page 1 of 4

This information was generated by the HP KEYMARK database on 18 Mar 2022

Login

Summary of	Buderus Logatherm WPS 17-1	Reg. No.	011-1W0184
Certificate Holder			
Name	Bosch Thermotechnik GmbH (Buderus)		
Address	Sophienstraße 30-32	Zip	35576
City	Wetzlar	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	Buderus Logatherm WPS 17-1		
Heat Pump Type	Brine/Water		
Refrigerant	R410A		
Mass of Refrigerant	2.8 kg		

This information was generated by the HP KEYMARK database on 18 Mar 2022

Model: Buderus Logatherm WPS 17-1

Configure model			
Model name	Buderus Logatherm WPS 17-1		
Application	Heating (medium temp)		
Units	Indoor		
Climate Zone	n/a		
Reversibility	No		
Cooling mode application (optional)	n/a		

General Data		
Power supply	3x400V 50Hz	

Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	17.00 kW	15.79 kW	
El input	3.92 kW	5.54 kW	
СОР	4.34	2.85	

EN 14511-4		
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed	
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	

Average Climate



This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	47 dB(A)	47 dB(A)

EN 14825			
	Low temperature	Medium temperature	
η_{s}	176 %	130 %	
Prated	19.00 kW	18.00 kW	
SCOP	4.60	3.45	
Tbiv	-7 °C	-7 °C	
TOL	-10 °C	-10 °C	
Pdh Tj = -7°C	16.70 kW	15.70 kW	
COP Tj = -7°C	4.42	3.01	
Pdh Tj = +2°C	16.90 kW	15.90 kW	
COP Tj = +2°C	4.61	3.39	
Pdh Tj = +7°C	17.00 kW	16.20 kW	
COP Tj = +7°C	4.78	3.76	
Pdh Tj = 12°C	17.10 kW	16.50 kW	
COP Tj = 12°C	4.95	4.14	
Pdh Tj = Tbiv	16.70 kW	15.70 kW	
COP Tj = Tbiv	4.42	3.01	

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 4 of 4 This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	16.70 kW	15.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.33	2.84
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	62 °C	62 °C
Poff	6 W	6 W
РТО	6 W	6 W
PSB	6 W	6 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.30 kW	2.10 kW
Annual energy consumption Qhe	8469 kWh	10627 kWh