

This information was generated by the HP KEYMARK database on 22 Jun 2022

[Login](#)

Summary of	i-SHWAK V4 06	Reg. No.	ICIM-PDC-000076-00
Certificate Holder			
Name	Advantix S.p.A.		
Address	Via San Giuseppe Lavoratore, 24	Zip	37040
City	Arcole Verona	Country	Italy
Certification Body	ICIM S.p.A.		
Subtype title	i-SHWAK V4 06		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	2.68 kg		
Certification Date	26.05.2020		
Testing basis	HP KEYMARK certification scheme rules rev. no. 7		

Model: i-SHWAK V4 06

Configure model

Model name	i-SHWAK V4 06
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	6.57 kW	5.64 kW
El input	1.50 kW	2.32 kW
COP	4.38	2.43

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	1.74 kW
Cooling capacity	5.07
EER	2.91

EN 14825

This information was generated by the HP KEYMARK database on 22 Jun 2022

	+7°C/+12°C
P _{designc}	5.07 kW
SEER	3.82
P _{dc} T _j = 35°C	5.07 kW
EER T _j = 35°C	2.91
P _{dc} T _j = 30°C	3.74 kW
EER T _j = 30°C	4.04
C _{dc}	1.0
P _{dc} T _j = 25°C	3.40 kW
EER T _j = 25°C	4.09
C _{dc}	1.0
P _{dc} T _j = 20°C	3.68 kW
EER T _j = 20°C	4.92
C _{dc}	1.0
P _{off}	12 W
PTO	0 W
PSB	12 W
PCK	0 W
Annual energy consumption Q _{ce}	464 kWh

Average Climate

This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	151 %	119 %
Prated	5.00 kW	4.00 kW
SCOP	3.86	3.06
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.30 kW	4.50 kW
COP Tj = -7°C	2.68	1.57
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	3.40 kW	2.70 kW
COP Tj = +2°C	4.10	2.95
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.60 kW	3.30 kW
COP Tj = +7°C	4.15	4.57
Cdh Tj = +7 °C	1.00	1.00

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	3.70 kW	3.60 kW
COP Tj = 12°C	5.11	6.02
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	5.30 kW	4.50 kW
COP Tj = Tbiv	2.68	1.57
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.00 kW	4.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.34	1.45
WTOL	39 °C	39 °C
Poff	0 W	0 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2171 kWh	2329 kWh