

This information was generated by the HP KEYMARK database on 22 Jun 2022

[Login](#)

Summary of	WWK 302	Reg. No.	011-1W0386
Certificate Holder			
Name	STIEBEL ELTRON GmbH & Co KG		
Address	Dr. Stiebel Straße 33	Zip	37603
City	Holzminden	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	WWK 302		
Heat Pump Type	Heat Pump for Domestic Hot Water (DHW)		
Refrigerant	R134a		
Mass of Refrigerant	0.85 kg		
Certification Date	28.07.2020		

Model: WWK 302

Configure model	
Model name	WWK 302
Units	Indoor
Climate zone (for heating)	n/a
Heat Source	n/a
Any additional heat sources	n/a

General Data	
Power supply	1x230V 50Hz
Off-peak product	No

Domestic Hot Water (DHW)

Average Climate

EN 12102-2	
Sound power level indoor	60 dB(A)

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	120 %
COP	2.91
Heating up time	11:10 h:min
Standby power input	92.0 W
Reference hot water temperature	59.8 °C
Mixed water at 40°C	457 l

Model: WWK 302 H

Configure model	
Model name	WWK 302 H
Units	Indoor
Climate zone (for heating)	n/a
Heat Source	n/a
Any additional heat sources	n/a

General Data	
Power supply	1x230V 50Hz
Off-peak product	No

Domestic Hot Water (DHW)

Average Climate

EN 12102-2	
Sound power level indoor	60 dB(A)

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	120 %
COP	2.91
Heating up time	11:10 h:min
Standby power input	92.0 W
Reference hot water temperature	59.8 °C
Mixed water at 40°C	457 l