

Page 1 of 3 This information was generated by the HP KEYMARK database on 22 Jun 2022

Login

Summary of	VIESSMANN Vitocal 060-A Typ T0E-ze 060-A (250I)	Reg. No.	011-1W0339	
Certificate Holder				
Name	Viessmann Faulquemont SAS			
Address	Avenue André Gouy	Zip	F-57380	
City	Faulquemont	Country	France	
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH			
Subtype title	VIESSMANN Vitocal 060-A Typ T0E-ze 060-A (250I)			
Heat Pump Type	Heat Pump for Domestic Hot Water (DHW)			
Refrigerant	R1234ze			
Mass of Refrigerant	1.35 kg			
Certification Date	27.02.2020			



 $$\operatorname{\textit{Page}}\xspace$ 2 of 3 This information was generated by the HP KEYMARK database on 22 Jun 2022

Model: Viessmann Vitocal 060-A Typ T0E-ze 060-

Configure model			
Model name	Viessmann Vitocal 060-A Typ T0E-ze 060-A		
Units	Indoor		
Climate zone (for heating)	n/a		
Heat Source	Outdoor Air		
Any additional heat sources	n/a		

General Data		
Power supply	1x230V 50Hz	
Off-peak product	Yes	



This information was generated by the HP KEYMARK database on 22 Jun 2022

Domestic Hot Water (DHW)

Average Climate

EN 12102-2		
Sound power level indoor	53 dB(A)	

EN 16147			
Declared load profile	L		
Efficiency ηDHW	132 %		
СОР	3.17		
Heating up time	9:47 h:min		
Standby power input	24.0 W		
Reference hot water temperature	53.3 °C		
Mixed water at 40°C	350 I		

Operating test

EN 16147		
Temperature operating range	passed	
Safety devices checking test	passed	
Condensate draining	passed	