

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	LW 310	Reg. No.	041-K001-41
Certificate Holder			
Name	ait-deutschland GmbH		
Address	Industriestr. 3	Zip	95359
City	Kasendorf	Country	Germany
Certification Body	BRE Global Limited		
Subtype title	LW 310		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R404A		
Mass of Refrigerant	10 kg		
Certification Date	08.10.2019		

Model: LW 310 (L)

Configure model	
Model name	LW 310 (L)
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	35.00 kW	33.42 kW
El input	8.75 kW	13.15 kW
COP	4.00	2.54

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	68 dB(A)	68 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	151 %	122 %
Prated	28.28 kW	26.86 kW
SCOP	3.86	3.11
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	25.02 kW	23.76 kW
COP Tj = -7°C	2.92	2.03
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	31.12 kW	30.53 kW
COP Tj = +2°C	3.67	3.02
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	19.40 kW	19.05 kW
COP Tj = +7°C	4.86	4.05
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	21.20 kW	21.11 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = 12°C	5.26	4.92
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	25.02 kW	23.76 kW
COP Tj = Tbiv	2.92	2.03
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	22.93 kW	21.51 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.63	1.76
WTOL	58 °C	58 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	5.35 kW	5.35 kW
Annual energy consumption Qhe	15151 kWh	17816 kWh

Warmer Climate

EN 14825		
	Low temperature	Medium temperature
η_s	186 %	145 %
Prated	31.00 kW	29.67 kW
SCOP	4.73	3.70

This information was generated by the HP KEYMARK database on 18 Mar 2022

Tbiv	4 °C	4 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	31.00 kW	29.67 kW
COP Tj = +2°C	3.52	2.38
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	19.30 kW	18.56 kW
COP Tj = +7°C	4.62	3.26
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	21.16 kW	20.98 kW
COP Tj = 12°C	5.15	4.51
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	26.34 kW	25.26 kW
COP Tj = Tbiv	3.83	2.64
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	31.00 kW	29.67 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.52	2.38
WTOL	58 °C	58 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity

This information was generated by the HP KEYMARK database on 18 Mar 2022

Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	8750 kWh	10714 kWh

Colder Climate

EN 14825		
	Low temperature	Medium temperature
η_s	131 %	107 %
Prated	29.62 kW	28.06 kW
SCOP	3.36	2.76
T _{biv}	-12 °C	-12 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	25.20 kW	24.32 kW
COP T _j = -7°C	3.10	2.35
C _{dh} T _j = -7 °C	1.00	1.00
P _{dh} T _j = +2°C	31.26 kW	30.87 kW
COP T _j = +2°C	3.85	3.36
C _{dh} T _j = +2 °C	1.00	1.00
P _{dh} T _j = +7°C	19.47 kW	19.25 kW
COP T _j = +7°C	5.05	4.47
C _{dh} T _j = +7 °C	1.00	1.00
P _{dh} T _j = 12°C	21.19 kW	21.17 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = 12°C	5.21	5.15
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	21.83 kW	20.68 kW
COP Tj = Tbiv	2.68	1.90
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	16.26 kW	14.82 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.90	1.26
WTOL	58 °C	58 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	29.62 kW	28.06 kW
Annual energy consumption Qhe	21723 kWh	25057 kWh
Pdh Tj = -15°C (if TOL<-20°C)	19.75	18.50
COP Tj = -15°C (if TOL<-20°C)	2.38	1.65
Cdh Tj = -15 °C	1.00	1.00

Model: LW 310A

Configure model	
Model name	LW 310A
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	35.00 kW	33.42 kW
El input	8.75 kW	13.15 kW
COP	4.00	2.54

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	68 dB(A)	68 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	151 %	122 %
Prated	28.28 kW	26.86 kW
SCOP	3.86	3.11
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	25.02 kW	23.76 kW
COP Tj = -7°C	2.92	2.03
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	31.12 kW	30.53 kW
COP Tj = +2°C	3.67	3.02
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	19.40 kW	19.05 kW
COP Tj = +7°C	4.86	4.05
Cdh Tj = +7 °C	1.00	1.00

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	21.20 kW	21.11 kW
COP Tj = 12°C	5.26	4.92
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	25.02 kW	23.76 kW
COP Tj = Tbiv	2.92	2.03
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	22.93 kW	21.51 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.63	1.76
WTOL	58 °C	58 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	5.35 kW	5.35 kW
Annual energy consumption Qhe	15151 kWh	17816 kWh

Warmer Climate

EN 14825		
	Low temperature	Medium temperature
η_s	186 %	145 %
Prated	31.00 kW	29.67 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

SCOP	4.73	3.70
Tbiv	4 °C	4 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	31.00 kW	29.67 kW
COP Tj = +2°C	3.52	2.38
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	19.30 kW	18.56 kW
COP Tj = +7°C	4.62	3.26
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	21.16 kW	20.98 kW
COP Tj = 12°C	5.15	4.51
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	26.34 kW	25.26 kW
COP Tj = Tbiv	3.83	2.64
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	31.00 kW	29.67 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.52	2.38
WTOL	58 °C	58 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W

This information was generated by the HP KEYMARK database on 18 Mar 2022

Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	8750 kWh	10714 kWh

Colder Climate

EN 14825		
	Low temperature	Medium temperature
η_s	131 %	107 %
Prated	29.62 kW	28.06 kW
SCOP	3.36	2.76
T _{biv}	-12 °C	-12 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	25.20 kW	24.32 kW
COP T _j = -7°C	3.10	2.35
C _{dh} T _j = -7 °C	1.00	1.00
P _{dh} T _j = +2°C	31.26 kW	30.87 kW
COP T _j = +2°C	3.85	3.36
C _{dh} T _j = +2 °C	1.00	1.00
P _{dh} T _j = +7°C	19.47 kW	19.25 kW
COP T _j = +7°C	5.05	4.47
C _{dh} T _j = +7 °C	1.00	1.00

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	21.19 kW	21.17 kW
COP Tj = 12°C	5.21	5.15
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	21.83 kW	20.68 kW
COP Tj = Tbiv	2.68	1.90
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	16.26 kW	14.82 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.90	1.26
WTOL	58 °C	58 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	29.62 kW	28.06 kW
Annual energy consumption Qhe	21723 kWh	25057 kWh
Pdh Tj = -15°C (if TOL<-20°C)	19.75	18.50
COP Tj = -15°C (if TOL<-20°C)	2.38	1.65
Cdh Tj = -15 °C	1.00	1.00