

[Login](#)

Summary of	DAIKIN ALTHERMA 3 R 7 F 4KW (230L)	Reg. No.	011-1W0366
Certificate Holder			
Name	DAIKIN Europe N.V.		
Address	Zandvoordestraat 300	Zip	B-8400
City	Oostende	Country	Belgium
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	DAIKIN ALTHERMA 3 R 7 F 4KW (230L)		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	1.5 kg		
Certification Date	09.04.2020		

Model: ERGA04DV7 / EHVH04S23D6V

Configure model	
Model name	ERGA04DV7 / EHVH04S23D6V
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.36 kW	4.90 kW
El input	0.83 kW	1.85 kW
COP	5.23	2.65

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	1.36 kW
Cooling capacity	4.52
EER	3.32

EN 14825

This information was generated by the HP KEYMARK database on 22 Jun 2022

	+7°C/+12°C
P _{designc}	4.50 kW
SEER	5.66
P _{dc} T _j = 35°C	4.52 kW
EER T _j = 35°C	3.32
P _{dc} T _j = 30°C	3.14 kW
EER T _j = 30°C	5.11
C _{dc}	1.0
P _{dc} T _j = 25°C	2.43 kW
EER T _j = 25°C	6.69
C _{dc}	1.0
P _{dc} T _j = 20°C	2.50 kW
EER T _j = 20°C	8.24
C _{dc}	1.0
P _{off}	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Q _{ce}	480 kWh

Average Climate

This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	192 %	127 %
Prated	6.0 kW	6.0 kW
SCOP	4.88	3.26
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.2 kW	5.3 kW
COP Tj = -7°C	3.23	1.97
Cdh Tj = -7 °C	1.00	1.0
Pdh Tj = +2°C	3.7 kW	3.3 kW
COP Tj = +2°C	4.94	3.23
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	3.2 kW	3.0 kW
COP Tj = +7°C	6.19	4.40
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	3.3 kW	3.3 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	6.2 kW	5.3 kW
COP Tj = Tbiv	3.23	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.2 kW	4.0 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.37
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.8 kW	2.0 kW
Annual energy consumption Qhe	2538 kWh	3806 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	104 %
COP	2.57
Heating up time	1:47 h:min
Standby power input	30.8 W
Reference hot water temperature	52.0 °C
Mixed water at 40°C	288 l

Model: ERGA04DV7 / EHVX04S23D3V

Configure model	
Model name	ERGA04DV7 / EHVX04S23D3V
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.36 kW	4.90 kW
El input	0.83 kW	1.85 kW
COP	5.23	2.65

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	1.36 kW
Cooling capacity	4.52
EER	3.32

EN 14825

This information was generated by the HP KEYMARK database on 22 Jun 2022

	+7°C/+12°C
P _{designc}	4.50 kW
SEER	5.66
P _{dc} T _j = 35°C	4.52 kW
EER T _j = 35°C	3.32
P _{dc} T _j = 30°C	3.14 kW
EER T _j = 30°C	5.11
C _{dc}	1.0
P _{dc} T _j = 25°C	2.43 kW
EER T _j = 25°C	6.69
C _{dc}	1.0
P _{dc} T _j = 20°C	2.50 kW
EER T _j = 20°C	8.24
C _{dc}	1.0
P _{off}	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Q _{ce}	480 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	195 %	129 %
Prated	6.0 kW	6.0 kW
SCOP	4.96	3.29
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.2 kW	5.3 kW
COP Tj = -7°C	3.23	1.97
Cdh Tj = -7 °C	1.00	1.0
Pdh Tj = +2°C	3.7 kW	3.3 kW
COP Tj = +2°C	4.94	3.23
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	3.2 kW	3.0 kW
COP Tj = +7°C	6.19	4.40
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	3.3 kW	3.3 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	6.2 kW	5.3 kW
COP Tj = Tbiv	3.23	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.2 kW	4.0 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.37
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.8 kW	2.0 kW
Annual energy consumption Qhe	2501 kWh	3769 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	105 %
COP	2.61
Heating up time	1:47 h:min
Standby power input	26.8 W
Reference hot water temperature	52.0 °C
Mixed water at 40°C	288 l

Model: ERGA04DV7 / EHVX04S23D6V

Configure model	
Model name	ERGA04DV7 / EHVX04S23D6V
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.36 kW	4.90 kW
El input	0.83 kW	1.85 kW
COP	5.23	2.65

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	1.36 kW
Cooling capacity	4.52
EER	3.32

EN 14825

This information was generated by the HP KEYMARK database on 22 Jun 2022

	+7°C/+12°C
P _{designc}	4.50 kW
SEER	5.66
P _{dc} T _j = 35°C	4.52 kW
EER T _j = 35°C	3.32
P _{dc} T _j = 30°C	3.14 kW
EER T _j = 30°C	5.11
C _{dc}	1.0
P _{dc} T _j = 25°C	2.43 kW
EER T _j = 25°C	6.69
C _{dc}	1.0
P _{dc} T _j = 20°C	2.50 kW
EER T _j = 20°C	8.24
C _{dc}	1.0
P _{off}	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Q _{ce}	480 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	195 %	129 %
Prated	6.0 kW	6.0 kW
SCOP	4.96	3.29
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.2 kW	5.3 kW
COP Tj = -7°C	3.23	1.97
Cdh Tj = -7 °C	1.00	1.0
Pdh Tj = +2°C	3.7 kW	3.3 kW
COP Tj = +2°C	4.94	3.23
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	3.2 kW	3.0 kW
COP Tj = +7°C	6.19	4.40
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	3.3 kW	3.3 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	6.2 kW	5.3 kW
COP Tj = Tbiv	3.23	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.2 kW	4.0 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.37
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.8 kW	2.0 kW
Annual energy consumption Qhe	2501 kWh	3769 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	104 %
COP	2.57
Heating up time	1:47 h:min
Standby power input	30.8 W
Reference hot water temperature	52.0 °C
Mixed water at 40°C	288 l

Model: ERGA04EV7 / EHVH04S23E6V

Configure model	
Model name	ERGA04EV7 / EHVH04S23E6V
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.36 kW	4.90 kW
El input	0.83 kW	1.85 kW
COP	5.23	2.65

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	1.36 kW
Cooling capacity	4.52
EER	3.32

EN 14825

This information was generated by the HP KEYMARK database on 22 Jun 2022

	+7°C/+12°C
P _{designc}	4.50 kW
SEER	5.66
P _{dc} T _j = 35°C	4.52 kW
EER T _j = 35°C	3.32
P _{dc} T _j = 30°C	3.14 kW
EER T _j = 30°C	5.11
C _{dc}	1.0
P _{dc} T _j = 25°C	2.43 kW
EER T _j = 25°C	6.69
C _{dc}	1.0
P _{dc} T _j = 20°C	2.50 kW
EER T _j = 20°C	8.24
C _{dc}	1.0
P _{off}	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Q _{ce}	480 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	192 %	127 %
Prated	6.0 kW	6.0 kW
SCOP	4.88	3.26
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.2 kW	5.3 kW
COP Tj = -7°C	3.23	1.97
Cdh Tj = -7 °C	1.00	1.0
Pdh Tj = +2°C	3.7 kW	3.3 kW
COP Tj = +2°C	4.94	3.23
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	3.2 kW	3.0 kW
COP Tj = +7°C	6.19	4.40
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	3.3 kW	3.3 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	6.2 kW	5.3 kW
COP Tj = Tbiv	3.23	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.2 kW	4.0 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.37
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.8 kW	2.0 kW
Annual energy consumption Qhe	2538 kWh	3806 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	105 %
COP	2.57
Heating up time	1:47 h:min
Standby power input	30.8 W
Reference hot water temperature	52.0 °C
Mixed water at 40°C	288 l

Model: ERGA04EV7 / EHVX04S23E3V

Configure model	
Model name	ERGA04EV7 / EHVX04S23E3V
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.36 kW	4.90 kW
El input	0.83 kW	1.85 kW
COP	5.23	2.65

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	1.36 kW
Cooling capacity	4.52
EER	3.32

EN 14825

This information was generated by the HP KEYMARK database on 22 Jun 2022

	+7°C/+12°C
P _{designc}	4.50 kW
SEER	5.66
P _{dc} T _j = 35°C	4.52 kW
EER T _j = 35°C	3.32
P _{dc} T _j = 30°C	3.14 kW
EER T _j = 30°C	5.11
C _{dc}	1.0
P _{dc} T _j = 25°C	2.43 kW
EER T _j = 25°C	6.69
C _{dc}	1.0
P _{dc} T _j = 20°C	2.50 kW
EER T _j = 20°C	8.24
C _{dc}	1.0
P _{off}	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Q _{ce}	480 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	195 %	129 %
Prated	6.0 kW	6.0 kW
SCOP	4.96	3.29
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.2 kW	5.3 kW
COP Tj = -7°C	3.23	1.97
Cdh Tj = -7 °C	1.00	1.0
Pdh Tj = +2°C	3.7 kW	3.3 kW
COP Tj = +2°C	4.94	3.23
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	3.2 kW	3.0 kW
COP Tj = +7°C	6.19	4.40
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	3.3 kW	3.3 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	6.2 kW	5.3 kW
COP Tj = Tbiv	3.23	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.2 kW	4.0 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.37
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.8 kW	2.0 kW
Annual energy consumption Qhe	2501 kWh	3769 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	106 %
COP	2.60
Heating up time	1:47 h:min
Standby power input	26.8 W
Reference hot water temperature	52.0 °C
Mixed water at 40°C	288 l

Model: ERGA04EV7 / EHVX04S23E6V(G)

Configure model	
Model name	ERGA04EV7 / EHVX04S23E6V(G)
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.36 kW	4.90 kW
El input	0.83 kW	1.85 kW
COP	5.23	2.65

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	1.36 kW
Cooling capacity	4.52
EER	3.32

EN 14825

This information was generated by the HP KEYMARK database on 22 Jun 2022

	+7°C/+12°C
P _{designc}	4.50 kW
SEER	5.66
P _{dc} T _j = 35°C	4.52 kW
EER T _j = 35°C	3.32
P _{dc} T _j = 30°C	3.14 kW
EER T _j = 30°C	5.11
C _{dc}	1.0
P _{dc} T _j = 25°C	2.43 kW
EER T _j = 25°C	6.69
C _{dc}	1.0
P _{dc} T _j = 20°C	2.50 kW
EER T _j = 20°C	8.24
C _{dc}	1.0
P _{off}	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Q _{ce}	480 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	195 %	129 %
Prated	6.0 kW	6.0 kW
SCOP	4.96	3.29
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.2 kW	5.3 kW
COP Tj = -7°C	3.23	1.97
Cdh Tj = -7 °C	1.00	1.0
Pdh Tj = +2°C	3.7 kW	3.3 kW
COP Tj = +2°C	4.94	3.23
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	3.2 kW	3.0 kW
COP Tj = +7°C	6.19	4.40
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	3.3 kW	3.3 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	6.2 kW	5.3 kW
COP Tj = Tbiv	3.23	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.2 kW	4.0 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.37
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.8 kW	2.0 kW
Annual energy consumption Qhe	2501 kWh	3769 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	105 %
COP	2.57
Heating up time	1:47 h:min
Standby power input	30.8 W
Reference hot water temperature	52.0 °C
Mixed water at 40°C	288 l