

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	TTF 27	Reg. No.	011-1W0280
Certificate Holder			
Name	tecalor GmbH		
Address	Fürstenbergerstr. 77	Zip	37603
City	Holzminen	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Name of testing laboratory	TÜV Rheinland Energy GmbH		
Subtype title	TTF 27		
Heat Pump Type	Brine/Water		
Refrigerant	R410a		
Mass Of Refrigerant	7.2 kg		

Model: TTF 27

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	29.69 kW	26.69 kW
El input	6.12 kW	9.57 kW
COP	4.85	2.79
Indoor water flow rate	3.65 m ³ /h	5.30 m ³ /h

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	55 dB(A)	55 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	203 %	132 %
Prated	30.00 kW	27.00 kW
SCOP	5.28	3.50
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	29.80 kW	27.00 kW
COP Tj = -7°C	4.92	2.92
Pdh Tj = +2°C	30.10 kW	28.00 kW
COP Tj = +2°C	5.31	3.49
Pdh Tj = +7°C	30.40 kW	28.70 kW
COP Tj = +7°C	5.71	3.93
Pdh Tj = 12°C	30.70 kW	29.30 kW
COP Tj = 12°C	6.16	4.47
Pdh Tj = Tbiv	29.70 kW	26.70 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

COP Tj = Tbiv	4.85	2.79
Pdh Tj = TOL	29.70 kW	26.70 kW
COP Tj = TOL	4.85	2.79
Cdh	0.90	0.90
WTOL	60 °C	60 °C
Poff	0 W	0 W
PTO	7 W	7 W
PSB	7 W	7 W
PCK	74 W	74 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	11619 kWh	15758 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	55 dB(A)	55 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	Medium temperature

This information was generated by the HP KEYMARK database on 17 Dec 2020

η_s	201 %	131 %
Prated	30.00 kW	27.00 kW
SCOP	5.23	3.48
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	29.70 kW	26.70 kW
COP Tj = +2°C	4.85	2.79
Pdh Tj = +7°C	30.00 kW	27.60 kW
COP Tj = +7°C	5.22	3.22
Pdh Tj = 12°C	30.50 kW	28.90 kW
COP Tj = 12°C	5.85	4.10
Pdh Tj = Tbiv	29.70 kW	26.70 kW
COP Tj = Tbiv	4.85	2.79
Pdh Tj = TOL	29.70 kW	26.70 kW
COP Tj = TOL	4.85	2.79
Cdh	0.90	0.90
WTOL	60 °C	60 °C
Poff	0 W	0 W
PTO	7 W	7 W
PSB	7 W	7 W
PCK	74 W	74 W

This information was generated by the HP KEYMARK database on 17 Dec 2020

Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	7587 kWh	10292 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	55 dB(A)	55 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	213 %	139 %
Prated	37.00 kW	34.00 kW
SCOP	5.53	3.68
T _{biv}	-15 °C	-15 °C
TOL	-22 °C	-22 °C
P _{dh} T _j = -7°C	30.20 kW	28.00 kW
COP T _j = -7°C	5.51	3.47
P _{dh} T _j = +2°C	30.50 kW	28.70 kW
COP T _j = +2°C	5.83	3.92

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = +7°C	30.60 kW	29.20 kW
COP Tj = +7°C	6.09	4.36
Pdh Tj = 12°C	30.70 kW	29.60 kW
COP Tj = 12°C	6.13	4.73
Pdh Tj = Tbiv	30.10 kW	27.60 kW
COP Tj = Tbiv	5.38	3.23
Pdh Tj = TOL	29.70 kW	26.70 kW
COP Tj = TOL	4.85	2.79
Cdh	0.90	0.90
WTOL	60 °C	60 °C
Poff	0 W	0 W
PTO	7 W	7 W
PSB	7 W	7 W
PCK	74 W	74 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	7.26 kW	7.13 kW
Annual energy consumption Qhe	1646 kWh	22680 kWh