

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	SWAN-A 190	Reg. No.	ICIM-PDC-000030-00
Certificate Holder			
Name	Clivet s.p.a.		
Address	Via camp lonc 25 c.ap.	Zip	I-32032
City	z.i. Villapaiera - Feltre (BL)	Country	Italy
Certification Body	ICIM S.p.A.		
Name of testing laboratory	-- TRANSITION RULES --		
Subtype title	SWAN-A 190		
Heat Pump Type	Heat Pump for Domestic Hot Water (DHW)		
Refrigerant	R134a		
Mass Of Refrigerant	1.1 kg		
Certification Date	02.05.2019		
Testing basis	HP KEYMARK certification scheme rules rev. no. 4		

Model: SWAN-A 190

General Data

Power supply	1x230V 50Hz
Off-peak product	No

Domestic Hot Water (DHW)

Average Climate

EN 12102-2

Sound power level indoor	51 dB(A)
--------------------------	----------

EN 16147

Declared load profile	L
Efficiency η_{DHW}	115 %
COP	2.76
Heating up time	7:01 h:min
Standby power input	26.3 W
Reference hot water temperature	53.8 °C
Mixed water at 40°C	234 l

Operating test

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Temperature operating range	passed
Safety devices checking test	passed
Condensate draining	passed