

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	AUREA 16	Reg. No.	012-SC1492-17
Certificate Holder			
Name	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000
City	La Roche Sur Yon	Country	France
Certification Body	RISE CERT		
Name of testing laboratory	RISE		
Subtype title	AUREA 16		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410a		
Mass Of Refrigerant	2.99 kg		

## Model: AUREA 16

### General Data

Power supply	1x230V 50Hz
--------------	-------------

## Heating

### EN 14511-2

	Low temperature	Medium temperature
Heat output	16.00 kW	12.80 kW
El input	4.08 kW	5.10 kW
COP	3.92	2.51
Indoor water flow rate	2.70 m <sup>3</sup> /h	1.41 m <sup>3</sup> /h

### EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

## Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	0 dB(A)	0 dB(A)
Sound power level outdoor	66 dB(A)	66 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	151 %	121 %
Prated	12.20 kW	10.30 kW
SCOP	3.86	3.10
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.79 kW	9.11 kW
COP Tj = -7°C	2.47	1.74
Pdh Tj = +2°C	6.57 kW	5.55 kW
COP Tj = +2°C	3.77	3.02
Pdh Tj = +7°C	8.24 kW	7.76 kW
COP Tj = +7°C	5.39	4.48
Pdh Tj = 12°C	5.14 kW	4.76 kW
COP Tj = 12°C	6.30	6.67
Pdh Tj = Tbiv	10.79 kW	9.11 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

COP $T_j = T_{biv}$	2.47	1.74
P <sub>dh</sub> $T_j = TOL$	10.34 kW	8.06 kW
COP $T_j = TOL$	2.07	1.55
C <sub>dh</sub>	0.96	0.97
WTOL	55 °C	55 °C
P <sub>off</sub>	5 W	5 W
PTO	60 W	50 W
PSB	5 W	5 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.90 kW	2.20 kW
Annual energy consumption Q <sub>he</sub>	6527 kWh	6857 kWh