

This information was generated by the HP KEYMARK database on 22 Jun 2022

[Login](#)

Summary of	Samsung EHS TDM Plus R410A 9 kW 1Phase (space heating/ 260L)	Reg. No.	011-1W0373
Certificate Holder			
Name	Samsung Electronics Air Conditioner Europe B.V.		
Address	Evert van de Beekstraat 310	Zip	1118 CX
City	Schiphol	Country	Netherlands
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	Samsung EHS TDM Plus R410A 9 kW 1Phase (space heating/ 260L)		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	2.4 kg		
Certification Date	29.07.2020		
Testing basis	European KEYMARK Scheme for Heat Pumps Rev. 7		

# Model: AE090MXTPEH/EU & AE260TNWTEH/EU

Configure model	
Model name	AE090MXTPEH/EU & AE260TNWTEH/EU
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

## Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	9.00 kW	7.66 kW
El input	2.12 kW	2.82 kW
COP	4.25	2.72

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## Average Climate

This information was generated by the HP KEYMARK database on 22 Jun 2022

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	69 dB(A)	69 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	174 %	117 %
Prated	6.00 kW	6.00 kW
SCOP	4.42	3.01
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.00 kW	4.90 kW
COP Tj = -7°C	2.67	1.77
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	3.00 kW	3.00 kW
COP Tj = +2°C	4.47	3.02
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.20 kW	2.30 kW
COP Tj = +7°C	5.74	3.90
Cdh Tj = +7 °C	0.90	0.90

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	3.00 kW	2.20 kW
COP Tj = 12°C	8.27	4.90
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	5.60 kW	5.50 kW
COP Tj = Tbiv	2.31	1.59
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.60 kW	5.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.31	1.59
WTOL	55 °C	55 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2660 kWh	3885 kWh

## Domestic Hot Water (DHW)

### Average Climate

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	105 %
COP	2.60
Heating up time	2:30 h:min
Standby power input	85.0 W
Reference hot water temperature	52.0 °C
Mixed water at 40°C	290 l