

Page 1 of 7

This information was generated by the HP KEYMARK database on 22 Jun 2022

Login

Summary of	WPF 40	Reg. No.	011-1W0277	
Certificate Holder				
Name	STIEBEL ELTRON GmbH & Co KG			
Address	Dr. Stiebel Straße 33	Zip	37603	
City	Holzminden	Country	Germany	
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH			
Subtype title	WPF 40			
Heat Pump Type	Brine/Water			
Refrigerant	R410A			
Mass of Refrigerant	10 kg	10 kg		
Certification Date	24.01.2019			



Model: WPF 40

Configure model			
Model name	WPF 40		
Application	Heating (medium temp)		
Units	Indoor		
Climate Zone	Colder Climate + Warmer Climate		
Reversibility	No		
Cooling mode application (optional)	n/a		

General Data		
Power supply	3x400V 50Hz	

Heating

COP

4.67

EN 14511-2		
	Low temperature	Medium temperature
Heat output	43.10 kW	40.20 kW
El input	9.23 kW	17.45 kW

2.99

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	

Warmer Climate



 $$\operatorname{\textit{Page}}\ 3$$ of 7 This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	59 dB(A)	59 dB(A)

EN 14825				
	Low temperature	Medium temperature		
η_{s}	194 %	133 %		
Prated	43.00 kW	40.00 kW		
SCOP	5.05	3.53		
Tbiv	2 °C	2 °C		
TOL	2 °C	2 °C		
Pdh Tj = $+2$ °C	43.10 kW	40.20 kW		
COP Tj = +2°C	4.67	2.88		
Pdh Tj = $+7^{\circ}$ C	43.40 kW	41.10 kW		
$COP Tj = +7^{\circ}C$	4.98	3.27		
Pdh Tj = 12°C	43.90 kW	42.40 kW		
COP Tj = 12°C	5.51	4.05		
Pdh Tj = Tbiv	43.10 kW	40.20 kW		
COP Tj = Tbiv	4.67	2.88		
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	43.10 kW	40.20 kW		
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.67	2.88		

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





This information was generated by the HP KEYMARK database on 22 Jun 2022

Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	0 W	0 W
PTO	7 W	7 W
PSB	7 W	7 W
PCK	74 W	74 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	11415 kWh	15248 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	59 dB(A)	59 dB(A)

EN 14825			
Low temperature	Medium temperature		
202 %	139 %		
53.00 kW	50.00 kW		
5.25	3.68		
-15 °C	-15 °C		
	Low temperature 202 % 53.00 kW 5.25		



Page 5 of 7 This information was generated by the HP KEYMARK database on 22 Jun 2022

Inis information was generated by the HP KEYMARK database on 22 Jun 2022					
TOL	-22 °C	-22 °C			
Pdh Tj = -7°C	43.60 kW	41.50 kW			
$COP Tj = -7^{\circ}C$	5.22	3.49			
Pdh Tj = +2°C	43.90 kW	42.10 kW			
COP Tj = +2°C	5.48	3.90			
Pdh Tj = +7°C	44.00 kW	42.60 kW			
$COP Tj = +7^{\circ}C$	5.70	4.28			
Pdh Tj = 12°C	44.00 kW	43.00 kW			
COP Tj = 12°C	5.73	4.60			
Pdh Tj = Tbiv	43.50 kW	41.10 kW			
COP Tj = Tbiv	5.11	3.27			
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	43.10 kW	40.20 kW			
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.67	2.88			
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90			
WTOL	60 °C	60 °C			
Poff	o w	0 W			
РТО	7 W	7 W			
PSB	7 W	7 W			
РСК	74 W	74 W			
Supplementary Heater: Type of energy input	Electricity	Electricity			
Supplementary Heater: PSUP	10.27 kW	10.14 kW			
	•	•			

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



This information was generated by the HP KEYMARK database on 22 Jun 2022

Annual energy consumption Qhe	25071 kWh	33723 kWh	

Average Climate

EN 12102-1				
	Low temperature	Medium temperature		
Sound power level indoor	59 dB(A)	59 dB(A)		

EN 14825			
	Low temperature	Medium temperature	
η_{s}	194 %	133 %	
Prated	43.00 kW	40.00 kW	
SCOP	5.05	3.53	
Tbiv	-10 °C	-10 °C	
TOL	-10 °C	-10 °C	
Pdh Tj = -7°C	43.20 kW	40.50 kW	
COP Tj = -7°C	4.73	3.00	
Pdh Tj = +2°C	43.50 kW	41.50 kW	
COP Tj = +2°C	5.05	3.51	
Pdh Tj = +7°C	43.80 kW	42.10 kW	
COP Tj = +7°C	5.38	3.90	
Pdh Tj = 12°C	44.10 kW	42.80 kW	
		·	

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 7 of 7 This information was generated by the HP KEYMARK database on 22 Jun 2022

	<u> </u>	
COP Tj = 12°C	5.76	4.38
Pdh Tj = Tbiv	43.10 kW	40.20 kW
COP Tj = Tbiv	4.67	2.88
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	43.10 kW	40.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.67	2.88
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	0 W	0 W
РТО	7 W	7 W
PSB	7 W	7 W
PCK	74 W	74 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	17606 kWh	23479 kWh