

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	Thermastage Compact Combi TCC13-16/ TOC16RIY	Reg. No.	012-C700093
Certificate Holder			
Name	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000
City	La Roche Sur Yon	Country	France
Certification Body	RISE CERT		
Subtype title	Thermastage Compact Combi TCC13-16/ TOC16RIY		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	2.5 kg		
Certification Date	22.12.2020		
Testing basis	HP Keymark Scheme 2017		

# Model: Compact Combi TCC13-16/ TOC16RIY

## Configure model

Model name	Compact Combi TCC13-16/ TOC16RIY
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

## General Data

Power supply	1x230V 50Hz
--------------	-------------

## Heating

### EN 14511-2

	Low temperature	Medium temperature
Heat output	13.50 kW	9.48 kW
El input	3.23 kW	3.95 kW
COP	4.18	2.40

### EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	69 dB(A)	69 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	148 %	113 %
Prated	13.00 kW	11.00 kW
SCOP	3.77	2.90
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	10.00 kW
COP Tj = -7°C	2.50	1.90
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	6.70 kW	6.10 kW
COP Tj = +2°C	3.60	2.80
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	6.20 kW	5.90 kW
COP Tj = +7°C	5.40	3.90
Cdh Tj = +7 °C	0.900	0.900

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	7.30 kW	7.10 kW
COP Tj = 12°C	6.90	5.10
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	11.10 kW	10.00 kW
COP Tj = Tbiv	2.50	1.90
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.80 kW	9.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.40	1.70
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	8 W	8 W
PTO	72 W	25 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.20 kW	1.70 kW
Annual energy consumption Qhe	6824 kWh	8041 kWh