

Testing basis

Page 1 of 2

## This information was generated by the HP KEYMARK database on 18 Mar 2022

<u>Login</u>				
Summary of	AQUA PLUS SWAN-2 190	Reg. No.	ICIM-PDC-000006	
Certificate Holder			'	
Name	Clivet s.p.a.			
Address	Via camp lonc 25 c.ap.	Zip	I-32032	
City	z.i. Villapaiera - Feltre (BL)	Country	Italy	
Certification Body	ICIM S.p.A.	ICIM S.p.A.		
Subtype title	AQUA PLUS SWAN-2 190	AQUA PLUS SWAN-2 190		
Heat Pump Type	Heat Pump for Domestic Hot Wat	Heat Pump for Domestic Hot Water (DHW)		
Refrigerant	R134a	R134a		
Mass of Refrigerant	1.1 kg			
Certification Date	12.07.2018			

HP KEYMARK certification scheme rules rev. no. 4



## Model: SWAN-2 190

Configure model				
Model name	SWAN-2 190			
Units	Indoor			
Climate zone (for heating)	n/a			
Heat Source	n/a			
Any additional heat sources	n/a			

General Data		
Power supply	1x230V 50Hz	
Off-peak product	No	

## Domestic Hot Water (DHW)

## Average Climate

EN 16147		
Declared load profile	L	
Efficiency ηDHW	115 %	
СОР	2.76	
Reference hot water temperature	53.8 °C	
Mixed water at 40°C	234	
Heating up time	7:01 h:min	
Standby power input	26.3 W	

EN 12102-2	
Sound power level indoor	51 dB(A)