

Page 1 of 4

This information was generated by the HP KEYMARK database on 18 Mar 2022

Login

| Summary of | Hi-Therma Monobloc 4kW | Reg. No. | 041-K021-03 |
|---------------------|---|----------|-------------|
| Certificate Holder | | | |
| Name | Qingdao Hisense Hitachi Air-conditioning Systems Co.,Ltd. | | |
| Address | Qianwangang Road | Zip | 266555 |
| City | Qingdao, Shandong | Country | China |
| Certification Body | BRE Global Limited | | |
| Subtype title | Hi-Therma Monobloc 4kW | | |
| Heat Pump Type | Outdoor Air/Water | | |
| Refrigerant | R32 | | |
| Mass of Refrigerant | 1.17 kg | | |
| Certification Date | 01.03.2022 | | |
| Testing basis | Heat Pump Keymark Scheme Rules Rev 09 | | |

This information was generated by the HP KEYMARK database on 18 Mar 2022

Model: AHZ-044HCDS1

| Configure model | | | |
|-------------------------------------|-----------------------|--|--|
| Model name | AHZ-044HCDS1 | | |
| Application | Heating (medium temp) | | |
| Units | Outdoor | | |
| Climate Zone | n/a | | |
| Reversibility | Yes | | |
| Cooling mode application (optional) | n/a | | |

| General Data | | |
|--------------|-------------|--|
| Power supply | 1x230V 50Hz | |

Heating

| EN 14511-2 | | | |
|-------------|-----------------|--------------------|--|
| | Low temperature | Medium temperature | |
| Heat output | 4.40 kW | 4.40 kW | |
| El input | 0.86 kW | 1.47 kW | |
| СОР | 5.10 | 3.00 | |

| EN 14511-4 | | |
|--|--------|--|
| Shutting off the heat transfer medium flow | passed | |
| Complete power supply failure | passed | |
| Defrost test | passed | |
| Starting and operating test | passed | |

Average Climate



This information was generated by the HP KEYMARK database on 18 Mar 2022

| EN 12102-1 | | | |
|---------------------------|-----------------|--------------------|--|
| | Low temperature | Medium temperature | |
| Sound power level outdoor | 61 dB(A) | 61 dB(A) | |

| | EN 14825 | |
|----------------|-----------------|--------------------|
| | Low temperature | Medium temperature |
| η_{s} | 204 % | 136 % |
| Prated | 4.61 kW | 4.09 kW |
| SCOP | 5.17 | 3.47 |
| Tbiv | -7 °C | -7 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 4.05 kW | 3.60 kW |
| COP Tj = -7°C | 3.26 | 2.08 |
| Cdh Tj = -7 °C | 0.900 | 0.900 |
| Pdh Tj = +2°C | 2.48 kW | 2.26 kW |
| COP Tj = +2°C | 5.02 | 3.44 |
| Cdh Tj = +2 °C | 0.900 | 0.900 |
| Pdh Tj = +7°C | 1.67 kW | 1.49 kW |
| COP Tj = +7°C | 6.70 | 4.33 |
| Cdh Tj = +7 °C | 0.900 | 0.900 |
| Pdh Tj = 12°C | 1.14 kW | 1.02 kW |

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 4 of 4 This information was generated by the HP KEYMARK database on 18 Mar 2022

| COP Tj = 12°C | 8.74 | 6.66 |
|---|-------------|-------------|
| Cdh Tj = +12 °C | 0.900 | 0.900 |
| Pdh Tj = Tbiv | 4.05 kW | 3.60 kW |
| COP Tj = Tbiv | 3.26 | 2.08 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 4.56 kW | 3.59 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.68 | 1.77 |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 0.900 | 0.900 |
| WTOL | 60 °C | 60 °C |
| Poff | 7 W | 7 W |
| РТО | 8 W | 8 W |
| PSB | 7 W | 7 W |
| PCK | o w | o w |
| Supplementary Heater: Type of energy input | Electricity | Electricity |
| Supplementary Heater: PSUP | 0.05 kW | 0.48 kW |
| Annual energy consumption Qhe | 1830 kWh | 2425 kWh |