

Page 1 of 4 This information was generated by the HP KEYMARK database on 17 Dec 2020

	<u> </u>		
Summary of	Ideal Boiler Alféa Extensa A.I. 8 R32	Reg. No.	012-C700014
Certificate Holder			-
Name	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000
City	La Roche Sur Yon	Country	France
Certification Body	RISE CERT		
Name of testing laboratory	n/a		
Subtype title	Ideal Boiler Alféa Extensa A.I. 8 R32		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass Of Refrigerant	1.02 kg		
Certification Date	04.03.2020		
Testing basis	HP Keymark Scheme Rules rev 7		



This information was generated by the HP KEYMARK database on 17 Dec 2020

Model: Ideal Boiler Alféa Extensa A.I. 8 R32

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	7.50 kW	7.00 kW	
El input	1.69 kW	2.63 kW	
СОР	4.43	2.66	
Indoor water flow rate	0.45 m³/h	0.56 m³/h	

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	

Average Climate



 $$\operatorname{\textit{Page}}\xspace$ 3 of 4 This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{s}	177 %	128 %
Prated	7.00 kW	6.00 kW
SCOP	4.50	3.28
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.80 kW	5.50 kW
COP Tj = -7°C	2.70	1.91
Cdh	1.00	1.00
Pdh Tj = +2°C	3.50 kW	3.30 kW
COP Tj = +2°C	4.35	3.18
Cdh	1.00	1.00
Pdh Tj = +7°C	2.30 kW	2.10 kW
COP Tj = +7°C	6.32	4.52
Cdh	1.00	1.00

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



 $$\operatorname{\textit{Page}}4 of 4$ This information was generated by the HP KEYMARK database on 17 Dec 2020$

Pdh Tj = 12°C	2.50 kW	2.40 kW
COP Tj = 12°C	8.07	6.37
Cdh	1.00	1.00
Pdh Tj = Tbiv	5.80 kW	5.50 kW
COP Tj = Tbiv	2.70	1.91
Pdh Tj = TOL	5.60 kW	5.00 kW
COP Tj = TOL	2.35	1.69
WTOL	55 °C	55 °C
Poff	4 W	4 W
РТО	14 W	14 W
PSB	10 W	10 W
PCK	o w	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.90 kW	1.20 kW
Annual energy consumption Qhe	2982 kWh	3903 kWh