Login

Summary of	DAIKIN ALTHERMA 3 R W/F 4KW (180L) (/A)	Reg. No.	011-1W0218
Certificate Holder			
Name	DAIKIN Europe N.V.		
Address	Zandvoordestraat 300	Zip	B-8400
City	Oostende	Country	Belgium
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	DAIKIN ALTHERMA 3 R W/F 4KW (180L) (/A)		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	1.5 kg		
Certification Date	11.06.2018		
Testing basis	HP KEYMARK certification scheme rules rev. 7		

Model: ERGA04DV(A) / EHVH04S18D6V(G)

Configure model	
Model name	ERGA04DV(A) / EHVH04S18D6V(G)
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	4.30 kW	4.90 kW
El input	0.85 kW	1.85 kW
COP	5.10	2.65

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	176 %	127 %
Prated	6.00 kW	6.00 kW
SCOP	4.48	3.26
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.50 kW	5.30 kW
COP Tj = -7°C	2.90	1.97
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	3.30 kW	3.30 kW
COP Tj = +2°C	4.33	3.23
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.19	4.40
Cdh Tj = +7 °C	1.00	1.00

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	5.50 kW	5.30 kW
COP Tj = Tbiv	2.90	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.20 kW	4.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.37
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.80 kW	2.00 kW
Annual energy consumption Qhe	2766 kWh	3806 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147

Declared load profile	L
Efficiency ηDHW	125 %
COP	3.10
Heating up time	1:34 h:min
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	238 l

Model: ERGA04DV(A) / EHVX04S18D3V(G)

Configure model	
Model name	ERGA04DV(A) / EHVX04S18D3V(G)
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	4.30 kW	4.90 kW
El input	0.85 kW	1.85 kW
COP	5.10	2.65

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	176 %	127 %
Prated	6.00 kW	6.00 kW
SCOP	4.48	3.26
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.50 kW	5.30 kW
COP Tj = -7°C	2.90	1.97
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	3.30 kW	3.30 kW
COP Tj = +2°C	4.33	3.23
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.19	4.40
Cdh Tj = +7 °C	1.00	1.00

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	5.50 kW	5.30 kW
COP Tj = Tbiv	2.90	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.20 kW	4.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.37
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.80 kW	2.00 kW
Annual energy consumption Qhe	2766 kWh	3806 kWh

Cooling

EN 14511-2

	+7°C/+12°C
El input	1.36 kW
Cooling capacity	4.52
EER	3.32

EN 14825

	+7°C/+12°C
Pdesignc	4.50 kW
SEER	5.66
Pdc Tj = 35°C	4.52 kW
EER Tj = 35°C	3.32
Pdc Tj = 30°C	3.14 kW
EER Tj = 30°C	5.11
Cdc	1.0
Pdc Tj = 25°C	2.43 kW
EER Tj = 25°C	6.69
Cdc	1.0
Pdc Tj = 20°C	2.50 kW
EER Tj = 20°C	8.24
Cdc	1.0
Poff	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Qce	480 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147

Declared load profile	L
Efficiency ηDHW	127 %
COP	3.10
Heating up time	1:34 h:min
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	238 l

Model: ERGA04DV(A) / EHVX04S18D6V(G)

Configure model	
Model name	ERGA04DV(A) / EHVX04S18D6V(G)
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	4.30 kW	4.90 kW
El input	0.85 kW	1.85 kW
COP	5.10	2.65

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	179 %	129 %
Prated	6.00 kW	6.00 kW
SCOP	4.54	3.26
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.50 kW	5.30 kW
COP Tj = -7°C	2.90	1.97
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	3.30 kW	3.30 kW
COP Tj = +2°C	4.33	3.23
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.19	4.40
Cdh Tj = +7 °C	1.00	1.00

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	5.50 kW	5.30 kW
COP Tj = Tbiv	2.90	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.20 kW	4.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.37
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.80 kW	2.00 kW
Annual energy consumption Qhe	2729 kWh	3769 kWh

Cooling

EN 14511-2

	+7°C/+12°C
El input	1.36 kW
Cooling capacity	4.52
EER	3.32

EN 14825

	+7°C/+12°C
Pdesignc	4.50 kW
SEER	5.66
Pdc Tj = 35°C	4.52 kW
EER Tj = 35°C	3.32
Pdc Tj = 30°C	3.14 kW
EER Tj = 30°C	5.11
Cdc	1.0
Pdc Tj = 25°C	2.43 kW
EER Tj = 25°C	6.69
Cdc	1.0
Pdc Tj = 20°C	2.50 kW
EER Tj = 20°C	8.24
Cdc	1.0
Poff	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Qce	480 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147

Declared load profile	L
Efficiency ηDHW	125 %
COP	3.10
Heating up time	1:34 h:min
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	238 l

Model: ERGA04DV / EHVZ04S18D6V(G)

Configure model	
Model name	ERGA04DV / EHVZ04S18D6V(G)
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	4.30 kW	4.90 kW
El input	0.85 kW	1.85 kW
COP	5.10	2.65

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	176 %	127 %
Prated	6.00 kW	6.00 kW
SCOP	4.48	3.26
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.50 kW	5.30 kW
COP Tj = -7°C	2.90	1.97
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	3.30 kW	3.30 kW
COP Tj = +2°C	4.33	3.23
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.19	4.40
Cdh Tj = +7 °C	1.00	1.00

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	5.50 kW	5.30 kW
COP Tj = Tbiv	2.90	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.20 kW	4.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.37
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.80 kW	2.00 kW
Annual energy consumption Qhe	2766 kWh	3806 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147

Declared load profile	L
Efficiency ηDHW	125 %
COP	3.10
Heating up time	1:34 h:min
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	238 l

Model: ERGA04DV(A) / EHBH04D6V

Configure model	
Model name	ERGA04DV(A) / EHBH04D6V
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	4.30 kW	4.90 kW
El input	0.85 kW	1.85 kW
COP	5.10	2.65

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	176 %	127 %
Prated	6.00 kW	6.00 kW
SCOP	4.48	3.26
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.50 kW	5.30 kW
COP Tj = -7°C	2.90	1.97
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	3.30 kW	3.30 kW
COP Tj = +2°C	4.33	3.23
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.19	4.40
Cdh Tj = +7 °C	1.00	1.00

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	5.50 kW	5.30 kW
COP Tj = Tbiv	2.90	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.20 kW	4.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.37
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.80 kW	2.00 kW
Annual energy consumption Qhe	2766 kWh	3806 kWh

Model: ERGA04DV(A) / EHBX04D6V

Configure model	
Model name	ERGA04DV(A) / EHBX04D6V
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	4.30 kW	4.90 kW
El input	0.85 kW	1.85 kW
COP	5.10	2.65

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	179 %	129 %
Prated	6.00 kW	6.00 kW
SCOP	4.54	3.29
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.50 kW	5.30 kW
COP Tj = -7°C	2.90	1.97
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	3.30 kW	3.30 kW
COP Tj = +2°C	4.33	3.23
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.19	4.40
Cdh Tj = +7 °C	1.00	1.00

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	5.50 kW	5.30 kW
COP Tj = Tbiv	2.90	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.20 kW	4.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.37
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.80 kW	2.00 kW
Annual energy consumption Qhe	2729 kWh	3769 kWh

Cooling

EN 14511-2

	+7°C/+12°C
El input	1.36 kW
Cooling capacity	4.52
EER	3.32

EN 14825

	+7°C/+12°C
Pdesignc	4.50 kW
SEER	5.66
Pdc Tj = 35°C	4.52 kW
EER Tj = 35°C	3.32
Pdc Tj = 30°C	3.14 kW
EER Tj = 30°C	5.11
Cdc	1.0
Pdc Tj = 25°C	2.43 kW
EER Tj = 25°C	6.69
Cdc	1.0
Pdc Tj = 20°C	2.50 kW
EER Tj = 20°C	8.24
Cdc	1.0
Poff	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Qce	480 kWh

Model: ERGA04EV / EHVH04S18E6V + cooling kit

Configure model	
Model name	ERGA04EV / EHVH04S18E6V + cooling kit
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	4.30 kW	4.90 kW
El input	0.85 kW	1.85 kW
COP	5.10	2.65

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	176 %	127 %
Prated	6.00 kW	6.00 kW
SCOP	4.48	3.26
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.50 kW	5.30 kW
COP Tj = -7°C	2.90	1.97
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	3.30 kW	3.30 kW
COP Tj = +2°C	4.33	3.23
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.19	4.40
Cdh Tj = +7 °C	1.00	1.00

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	5.50 kW	5.30 kW
COP Tj = Tbiv	2.90	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.20 kW	4.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.37
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.80 kW	2.00 kW
Annual energy consumption Qhe	2766 kWh	3806 kWh

Cooling

EN 14511-2

	+7°C/+12°C
El input	1.36 kW
Cooling capacity	4.52
EER	3.32

EN 14825

	+7°C/+12°C
Pdesignc	4.50 kW
SEER	5.66
Pdc Tj = 35°C	4.52 kW
EER Tj = 35°C	3.32
Pdc Tj = 30°C	3.14 kW
EER Tj = 30°C	5.11
Cdc	1.0
Pdc Tj = 25°C	2.43 kW
EER Tj = 25°C	6.69
Cdc	1.0
Pdc Tj = 20°C	2.50 kW
EER Tj = 20°C	8.24
Cdc	1.0
Poff	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Qce	480 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147

Declared load profile	L
Efficiency ηDHW	125 %
COP	3.10
Heating up time	1:34 h:min
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	238 l

Model: ERGA04EV(A) / EHVX04S18E3V

Configure model	
Model name	ERGA04EV(A) / EHVX04S18E3V
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	4.30 kW	4.90 kW
El input	0.85 kW	1.85 kW
COP	5.10	2.65

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	179 %	129 %
Prated	6.00 kW	6.00 kW
SCOP	4.54	3.29
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.50 kW	5.30 kW
COP Tj = -7°C	2.90	1.97
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	3.30 kW	3.30 kW
COP Tj = +2°C	4.33	3.23
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.19	4.40
Cdh Tj = +7 °C	1.00	1.00

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	5.50 kW	5.30 kW
COP Tj = Tbiv	2.90	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.20 kW	4.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.37
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.80 kW	2.00 kW
Annual energy consumption Qhe	2729 kWh	3769 kWh

Cooling

EN 14511-2

	+7°C/+12°C
El input	1.36 kW
Cooling capacity	4.52
EER	3.32

EN 14825

	+7°C/+12°C
Pdesignc	4.50 kW
SEER	5.66
Pdc Tj = 35°C	4.52 kW
EER Tj = 35°C	3.32
Pdc Tj = 30°C	3.14 kW
EER Tj = 30°C	5.11
Cdc	1.0
Pdc Tj = 25°C	2.43 kW
EER Tj = 25°C	6.69
Cdc	1.0
Pdc Tj = 20°C	2.50 kW
EER Tj = 20°C	8.24
Cdc	1.0
Poff	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Qce	480 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147

Declared load profile	L
Efficiency ηDHW	125 %
COP	3.10
Heating up time	1:34 h:min
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	238 l

Model: ERGA04EV(A) / EHVX04S18E6V(G)

Configure model	
Model name	ERGA04EV(A) / EHVX04S18E6V(G)
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	4.30 kW	4.90 kW
El input	0.85 kW	1.85 kW
COP	5.10	2.65

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	179 %	129 %
Prated	6.00 kW	6.00 kW
SCOP	4.54	3.29
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.50 kW	5.30 kW
COP Tj = -7°C	2.90	1.97
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	3.30 kW	3.30 kW
COP Tj = +2°C	4.33	3.23
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.19	4.40
Cdh Tj = +7 °C	1.00	1.00

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	5.50 kW	5.30 kW
COP Tj = Tbiv	2.90	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.20 kW	4.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.37
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.80 kW	2.00 kW
Annual energy consumption Qhe	2729 kWh	3769 kWh

Cooling

EN 14511-2

	+7°C/+12°C
El input	1.36 kW
Cooling capacity	4.52
EER	3.32

EN 14825

	+7°C/+12°C
Pdesignc	4.50 kW
SEER	5.66
Pdc Tj = 35°C	4.52 kW
EER Tj = 35°C	3.32
Pdc Tj = 30°C	3.14 kW
EER Tj = 30°C	5.11
Cdc	1.0
Pdc Tj = 25°C	2.43 kW
EER Tj = 25°C	6.69
Cdc	1.0
Pdc Tj = 20°C	2.50 kW
EER Tj = 20°C	8.24
Cdc	1.0
Poff	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Qce	480 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147

Declared load profile	L
Efficiency ηDHW	125 %
COP	3.10
Heating up time	1:34 h:min
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	238 l

Model: ERGA04EV(A) / EHVH04S18E6V

Configure model	
Model name	ERGA04EV(A) / EHVH04S18E6V
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	4.30 kW	4.90 kW
El input	0.85 kW	1.85 kW
COP	5.10	2.65

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	176 %	127 %
Prated	6.00 kW	6.00 kW
SCOP	4.48	3.26
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.50 kW	5.30 kW
COP Tj = -7°C	2.90	1.97
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	3.30 kW	3.30 kW
COP Tj = +2°C	4.33	3.23
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.19	4.40
Cdh Tj = +7 °C	1.00	1.00

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	5.50 kW	5.30 kW
COP Tj = Tbiv	2.90	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.20 kW	4.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.37
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.80 kW	2.00 kW
Annual energy consumption Qhe	2766 kWh	3806 kWh

Cooling

EN 14511-2

	+7°C/+12°C
El input	1.36 kW
Cooling capacity	4.52
EER	3.32

EN 14825

	+7°C/+12°C
Pdesignc	4.50 kW
SEER	5.66
Pdc Tj = 35°C	4.52 kW
EER Tj = 35°C	3.32
Pdc Tj = 30°C	3.14 kW
EER Tj = 30°C	5.11
Cdc	1.0
Pdc Tj = 25°C	2.43 kW
EER Tj = 25°C	6.69
Cdc	1.0
Pdc Tj = 20°C	2.50 kW
EER Tj = 20°C	8.24
Cdc	1.0
Poff	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Qce	480 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147

Declared load profile	L
Efficiency ηDHW	125 %
COP	3.10
Heating up time	1:34 h:min
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	238 l

Model: ERGA04EV / EHVZ04S18E6V

Configure model	
Model name	ERGA04EV / EHVZ04S18E6V
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	4.30 kW	4.90 kW
El input	0.85 kW	1.85 kW
COP	5.10	2.65

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	176 %	127 %
Prated	6.00 kW	6.00 kW
SCOP	4.48	3.26
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.50 kW	5.30 kW
COP Tj = -7°C	2.90	1.97
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	3.30 kW	3.30 kW
COP Tj = +2°C	4.33	3.23
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.19	4.40
Cdh Tj = +7 °C	1.00	1.00

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	5.50 kW	5.30 kW
COP Tj = Tbiv	2.90	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.20 kW	4.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.37
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.80 kW	2.00 kW
Annual energy consumption Qhe	2766 kWh	3806 kWh

Cooling

EN 14511-2

	+7°C/+12°C
El input	1.36 kW
Cooling capacity	4.52
EER	3.32

EN 14825

	+7°C/+12°C
Pdesignc	4.50 kW
SEER	5.66
Pdc Tj = 35°C	4.52 kW
EER Tj = 35°C	3.32
Pdc Tj = 30°C	3.14 kW
EER Tj = 30°C	5.11
Cdc	1.0
Pdc Tj = 25°C	2.43 kW
EER Tj = 25°C	6.69
Cdc	1.0
Pdc Tj = 20°C	2.50 kW
EER Tj = 20°C	8.24
Cdc	1.0
Poff	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Qce	480 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147

Declared load profile	L
Efficiency ηDHW	125 %
COP	3.10
Heating up time	1:34 h:min
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	238 l

Model: ERGA04EV(A) / EHVH04SU18E6V

Configure model	
Model name	ERGA04EV(A) / EHVH04SU18E6V
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	4.30 kW	4.90 kW
El input	0.85 kW	1.85 kW
COP	5.10	2.65

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	176 %	127 %
Prated	6.00 kW	6.00 kW
SCOP	4.48	3.26
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.50 kW	5.30 kW
COP Tj = -7°C	2.90	1.97
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	3.30 kW	3.30 kW
COP Tj = +2°C	4.33	3.23
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.19	4.40
Cdh Tj = +7 °C	1.00	1.00

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	5.50 kW	5.30 kW
COP Tj = Tbiv	2.90	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.20 kW	4.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.37
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.80 kW	2.00 kW
Annual energy consumption Qhe	2766 kWh	3806 kWh

Cooling

EN 14511-2

	+7°C/+12°C
El input	1.36 kW
Cooling capacity	4.52
EER	3.32

EN 14825

	+7°C/+12°C
Pdesignc	4.50 kW
SEER	5.66
Pdc Tj = 35°C	4.52 kW
EER Tj = 35°C	3.32
Pdc Tj = 30°C	3.14 kW
EER Tj = 30°C	5.11
Cdc	1.0
Pdc Tj = 25°C	2.43 kW
EER Tj = 25°C	6.69
Cdc	1.0
Pdc Tj = 20°C	2.50 kW
EER Tj = 20°C	8.24
Cdc	1.0
Poff	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Qce	480 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147

Declared load profile	L
Efficiency ηDHW	125 %
COP	3.10
Heating up time	1:34 h:min
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	238 l

Model: ERGA04EV / EHVZ04S18E6V + cooling kit

Configure model	
Model name	ERGA04EV / EHVZ04S18E6V + cooling kit
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	n/a

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	4.30 kW	4.90 kW
El input	0.85 kW	1.85 kW
COP	5.10	2.65

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	176 %	127 %
Prated	6.00 kW	6.00 kW
SCOP	4.48	3.26
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.50 kW	5.30 kW
COP Tj = -7°C	2.90	1.97
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	3.30 kW	3.30 kW
COP Tj = +2°C	4.33	3.23
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.19	4.40
Cdh Tj = +7 °C	1.00	1.00

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	5.50 kW	5.30 kW
COP Tj = Tbiv	2.90	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.20 kW	4.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.37
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.80 kW	2.00 kW
Annual energy consumption Qhe	2766 kWh	3806 kWh

Cooling

EN 14511-2

	+7°C/+12°C
El input	1.36 kW
Cooling capacity	4.52
EER	3.32

EN 14825

	+7°C/+12°C
Pdesignc	4.50 kW
SEER	5.66
Pdc Tj = 35°C	4.52 kW
EER Tj = 35°C	3.32
Pdc Tj = 30°C	3.14 kW
EER Tj = 30°C	5.11
Cdc	1.0
Pdc Tj = 25°C	2.43 kW
EER Tj = 25°C	6.69
Cdc	1.0
Pdc Tj = 20°C	2.50 kW
EER Tj = 20°C	8.24
Cdc	1.0
Poff	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Qce	480 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147

Declared load profile	L
Efficiency ηDHW	125 %
COP	3.10
Heating up time	1:34 h:min
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	238 l

Model: ERGA04EV(A) / EHBX04E6V

Configure model	
Model name	ERGA04EV(A) / EHBX04E6V
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	4.30 kW	4.90 kW
El input	0.85 kW	1.85 kW
COP	5.10	2.65

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	179 %	129 %
Prated	6.00 kW	6.00 kW
SCOP	4.54	3.29
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.50 kW	5.30 kW
COP Tj = -7°C	2.90	1.97
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	3.30 kW	3.30 kW
COP Tj = +2°C	4.33	3.23
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.19	4.40
Cdh Tj = +7 °C	1.00	1.00

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	5.50 kW	5.30 kW
COP Tj = Tbiv	2.90	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.20 kW	4.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.37
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.80 kW	2.00 kW
Annual energy consumption Qhe	2729 kWh	3769 kWh

Cooling

EN 14511-2

	+7°C/+12°C
El input	1.36 kW
Cooling capacity	4.52
EER	3.32

EN 14825

	+7°C/+12°C
Pdesignc	4.50 kW
SEER	5.66
Pdc Tj = 35°C	4.52 kW
EER Tj = 35°C	3.32
Pdc Tj = 30°C	3.14 kW
EER Tj = 30°C	5.11
Cdc	1.0
Pdc Tj = 25°C	2.43 kW
EER Tj = 25°C	6.69
Cdc	1.0
Pdc Tj = 20°C	2.50 kW
EER Tj = 20°C	8.24
Cdc	1.0
Poff	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Qce	480 kWh

Model: ERGA04EV(A) / EHBH04E6V

Configure model	
Model name	ERGA04EV(A) / EHBH04E6V
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	4.30 kW	4.90 kW
El input	0.85 kW	1.85 kW
COP	5.10	2.65

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	179 %	129 %
Prated	6.00 kW	6.00 kW
SCOP	4.54	3.29
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.50 kW	5.30 kW
COP Tj = -7°C	2.90	1.97
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	3.30 kW	3.30 kW
COP Tj = +2°C	4.33	3.23
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.19	4.40
Cdh Tj = +7 °C	1.00	1.00

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	5.50 kW	5.30 kW
COP Tj = Tbiv	2.90	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.20 kW	4.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.37
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.80 kW	2.00 kW
Annual energy consumption Qhe	2729 kWh	3769 kWh

Cooling

EN 14511-2

	+7°C/+12°C
El input	1.36 kW
Cooling capacity	4.52
EER	3.32

EN 14825

	+7°C/+12°C
Pdesignc	4.50 kW
SEER	5.66
Pdc Tj = 35°C	4.52 kW
EER Tj = 35°C	3.32
Pdc Tj = 30°C	3.14 kW
EER Tj = 30°C	5.11
Cdc	1.0
Pdc Tj = 25°C	2.43 kW
EER Tj = 25°C	6.69
Cdc	1.0
Pdc Tj = 20°C	2.50 kW
EER Tj = 20°C	8.24
Cdc	1.0
Poff	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Qce	480 kWh

Model: ERGA04EV / EHBH04E6V + cooling kit

Configure model	
Model name	ERGA04EV / EHBH04E6V + cooling kit
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	4.30 kW	4.90 kW
El input	0.85 kW	1.85 kW
COP	5.10	2.65

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	176 %	127 %
Prated	6.00 kW	6.00 kW
SCOP	4.48	3.26
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.50 kW	5.30 kW
COP Tj = -7°C	2.90	1.97
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	3.30 kW	3.30 kW
COP Tj = +2°C	4.33	3.23
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.19	4.40
Cdh Tj = +7 °C	1.00	1.00

Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	5.50 kW	5.30 kW
COP Tj = Tbiv	2.90	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.20 kW	4.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.37
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.80 kW	2.00 kW
Annual energy consumption Qhe	2766 kWh	3806 kWh

Cooling

EN 14511-2

	+7°C/+12°C
El input	1.36 kW
Cooling capacity	4.52
EER	3.32

EN 14825

	+7°C/+12°C
Pdesignc	4.50 kW
SEER	5.66
Pdc Tj = 35°C	4.52 kW
EER Tj = 35°C	3.32
Pdc Tj = 30°C	3.14 kW
EER Tj = 30°C	5.11
Cdc	1.0
Pdc Tj = 25°C	2.43 kW
EER Tj = 25°C	6.69
Cdc	1.0
Pdc Tj = 20°C	2.50 kW
EER Tj = 20°C	8.24
Cdc	1.0
Poff	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Qce	480 kWh