

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	TTF 52	Reg. No.	011-1W0188
Certificate Holder			
Name	tecalor GmbH		
Address	Fürstenbergerstr. 77	Zip	37603
City	Holzminden	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	TTF 52		
Heat Pump Type	Brine/Water		
Refrigerant	R410A		
Mass of Refrigerant	12.5 kg		
Certification Date	04.09.2019		

Model: TTF 52

Configure model	
Model name	TTF 52
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	55.83 kW	52.18 kW
El input	11.61 kW	17.45 kW
COP	4.81	2.99

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 14825

	Low temperature	Medium temperature
η_s	200 %	138 %
Prated	56.00 kW	52.00 kW
SCOP	5.20	3.65
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	55.90 kW	52.50 kW
COP Tj = -7°C	4.87	3.12
Pdh Tj = +2°C	56.30 kW	53.80 kW
COP Tj = +2°C	5.20	3.64
Pdh Tj = +7°C	56.70 kW	54.60 kW
COP Tj = +7°C	5.53	4.03
Pdh Tj = 12°C	57.00 kW	55.40 kW
COP Tj = 12°C	5.90	4.52
Pdh Tj = Tbiv	55.80 kW	52.20 kW
COP Tj = Tbiv	4.81	2.99
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	55.80 kW	52.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.81	2.99
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C

This information was generated by the HP KEYMARK database on 18 Mar 2022

Poff	0 W	0 W
PTO	7 W	7 W
PSB	7 W	7 W
PCK	99 W	99 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	22209 kWh	29469 kWh

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	58 dB(A)	63 dB(A)
Sound power level outdoor	58 dB(A)	63 dB(A)

Warmer Climate

EN 14825		
	Low temperature	Medium temperature
η_s	199 %	138 %
Prated	56.00 kW	52.00 kW
SCOP	5.18	3.65
Tbiv	2 °C	2 °C
TOL	0 °C	0 °C

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = +2°C	55.80 kW	55.20 kW
COP Tj = +2°C	4.81	2.99
Pdh Tj = +7°C	56.20 kW	53.30 kW
COP Tj = +7°C	5.12	3.39
Pdh Tj = 12°C	56.80 kW	54.90 kW
COP Tj = 12°C	5.65	4.19
Pdh Tj = Tbiv	55.80 kW	52.20 kW
COP Tj = Tbiv	4.81	2.99
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	55.80 kW	52.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.81	2.99
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	0 W	0 W
PTO	7 W	7 W
PSB	7 W	7 W
PCK	99 W	99 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	14419 kWh	19157 kWh

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	58 dB(A)	63 dB(A)
Sound power level outdoor	58 dB(A)	63 dB(A)

Colder Climate

EN 14825		
	Low temperature	Medium temperature
η_s	207 %	144 %
Prated	69.00 kW	65.00 kW
SCOP	5.38	3.80
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	56.50 kW	53.80 kW
COP Tj = -7°C	5.36	3.62
Pdh Tj = +2°C	56.80 kW	54.60 kW
COP Tj = +2°C	5.63	4.03
Pdh Tj = +7°C	57.00 kW	55.30 kW
COP Tj = +7°C	5.84	4.42
Pdh Tj = 12°C	57.00 kW	55.70 kW
COP Tj = 12°C	5.88	4.74

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = Tbiv	56.40 kW	53.30 kW
COP Tj = Tbiv	5.25	3.39
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	55.80 kW	52.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.81	2.99
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	0 W	0 W
PTO	7 W	7 W
PSB	7 W	7 W
PCK	99 W	99 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	13.28 kW	13.12 kW
Annual energy consumption Qhe	31644 kWh	42330 kWh

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	58 dB(A)	63 dB(A)
Sound power level outdoor	58 dB(A)	63 dB(A)