

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	Áurea+ HP60 14 / AHP60 14	Reg. No.	ICIM-PDC-000124-00
Certificate Holder			
Name	Group Atlantic España - Soluciones Confort Térmico S.A.		
Address	Calle Antonio Machado, 65 - Edificio Sócrates	Zip	08840
City	Viladecans, Barcelona	Country	Spain
Certification Body	ICIM S.p.A.		
Subtype title	Áurea+ HP60 14 / AHP60 14		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	3.6 kg		
Certification Date	18.10.2021		
Testing basis	HP KEYMARK certification scheme rules rev. no. 7		

Model: HP60-14 / AHP60-14

Configure model	
Model name	HP60-14 / AHP60-14
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.10 kW	13.44 kW
El input	2.91 kW	4.35 kW
COP	4.85	3.09

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	176 %	130 %
Prated	12.00 kW	12.00 kW
SCOP	4.48	3.31
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-15 °C
Pdh Tj = -7°C	10.70 kW	10.30 kW
COP Tj = -7°C	2.98	2.10
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	6.50 kW	6.20 kW
COP Tj = +2°C	4.20	3.21
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	5.80 kW	5.70 kW
COP Tj = +7°C	5.98	4.19
Cdh Tj = +7 °C	0.980	0.986

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	6.70 kW	6.60 kW
COP Tj = 12°C	8.16	6.17
Cdh Tj = +12 °C	0.977	0.982
Pdh Tj = Tbiv	10.70 kW	10.30 kW
COP Tj = Tbiv	2.98	2.10
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.50 kW	10.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.69	1.96
WTOL	60 °C	60 °C
Poff	19 W	19 W
PTO	22 W	22 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5583 kWh	7259 kWh

Cooling

EN 14511-2

	+7°C/+12°C
El input	3.53 kW
Cooling capacity	11.48
EER	3.25

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	+7°C/+12°C
P _{designc}	11.48 kW
SEER	4.62
P _{dc} T _j = 35°C	11.48 kW
EER T _j = 35°C	3.25
P _{dc} T _j = 30°C	8.47 kW
EER T _j = 30°C	4.31
C _{dc}	1.0
P _{dc} T _j = 25°C	5.41 kW
EER T _j = 25°C	4.91
C _{dc}	1.0
P _{dc} T _j = 20°C	5.53 kW
EER T _j = 20°C	6.72
C _{dc}	1.0
P _{off}	19 W
PTO	0 W
PSB	19 W
PCK	30 W
Annual energy consumption Q _{ce}	1492 kWh

Model: HP60-14TR / AHP60-14TR

Configure model	
Model name	HP60-14TR / AHP60-14TR
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.10 kW	13.44 kW
El input	2.91 kW	4.35 kW
COP	4.85	3.09

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	176 %	130 %
Prated	12.00 kW	12.00 kW
SCOP	4.48	3.31
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-15 °C
Pdh Tj = -7°C	10.70 kW	10.30 kW
COP Tj = -7°C	2.98	2.10
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	6.50 kW	6.20 kW
COP Tj = +2°C	4.20	3.21
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	5.80 kW	5.70 kW
COP Tj = +7°C	5.98	4.19
Cdh Tj = +7 °C	0.980	0.986

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	6.70 kW	6.60 kW
COP Tj = 12°C	8.16	6.17
Cdh Tj = +12 °C	0.977	0.982
Pdh Tj = Tbiv	10.70 kW	10.30 kW
COP Tj = Tbiv	2.98	2.10
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.50 kW	10.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.69	1.96
WTOL	60 °C	60 °C
Poff	19 W	19 W
PTO	22 W	22 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5583 kWh	7259 kWh

Cooling

EN 14511-2

	+7°C/+12°C
El input	3.53 kW
Cooling capacity	11.48
EER	3.25

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	+7°C/+12°C
P _{designc}	11.48 kW
SEER	4.62
P _{dc} T _j = 35°C	11.48 kW
EER T _j = 35°C	3.25
P _{dc} T _j = 30°C	8.47 kW
EER T _j = 30°C	4.31
C _{dc}	1.0
P _{dc} T _j = 25°C	5.41 kW
EER T _j = 25°C	4.91
C _{dc}	1.0
P _{dc} T _j = 20°C	5.53 kW
EER T _j = 20°C	6.72
C _{dc}	1.0
P _{off}	19 W
PTO	0 W
PSB	19 W
PCK	30 W
Annual energy consumption Q _{ce}	1492 kWh