

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	L6 Split	Reg. No.	012-C700070
Certificate Holder			
Name	ait-deutschland GmbH		
Address	Industriestr. 3	Zip	95359
City	Kasendorf	Country	Germany
Certification Body	RISE CERT		
Subtype title	L6 Split		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	1.5 kg		
Certification Date	29.04.2020		
Testing basis	HP Keymark Scheme 2018		

Model: alpha innotec L6 Split-HT 6

Configure model	
Model name	alpha innotec L6 Split-HT 6
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	2.42 kW	1.57 kW
El input	0.50 kW	0.76 kW
COP	4.85	2.06

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	51 dB(A)	51 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	188 %	131 %
Prated	4.80 kW	5.30 kW
SCOP	4.77	3.35
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.30 kW	4.70 kW
COP Tj = -7°C	2.60	1.88
Pdh Tj = +2°C	2.60 kW	2.80 kW
COP Tj = +2°C	4.84	3.26
Pdh Tj = +7°C	1.70 kW	1.80 kW
COP Tj = +7°C	6.91	4.72
Pdh Tj = 12°C	2.70 kW	2.70 kW
COP Tj = 12°C	7.72	6.47
Pdh Tj = Tbiv	4.30 kW	4.70 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP $T_j = T_{biv}$	2.60	1.88
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	3.20 kW	4.10 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.24	1.77
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.98	0.99
WTOL	65 °C	65 °C
P _{off}	7 W	7 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.60 kW	1.20 kW
Annual energy consumption Q_{he}	2089 kWh	3248 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	91 %
COP	2.22
Heating up time	01:40 h:min
Mixed water at 40°C	230 l
Standby power input	45.0 W
Reference hot water temperature	51.0 °C

Model: NOVELAN L6 Split-CS 6

Configure model	
Model name	NOVELAN L6 Split-CS 6
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	n/a

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	2.42 kW	1.57 kW
El input	0.50 kW	0.76 kW
COP	4.85	2.06

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	51 dB(A)	51 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	188 %	131 %
Prated	4.80 kW	5.30 kW
SCOP	4.77	3.35
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.30 kW	4.70 kW
COP Tj = -7°C	2.60	1.88
Pdh Tj = +2°C	2.60 kW	2.80 kW
COP Tj = +2°C	4.84	3.26
Pdh Tj = +7°C	1.70 kW	1.80 kW
COP Tj = +7°C	6.91	4.72
Pdh Tj = 12°C	2.70 kW	2.70 kW
COP Tj = 12°C	7.72	6.47
Pdh Tj = Tbiv	4.30 kW	4.70 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP $T_j = T_{biv}$	2.60	1.88
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	3.20 kW	4.10 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.24	1.77
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.98	0.99
WTOL	65 °C	65 °C
P _{off}	7 W	7 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.60 kW	1.20 kW
Annual energy consumption Q_{he}	2089 kWh	3248 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	91 %
COP	2.22
Heating up time	01:40 h:min
Mixed water at 40°C	230 l
Standby power input	45.0 W
Reference hot water temperature	51.0 °C

Model: alpha innotec L6 Split-HM 6

Configure model	
Model name	alpha innotec L6 Split-HM 6
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	2.42 kW	1.57 kW
El input	0.50 kW	0.76 kW
COP	4.85	2.06

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	51 dB(A)	51 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	188 %	131 %
Prated	4.80 kW	5.30 kW
SCOP	4.77	3.35
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.30 kW	4.70 kW
COP Tj = -7°C	2.60	1.88
Pdh Tj = +2°C	2.60 kW	2.80 kW
COP Tj = +2°C	4.84	3.26
Pdh Tj = +7°C	1.70 kW	1.80 kW
COP Tj = +7°C	6.91	4.72
Pdh Tj = 12°C	2.70 kW	2.70 kW
COP Tj = 12°C	7.72	6.47
Pdh Tj = Tbiv	4.30 kW	4.70 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP $T_j = T_{biv}$	2.60	1.88
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	3.20 kW	4.10 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.24	1.77
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.98	0.99
WTOL	65 °C	65 °C
P _{off}	7 W	7 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.60 kW	1.20 kW
Annual energy consumption Q _{he}	2089 kWh	3248 kWh

Model: NOVELAN L6 Split-HV 6

Configure model	
Model name	NOVELAN L6 Split-HV 6
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	2.42 kW	1.57 kW
El input	0.50 kW	0.76 kW
COP	4.85	2.06

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	51 dB(A)	51 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	188 %	131 %
Prated	4.80 kW	5.30 kW
SCOP	4.77	3.35
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.30 kW	4.70 kW
COP Tj = -7°C	2.60	1.88
Pdh Tj = +2°C	2.60 kW	2.80 kW
COP Tj = +2°C	4.84	3.26
Pdh Tj = +7°C	1.70 kW	1.80 kW
COP Tj = +7°C	6.91	4.72
Pdh Tj = 12°C	2.70 kW	2.70 kW
COP Tj = 12°C	7.72	6.47
Pdh Tj = Tbiv	4.30 kW	4.70 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP $T_j = T_{biv}$	2.60	1.88
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	3.20 kW	4.10 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.24	1.77
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.98	0.99
WTOL	65 °C	65 °C
P _{off}	7 W	7 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.60 kW	1.20 kW
Annual energy consumption Q_{he}	2089 kWh	3248 kWh